

ATTACHMENT 2 TO AEP:NRC:0896K

PROPOSED REVISED TECHNICAL SPECIFICATION PAGES

8912040018 891128
PDR ADOCK 05000315
PDC

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the onsite Class 1E distribution system, and
- b. Two separate and independent diesel generators, each with:
 1. A separate day fuel tank containing a minimum of 70 gallons of fuel,
 2. A separate fuel storage system* containing a minimum indicated volume of 46,000 gallons of fuel, and
 3. A separate fuel transfer pump.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With an offsite circuit of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. offsite source by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter; and Surveillance Requirement 4.8.1.1.2.a.4 within 24 hours; restore at least two offsite circuits and two diesel generators to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With a diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the A.C. offsite sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter; and if the diesel generator became inoperable due to any cause other than preplanned preventive maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE diesel generator by performing Surveillance Requirement 4.8.1.1.2.a.4 within 24 hours; restore diesel generators to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. At the number of failures for the inoperable diesel indicated in Table 4.8-1 perform the Additional Reliability Actions prescribed in Table 4.8-1.

*Tanks are separate between diesels but shared between Units 1 and 2.

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
 1. A day fuel tank containing a minimum of 70 gallons of fuel,
 2. A fuel storage system containing a minimum indicated volume of 46,000 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS positive reactivity changes* until the minimum required A.C. electrical power sources are restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1 and 4.8.1.1.2 except for requirement 4.8.1.1.2.a.5.

*For purposes of this specification, addition of water from the RWST does not constitute a positive reactivity addition provided the boron concentration in the RWST is greater than the minimum required by Specification 3.1.2.7.b.2.

ELECTRICAL POWER SYSTEMS (Continued)

BASES

Removal of accumulated water as required by 4.8.1.1.2.b.2 is performed by drawing the contents off the bottom of the tank until acceptable results are obtained for either a tape test or a water and sediment test. An acceptable result for the water and sediment content is a measured value less than 0.05 percent volume.

The sample specified in 4.8.1.1.2.c.4 is sent offsite for testing. A serious attempt will be made to meet the 31-day limit on the offsite tests; however, if for some reason this limit is not met (e.g., if the sample is lost or broken or if the results are not received in 31 days), the diesel generators should not be considered inoperable. If the sample is lost, broken, or fails the offsite tests and the new oil has already been put into the storage tank, the offsite tests will be performed on a sample taken from the storage tank. If the results on the subsequent storage tank sample are not within specified limits, the diesel generators should be considered OPERABLE and the out-of-spec properties should be returned to within specification as soon as possible.

If the monthly storage tank sample taken in accordance with Specification 4.8.1.1.2.d fails the particulate contamination test, the diesel generators should be considered OPERABLE and the contamination level should be restored to below 10 mg/liter as soon as possible.

The precision leak-detection test described in Surveillance Requirement 4.8.1.1.2.f.2 should be performed as described in NFPA (National Fire Protection Association) - 329. As NFPA-329 is revised, the precision leak-detection test may be modified to incorporate changes to the test as described in the revisions to NFPA-329.

The minimum required diesel fuel oil volume is 43,240 gallons. This volume is consistent with operation of one diesel generator continuously for 7 days at rated load, as recommended in Regulatory Guide 1.137, entitled "Fuel Oil System for Standby Diesel Generators." The Technical Specifications require a minimum of 46,000 gallons of fuel. The 46,000 gallons is an indicated volume. This amount includes margin for characteristics such as location of the tank discharge pipes and slope of the tanks.

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the onsite Class 1E distribution system, and
- b. Two separate and independent diesel generators, each with:
 1. A separate day fuel tank containing a minimum of 70 gallons of fuel,
 2. A separate fuel storage system* containing a minimum indicated volume of 46,000 gallons of fuel, and
 3. A separate fuel transfer pump.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

- a. With an offsite circuit of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. offsite source by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter; and Surveillance Requirement 4.8.1.1.2.a.4 within 24 hours; restore at least two offsite circuits and two diesel generators to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.
- b. With a diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the A.C. offsite sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter; and if the diesel generator became inoperable due to any cause other than preplanned preventive maintenance or testing, demonstrate the OPERABILITY of the remaining OPERABLE diesel generator by performing Surveillance Requirement 4.8.1.1.2.a.4 within 24 hours; restore diesel generators to OPERABLE status within 72 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours. At the number of failures for the inoperable diesel indicated in Table 4.8-1 perform the Additional Reliability Actions prescribed in Table 4.8-1.

*Tanks are separate between diesels but shared between Units 1 and 2.

ELECTRICAL POWER SYSTEMS

SHUTDOWN

LIMITING CONDITION FOR OPERATION

3.8.1.2 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. One circuit between the offsite transmission network and the onsite Class 1E distribution system, and
- b. One diesel generator with:
 1. A day fuel tank containing a minimum of 70 gallons of fuel,
 2. A fuel storage system containing a minimum indicated volume of 46,000 gallons of fuel, and
 3. A fuel transfer pump.

APPLICABILITY: MODES 5 and 6.

ACTION:

With less than the above minimum required A.C. electrical power sources OPERABLE, suspend all operations involving CORE ALTERATIONS or positive reactivity changes* until the minimum required A.C. electrical power sources are restored to OPERABLE status.

SURVEILLANCE REQUIREMENTS

4.8.1.2 The above required A.C. electrical power sources shall be demonstrated OPERABLE by the performance of each of the Surveillance Requirements of 4.8.1.1.1 and 4.8.1.1.2 except for requirement 4.8.1.1.2.a.5.

*For purposes of this specification, addition of water from the RWST does not constitute a positive reactivity addition provided the boron concentration in the RWST is greater than the minimum required by Specification 3.1.2.7.b.2.

ELECTRICAL POWER SYSTEMS (Continued)

BASES

Removal of accumulated water as required by 4.8.1.1.2.b.2 is performed by drawing the contents off the bottom of the tank until acceptable results are obtained for either a tape test or a water and sediment test. An acceptable result for the water and sediment content is a measured value less than 0.05 percent volume.

The sample specified in 4.8.1.1.2.c.4 is sent offsite for testing. A serious attempt will be made to meet the 31-day limit on the offsite tests; however, if for some reason this limit is not met (e.g., if the sample is lost or broken or if the results are not received in 31 days), the diesel generators should not be considered inoperable. If the sample is lost, broken, or fails the offsite tests and the new oil has already been put into the storage tank, the offsite tests will be performed on a sample taken from the storage tank. If the results on the subsequent storage tank sample are not within specified limits, the diesel generators should be considered OPERABLE and the out-of-spec properties should be returned to within specification as soon as possible.

If the monthly storage tank sample taken in accordance with Specification 4.8.1.1.2.d fails the particulate contamination test, the diesel generators should be considered OPERABLE and the contamination level should be restored to below 10 mg/liter as soon as possible.

The precision leak-detection test described in Surveillance Requirement 4.8.1.1.2.f.2 should be performed as described in NFPA (National Fire Protection Association) - 329. As NFPA-329 is revised, the precision leak-detection test may be modified to incorporate changes to the test as described in the revisions to NFPA-329.

The minimum required diesel fuel oil volume is 43,240 gallons. This volume is consistent with operation of one diesel generator continuously for 7 days at rated load, as recommended in Regulatory Guide 1.137, entitled "Fuel Oil System for Standby Diesel Generators." The Technical Specifications require a minimum of 46,000 gallons of fuel. The 46,000 gallons is an indicated volume. This amount includes margin for characteristics such as location of the tank discharge pipes and slope of the tanks.

