

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SUBJECT: Forwards LER 99-S001-01, "Vulnerability in Locking Mechanism of Four Vital Area Gates," per 10CFR50.73.Commitments made by util,listed.

**NOTES :**

NOTE TO ALL "RIDS" RECIPIENTS:  
PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LIST  
OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTRC  
DESK (DCD) ON EXTENSION 415-2083

**TOTAL NUMBER OF COPIES REQUIRED: LTTR 7 ENCL 6**

Indiana Michigan  
Power Company  
Cook Nuclear Plant  
One Cook Plant  
Bridgman, MI 49106  
616 465 5901



April 7, 1999

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Operating License DPR-58  
Docket No. 50-315

Document Control Manager:


In accordance with the criteria established by 10CFR73, Appendix G, paragraph I(c) and 10CFR73.71(d), the following report is being submitted:

LER 315/99-S001-00, "Vulnerability in the Locking Mechanism of Four Vital Area Gates."

The following commitments were identified in this submittal:

- Gate repairs/modifications are being made to eliminate identified nonconforming conditions.
- Compensatory measures will remain in place until the gates are returned to operable.
- A new Operating Experience (OE) Program is being developed which will reside under the Regulatory Affairs Department. The ingredients of the program will include benchmarking from other utilities that have proven, effective OE programs and is intended to better utilize industry operating experience, including information notices.
- Security vital area access test procedures will be revised to incorporate appropriate steps for non-destructive testing of security systems such as gates.
- Security preventive maintenance procedures will be revised to incorporate steps intended to identify and correct degradation of barriers which could lead to vulnerability to tampering.

Sincerely,

  
R. P. Powers  
Vice President

9904130265 990407  
PDR ADOCK 05000315  
S PDR

IE74



/lrb  
Attachment

c: J. E. Dyer, Region III  
R. P. Powers  
P. A. Barrett  
D. F. Kunsemiller  
R. Whale  
D. Hahn  
Records Center, INPO  
NRC Resident Inspector