

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

SUBJECT: Forwards LER 99-011-00, concerning air sys for EDG not supporting long term operability. Commitments made by util are listed.

NOTES:

| | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | | RECIPIENT ID CODE/NAME | COPIES LTTR ENCL | |
|-----------|---------------------------|---------------------|---|---------------------------|---------------------|---|
| | LPD3-1 PD | 1 | 1 | STANG, J | 1 | 1 |
| INTERNAL: | AEOD/SPD/RRAB | 1 | 1 | <u>FILE CENTER</u> | 1 | 1 |
| | NRR/DIPM/IOLB | 1 | 1 | NRR/DIPM/IQMB | 1 | 1 |
| | NRR/DRIP/REXB | 1 | 1 | NRR/DSSA/SPLB | 1 | 1 |
| | RES/DET/EIB | 1 | 1 | RGN3 FILE 01 | 1 | 1 |
| EXTERNAL: | L ST LOBBY WARD | 1 | 1 | LIMITCO MARSHALL | 1 | 1 |
| | NOAC POORE, W. | 1 | 1 | NOAC QUEENER, DS | 1 | 1 |
| | NRC PDR | 1 | 1 | NUDOCS FULL TXT | 1 | 1 |

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED
TOTAL NUMBER OF COPIES REQUIRED: LTTR 16 ENCL 16



May 4, 1999

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Operating License DPR-58
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10 CFR 50.73 entitled Licensee Event Report System, the following interim report is being submitted:

LER 315/99-011-00, "Air System for Emergency Diesel Generators (EDG) May Not Support Long Term Operability Due to Original Design Error".

The following commitment was identified in this submittal:

- Once testing is complete, the LER will be updated to provide the safety significance of the identified condition.

Sincerely,

M. W. Rencheck
Vice President – Nuclear Engineering

/mbd
Attachment

c: J. E. Dyer, Region III
R. P. Powers
P. A. Barrett
D. F. Kunsemiller
R. Whale
D. Hahn
Records Center, INPO
NRC Resident Inspector

9905110292 990504
PDR ADDCK 05000315
S PDR

IE22'11

