

**CATEGORY 1**

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9908240283      DOC.DATE: 99/08/16    NOTARIZED: NO                  DOCKET #  
FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M    05000315  
AUTH.NAME                  AUTHOR AFFILIATION  
RENCHECK,M.W.             American Electric Power Co., Inc.  
RECIP.NAME                RECIPIENT AFFILIATION  
                             Records Management Branch (Document Control Desk)

**SUBJECT: Forwards LER 99-019-00, re victoreen containment high range montors not being environmentally qualified to withstand Post-LOCA conditions. Commitments made by util are listed.**

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: C  
TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

**NOTES:**

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
LPD3	1-BD	1	1	STANG	J	1	1
INTERNAL:	FILE CENTER	1	1	NRR/DIPM/IOLB		1	1
	<del>NRR/DRIP/REXB</del>	1	1	NRR/DSSA/SPLB		1	1
	RES/DET/ERAB	1	1	RES/DRAA/OERAB		1	1
	RGN3 FILE 01	1	1				
EXTERNAL:	L ST LOBBY WARD	1	1	LMITCO MARSHALL		1	1
	NOAC POORE, W.	1	1	NOAC QUEENER, DS		1	1
	NRC PDR	1	1	NUDOCS FULL TXT		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED  
TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 15

American Electric Power  
Cook Nuclear Plant  
One Cook Place  
Bridgman, MI 49106  
616 465 5901



August 16, 1999

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Operating License DPR-58  
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10 CFR 50.73 entitled Licensee Event Report System, the following report is being submitted:

LER 315/99-019-00, "Victoreen Containment High Range Radiation Monitors Not Environmentally Qualified to Withstand Post-LOCA Conditions."

The following new commitments were identified in this LER.

- A permanent solution for the susceptibility of the HRRMs to moisture intrusion will be developed to support HRRM operability in Modes 1-4. Options for the permanent solution are currently under review and will be implemented prior to Mode 4 for each unit.
- An evaluation of the as-built configuration for other low signal current application EQ equipment is being performed to identify additional electrical equipment that may be susceptible to moisture intrusion due to a LOCA or pipe break condition. The evaluation will include a review of the current EQ Program documentation regarding requirements for leaktight electrical enclosures. This evaluation will be completed by September 30, 1999. Based on results of the evaluation, appropriate corrective actions will be taken to address any identified EQ discrepancies.

Sincerely,

A handwritten signature in cursive script that reads "M. W. Rencheck".

M. W. Rencheck  
Vice President - Nuclear Engineering

/bwo  
Attachment

9908240283 990816  
PDR ADDCK 05000315  
S PDR

343

1/1  
IE22

c: J. E. Dyer, Region III  
R. P. Powers  
P. A. Barrett  
R. C. Godley  
R. Whale  
D. Hahn  
Records Center, INPO  
NRC Resident Inspector