

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9909020031 DOC.DATE: 99/08/27 NOTARIZED: NO DOCKET #
FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
AUTH.NAME AUTHOR AFFILIATION
RENCHECK,M.W. Indiana Michigan Power Co.
RECIP.NAME RECIPIENT AFFILIATION
 Records Management Branch (Document Control Desk)

SUBJECT: Forwards LER 99-021-00, "GL 96-01 Test Requirements Not Met in Surveillance Tests." List of commitments identified in LER, provided.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 3
TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

NOTES :

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
	LPD3-1 PD	1	1		STANG, J	1	1
INTERNAL:	FILE CENTER	1	1		NRR/DIPM/IOLB	1	1
	NRR/DRIP/REXB	1	1		NRR/DSSA/SPLB	1	1
	RES/DET/ERAB	1	1		RES/DRAA/OERAB	1	1
	RGN3 FILE 01	1	1				
EXTERNAL:	L ST LOBBY WARD	1	1		LMITCO MARSHALL	1	1
	NOAC POORE, W.	1	1		NOAC QUEENER, DS	1	1
	NRC PDR	1	1		NUDOCS FULL TXT	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LISTS OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL DESK (DCD) ON EXTENSION 415-2083

FULL TEXT CONVERSION REQUIRED
TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 15

Indiana Michigan
Power Company
Cook Nuclear Plant
One Cook Plant
Bridgman, MI 49106
616 465 5601



August 27, 1999

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Operating License DPR-58
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by 10 CFR 50.73 entitled Licensee Event Report System, the following report is being submitted:

LER 315/99-021-00, "Generic Letter 96-01 Test Requirements Not Met In Surveillance Tests."

The following new commitments were identified in this LER.

- Surveillance procedures to perform testing of the CRVS on a high radiation signal will be written.
- Surveillance procedures to test the SSPS permissive signals for all applicable plant conditions will be written.
- Existing surveillance procedures will be revised to test each of the three ESS voltage available paths.
- Existing surveillance procedures will be revised to test the EDG load shed and sequencing tripping and block relays.
- These procedures will be implemented and testing complete prior to Mode 4 entry for each Unit.
- Review of the implementation of GL 96-01 at D. C. Cook will be completed by September 30, 1999.

Sincerely,

A handwritten signature in black ink, appearing to read 'M. W. Rencheck'.

M. W. Rencheck
Vice President - Nuclear Engineering

/bwo
Attachment

IE2211

9909020031 990827
PDR ADOCK 05000315
S PDR

c: J. E. Dyer, Region III
R. P. Powers
P. A. Barrett
R. C. Godley
R. Whale
D. Hahn
Records Center, INPO
NRC Resident Inspector