

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	1	2	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER								25	26	LICENSE TYPE				30	57	CAT		58

CON'T

REPORT SOURCE 01 7 8 L 6 0 5 0 0 0 3 1 5 7 0 9 0 5 7 9 8 1 0 0 5 7 9 9 60 61 68 69 74 75 80

DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | WHILE CONDUCTING A FULL LENGTH CONTROL ROD OPERABILITY TEST, AN
0 3 | URGENT FAILURE ALARM FROM POWER CABINET 2 AC WAS RECEIVED ON ROD
0 4 | CONTROL. ONLY SHUTDOWN BANK-A WOULD MOVE. THE OTHER CONTROL BANKS
0 5 | COULD NOT BE MOVED EVEN IN MANUAL CONTROL. THIS EVENT IS NON-CON-
0 6 | SERVATIVE IN RESPECT TO T.S. 3.1.3.1. THE REQUIREMENTS OF ACTION
0 7 | ITEM b WERE MET AS THE CONTROL RODS WERE RETURNED TO OPERATION IN
0 8 | LESS THAN 6 HOURS.

09		SYSTEM CODE R B		11	CAUSE CODE X		12	CAUSE SUBCODE X		13	COMPONENT CODE Z Z Z Z				14	COMP. SUBCODE Z		15	VALVE SUBCODE Z		16					
7	8	9	10		11	12		12		13				18		19		20								
17		LER/RO REPORT NUMBER		EVENT YEAR 7 9		21	22	SEQUENTIAL REPORT NO. 0 4 6		24	25	26	OCCURRENCE CODE 0 3		28	29	REPORT TYPE L		30	31	REVISION NO. 0		32			
ACTION TAKEN Z		FUTURE ACTION Z		EFFECT ON PLANT Z		18	19	SHUTDOWN METHOD Z		20	21	HOURS 0 0 0		22	ATTACHMENT SUBMITTED N		23	NPRD-4 FORM SUB. N		24	PRIME COMP. SUPPLIER N		25	COMPONENT MANUFACTURER Z 9 9		26
33	34	35		36				37				40		41		42		43				44		47		

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	INVESTIGATION FAILED TO REVEAL ANY EQUIPMENT FAILURE OR MALFUNCTION.
1	1	THE POWER SUPPLY WAS RESET AND THE FULL LENGTH CONTROL ROD OPERABILITY
1	2	TEST WAS SATISFACTORILY COMPLETED. NO OTHER PROBLEMS HAVE BEEN
1	3	ENCOUNTERED SINCE THIS EVENT. NO FURTHER ACTIONS ARE PLANNED AT
		THIS TIME.

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

FACILITY STATUS (28) 1 5 E

% POWER 1 0 0 (29)

OTHER STATUS (30) NA

METHOD OF DISCOVERY (31) A

DISCOVERY DESCRIPTION (32) AUDIBLE ALARM

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 Z (33) (34) NA

7 8 9 10 11 44

AMOUNT OF ACTIVITY (35)

NA

45 80

LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37) Z (38) NA				

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

7910110317

1 9		Z		42		43	
7 8		9		10		80	
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION			
				NA			

PUBLICITY										NRC USE ONLY									
ISSUED		N		DESCRIPTION		NA													
2	0	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24

NAME OF PREPARER J. L. Rischling

PHONE: 616-465-5901

NRC USE ONLY

800 617-938

