

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK:

							(1)
--	--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	6	7	0	9	1	2	7	9	8	1	0	1	0	7	9	9
60	61									68	69						74	75						80
DOCKET NUMBER											EVENT DATE						REPORT DATE							

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | WHILE PERFORMING STP.010, THE 612¹ ELEVATION CONTAINMENT AIRLOCK INTERLOCK

0 3 | DID NOT PREVENT THE OPENING OF THE OUTER DOOR WITH THE INNER DOOR OPEN.

0 4 | THIS OCCURRED ON BOTH 9-11-79 AND 9-12-79, CONSTITUTING AN INOPERABLE

0 5 | AIRLOCK PER TECH. SPEC. 3.6.1.3. AT LEAST ONE DOOR REMAINED SHUT PER

0 6 | ACTION ITEM. PUBLIC HEALTH AND SAFETY WERE NOT JEOPARDIZED. SIMILAR

0 7 | EVENTS: 78-014/03L-0; 78-066/03L-0; 79-016/03L-0; AND DOCKET 050-315

0 8 | 79-004/03L-0.

7	8	9	SYSTEM CODE S A (11)		CAUSE CODE B (12)	CAUSE SUBCODE B (13)	COMPONENT CODE P E N E T R (14)				COMP. SUBCODE A (15)	VALVE SUBCODE Z (16)		
0	9		9	10	11	12	13	14	15	16				
7		8				SEQUENTIAL REPORT NO. 0 3 1 (22)		OCCURRENCE CODE 0 3 (23)	REPORT TYPE L (24)		REVISION NO. 0 (25)			
(17)	LER/RO REPORT NUMBER		EVENT YEAR 7 9 (21)		23	24	25	26	27	28	29	30	31	32
ACTION TAKEN B (18)	FUTURE ACTION F (19)	EFFECT ON PLANT Z (20)	SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)				ATTACHMENT SUBMITTED N (23)	NPRD-4 FORM SUB. N (24)	PRIME COMP. SUPPLIER N (25)	COMPONENT MANUFACTURER W 3 0 2 (26)		
33	34	35	36	37	38	39	40	41	42	43	44		47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE CAUSE OF FAILURE WAS FOUND TO BE ONE INTERLOCK SUPPORT BRACKET,
1 1 W. J. WOOLEY DETAIL 30234-6, WAS "FLEXING", PREVENTING THE INTERLOCK SIGNAL
1 2 FROM ENGAGING THE INTERLOCK PAWL. A GUSSET WAS ADDED TO THE BRACKET AND
1 3 TESTED SATISFACTORILY. A LONGER TRAVEL DRIVE SPRING WILL BE ADDED TO
2 4 IMPROVE THE OVERALL PERFORMANCE OF THE MECHANISM.

7 8 9 FACILITY STATUS (28) 10 11 12 % POWER (29) 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 OTHER STATUS (30) 31 32 33 34 35 36 37 38 39 40 41 42 43 44

1 5 1 0 0 NA

7 8 9 ACTIVITY CONTENT (35) 10 11 12 RELEASED OF RELEASE (34) 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 AMOUNT OF ACTIVITY (35) 31 32 33 34 35 36 37 38 39 40 41 42 43 44

1 6 Z NA

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44

45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

METHOD OF DISCOVERY (31) SURVEILLANCE TESTING (32) DISCOVERY DESCRIPTION (32)

45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

NA LOCATION OF RELEASE (36)

45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

PERSONNEL EXPOSURES									
NUMBER			TYPE	DESCRIPTION					
1	7	0	0	0	(37)	(38)	NA	(39)	

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

7910160506

1 9		LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION		(43)
1 9		Z	(42)	NA

7		8	9	10		80	
		PUBLICITY		DESCRIPTION		NRC USE ONLY	
2	0	N	(44)	NA			
7	8	9	10			68	69

NRC USE ONLY

10 M. S. BROWN
NAME OF PREPARER _____

PHONE: (616) 465-5901, EXT:398

