

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
7	8

REPORT SOURCE

L	6	0	5	0	0	0	3	1	6	7	0	9	0	9	7	9	8	1	0	0	9	7	9	9
60	61									68	69						74	75						80
DOCKET NUMBER										EVENT DATE										REPORT DATE				

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | AFTER COMPLETION OF INCORE/EXCORE CROSS CALIBRATION TEST AT 70% POWER, THE UNIT
0 3 | POWER WAS BEING ESCALATED TO 100%. ON REACHING 81% POWER THE DELTA FLUX INDICA-
0 4 | TION WAS OUT OF THE TARGET BAND FOR AN ESTIMATED 21-22 MINUTES. THIS IS BELOW THE
0 5 | TECHNICAL SPECIFICATION LIMIT OF 84% BUT VIOLATES A MORE RESTRICTIVE ADMINISTRATIVE
0 6 | LIMIT OF 81% IMPOSED PENDING REVISION OF TECHNICAL SPECIFICATIONS.
0 7 |
0 8 |

SYSTEM CODE X X (11)		CAUSE CODE D (12)		CAUSE SUBCODE Z (13)		COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)	
EVENT YEAR 7 9 (22)		SEQUENTIAL REPORT NO. 0 3 0 (26)		OCCURRENCE CODE 0 3 (29)		REPORT TYPE 1 (31)		REVISION NO. 0 (32)	
ACTION TAKEN G (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)	
ATTACHMENT SUBMITTED Y (23)		NPRD-4 FORM SUB. N (24)		PRIME COMP. SUPPLIER Z (25)		COMPONENT MANUFACTURER Z 9 9 9 (26)			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE OPERATOR, WHILE PERFORMING THE POWER ESCALATION ON THE UNIT, WAS USING THE

1 1 AXIAL FLUX LIMITS DIFFERENCE AS SHOWN IN TECH SPECS. RATHER THAN THE ADMINISTRA-

1 2 TIVE LIMITS IMPOSED PENDING REVISION OF TECHNICAL SPECIFICATIONS. THIS RESULTED IN

1 3 THE DELTA FLUX GOING SLIGHTLY OUT OF THE TARGET BAND BETWEEN 81-82% POWER. THE

1 4 CONTROL ROOM COPY OF THE TECH. SPEC. GRAPH HAS BEEN UPDATED WITH THE (CONTINUED)

7 8 9
FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)
1 5 F 0 8 1 NA A NUCLEAR SECTION

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

AMOUNT OF ACTIVITY NA

LOCATION OF RELEASE NA

PERSONNEL EXPOSURES									
NUMBER				TYPE	DESCRIPTION				
1	7	0	0	0	(37) Z	(38) NA	(39)		

PERSONNEL INJURIES		NUMBER		DESCRIPTION	
1	8	0	0	0	NA

7910160507

1		9		7		8		9		10		8	
Z		(42)		NA									

PUBLICITY		ISSUED		DESCRIPTION		NRC USE ONLY											
7	8	9	10	11	12												
2 0		N 44		NA													

NAME OF PREPARER C. E. MURPHY

PHONE: (616) 465-5901 X-316

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS:

ADMINISTRATIVE LIMITS AND THE INCORE/EXCORE TEST PROCEDURE HAS BEEN CHANGED TO REQUIRE OPERATOR SIGNOFF THAT THE AXIAL FLUX DIFFERENCE IS WITHIN THE TARGET BAND PRIOR TO POWER ESCALATION.

