

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

REPORT

REPORT SOURCE 0 1 7 8

DOCKET NUMBER 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

EVENT DATE 0 5 0 0 0 3 1 5 7 0 9 1 7 7 9 8 1 0 1 7 7 9 9

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | INVESTIGATION OF A LOW FLOW ALARM FOUND THE SAMPLE PUMP FOR RADIATION MONITORS

03 | R-11 AND R-12 TO BE INOPERABLE DUE TO A FAILED MOTOR TO PUMP COUPLING INSERT.

04 THE ACTION REQUIREMENTS OF T. S. 3.4.6.1 WERE MET. PUBLIC HEALTH AND SAFETY

05 , WERE NOT JEOPARDIZED. A SIMILAR EVENT WAS REPORTED AS R/O 79-012/03L-0.

06 _____

0	7	
---	---	--

0	8	
---	---	--

SYSTEM CODE B B (11)		CAUSE CODE E (12)		CAUSE SUBCODE B (13)		COMPONENT CODE P U M P X X (14)				COMP. SUBCODE H (15)		VALVE SUBCODE Z (16)	
LER/RO REPORT NUMBER 17 9 (17)		EVENT YEAR 7 9 (21)		SEQUENTIAL REPORT NO. 0 4 8 (24)		OCCURRENCE CODE 0 3 (28)		REPORT TYPE L (30)		REVISION NO. 0 (32)			
ACTION TAKEN A (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 0 (22)		ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. N (24)	
PRIME COMP. SUPPLIER A (25)		COMPONENT MANUFACTURER W 1 2 0 (26)											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | FAILURE WAS DUE TO FAILURE OF THE RUBBER SPIDER IN THE LOVEJOY L-100

111 | COUPLING. THE COMPLETE COUPLING WAS REPLACED AND THE AIR SAMPLER TESTED.

1 2 NO FURTHER ACTIONS ARE PLANNED.

1	3	
---	---	--

1	4	
---	---	--

7 8 9
FACILITY STATUS (28) 1 5 E
% POWER 1 0 0 (29) NA
OTHER STATUS (30)
METHOD OF DISCOVERY (31) A
DISCOVERY DESCRIPTION (32) OPERATOR OBSERVATION

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35)
1 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60
Z Z NA NA LOCATION OF RELEASE (36)

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION
1	7	000	(37) Z	(38) NA (39)

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
		NA	

7910220260

		LOSS OF OR DAMAGE TO FACILITY		(43)
		TYPE	DESCRIPTION	
1	9	Z	(42)	NA

7	8	9	10											8	
		PUBLICITY				NRC USE ONLY									
		ISSUED		DESCRIPTION											
2	0	N	(44)	NA											

NAME OF PREPARER D. G. WIZNER

PHONE: (616) 465-5901, EXT 398

