

LICENSEE EVENT REPORT

CONTROL BLOCK:

--	--	--	--	--	--

 ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	1	2	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5			
7	8	LICENSEE CODE						14	15	LICENSE NUMBER											25	26	LICENSE TYPE					30	57	CAT		58

CON'T

0	1	REPORT SOURCE	L	6	0	5	0	0	0	3	1	5	7	0	9	2	9	7	9	8	1	0	2	5	7	9	9
7	8		60	61	DOCKET NUMBER								68	EVENT DATE					74	REPORT DATE					80		

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | WHILE PERFORMING A SURVEILLANCE TEST ON STEAM GENERATOR PROTECTION

0 3 | SET 3, LOOP 3, IT WAS DISCOVERED THAT THE STEAM GENERATOR WATER

0 4 | LEVEL-LOW-LOW BISTABLE WAS DRIFTING EXCESSIVELY. THIS BISTABLE

0 5 | WAS DETERMINED INOPERABLE AND NON-CONSERVATIVE TO T.S. TABLE 3.3-1

0 6 | ITEM 14. THE BISTABLE WAS LEFT IN THE TRIP POSITION AS REQUIRED BY

0 7 | THE APPLICABLE ACTION REQUIREMENT. PREVIOUS OCCURRENCES OF A SIMILAR

0 8 | NATURE INCLUDE: 050-315/78-52, 050-316/79-7.

09		SYSTEM CODE I A		11	CAUSE CODE E		12	CAUSE SUBCODE E				13	COMPONENT CODE I N S T R U				14	COMP. SUBCODE S		15	VALVE SUBCODE Z		16		
7	8	9	10		11			12				13					18	19		20					
17		LER/RO REPORT NUMBER		EVENT YEAR 7 9		21	22	SEQUENTIAL REPORT NO. 0 5 0		24	25	26	OCCURRENCE CODE 0 3		28	29	REPORT TYPE L		30	REVISION NO. 0		32			
ACTION TAKEN C		FUTURE ACTION Z		EFFECT ON PLANT Z		18	19	SHUTDOWN METHOD Z		20	HOURS 0 0 0		22	ATTACHMENT SUBMITTED N		23	NPRD-4 FORM SUB. Y		24	PRIME COMP. SUPPLIER N		25	COMPONENT MANUFACTURER F 1 8 0		26
33	34	35		36				37				40		41			42		43			44		47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

THE DEFECTIVE BISTABLE; MANUFACTURED BY FOXBORO-MODEL NUMBER
63U-AC-OHAA-F, WAS REPLACED. THE NEW BISTABLE WAS CALIBRATED,
TESTED WITH THE APPROPRIATE SURVEILLANCE TEST PROCEDURE,
AND RETURNED TO SERVICE.

1 4
7 8 9
FACILITY STATUS
1 5 E 28
7 8 9
% POWER 1 0 0 29
10 11 12 13
OTHER STATUS NA 30
METHOD OF DISCOVERY B 31
45 46
SURVEILLANCE TEST DISCOVERY DESCRIPTION 32
47 48 49 50

ACTIVITY CONTENT
RELEASED OF RELEASE

AMOUNT OF ACTIVITY (35)

NA

LOCATION OF RELEASE (36)

NA

PERSONNEL EXPOSURES									
NUMBER				TYPE	DESCRIPTION				
1	7	0	0	0	NA				

		PERSONNEL INJURIES						
		NUMBER			DESCRIPTION			
1	8	0	0	0	(40)	NA	7910300223	

7		8	9	11		12	80
		TYPE		DESCRIPTION		(43)	
1	9	Z	(42)	NA			

7		8	9	10	80	
PUBLICITY		ISSUED		DESCRIPTION	NRC USE ONLY	
2	0	N	(44)	NA		
7	8	9	10		68	69

NAME OF PREPARER J. L. Rischling

PHONE: _____

NRC USE ONLY

616-⁶⁸465-5901⁶⁹

