

## LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 M I D C C 1 2 0 0 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5  
7 8 9 14 15 25 26 30 57 CAT 58

CON'T

0 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 5 7 1 0 1 2 7 9 8 1 1 0 7 7 9 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 LOOP 3 CHANNEL 4 STEAM GENERATOR LEVEL FAILED AS EVIDENCED BY A  
0 3 DRIFTING AND LOSS OF LEVEL INDICATION. THIS CONDITION WAS NON  
0 4 CONSERVATIVE WITH RESPECT TO T.S. TABLE 3.3-1 ITEMS 14 AND 15 AND  
0 5 TABLE 3.3-3 ITEM 5a.  
0 6  
0 7  
0 8

0 9 SYSTEM CODE I A 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE P E N E T R 14 COMP. SUBCODE D 15 VALVE SUBCODE Z 16  
7 8 9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 7 9 21 22 23 24 26 27 28 29 30 31 32 REVISION NO. 0  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED N 23 NPD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER W 1 2 0 26  
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE CAUSE OF THE FAILURE WAS FOUND TO BE A FAULTY CONTAINMENT CABLE  
1 1 PENETRATION. THE PENETRATION FEED THROUGH WAS SWITCHED TO A SPARE  
1 2 PENETRATION AND THE NEW FEED THROUGH CHECKED FOR OPERABILITY.  
1 3 THE ACTION ITEM REQUIREMENTS OF TABLE 3.3-1 FOR ITEMS 14 AND 15  
1 4 AND TABLE 3.3-3 ITEM 5a WERE FULFILLED.

1 5 FACILITY STATUS E 28 % POWER 1 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION ROUTINE OPERATOR READINGS 32  
7 8 9 10 12 13 44 45 46 80  
1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36  
7 8 9 10 11 44 45 80  
1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
7 8 9 11 12 13 80  
1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
7 8 9 11 12 80  
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
7 8 9 10 80  
2 0 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
7 8 9 10 80

NAME OF PREPARER S. D. DeLong

PHONE: 79 11140344  
68 69 80NRC USE ONLY  
616-465-5901

