

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8001030693 DOC. DATE: 79/12/26 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH. NAME: HUNTER, R.S. AUTHOR AFFILIATION: Indiana & Michigan Electric Co.  
 RECIP. NAME: DENTON, H.R. RECIPIENT AFFILIATION: Office of Nuclear Reactor Regulation

SUBJECT: Advises that leakage test of letdown & charging sys for Unit 1 will follow completion of work on Unit 2, in response to NUREG-0578 requirements.

DISTRIBUTION CODE: A039S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: Resp to Lesson Learn Task Force - Westinghouse

## NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
ACTION:	10 BC ORB #1	7		
INTERNAL:	1 REG FILE	1	17 I & E	2
	19 TA/EDU	1	2 NRC PDR	1
	20 CORE PERF BR	1	21 ENG BR	1
	22 REAC SFTY BR	1	23 PLANT SYS BR	1
	24 EEB	1	25 EFLT TRT SYS	1
	3 LPDR	1	4 NSIC	1
	5 J OLSHINSKI	1	6 J KERRIGAN	1
	7 J BURDION	1	8 C WILLIS	1
	9 G IMBRO	1	M FIELDS	1
	N ANDERSON	1	OELD	1
	P O'REILLY	1		
EXTERNAL:	26 ACRS	16		

JAN 7 1980

TOTAL NUMBER OF COPIES REQUIRED: LTR 45 ENCL 0

MA 4

60



# INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18  
BOWLING GREEN STATION  
NEW YORK, N. Y. 10004

December 26, 1979  
AEP:NRC:00253C

Donald C. Cook Nuclear Plant Unit No. 1  
Docket No. 50-315  
License No. DPR-58

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Mr. Denton:

This will confirm our telephone discussion with members of your staff on December 26, 1979 with respect to the status of NUREG-0578 requirements for Unit 1. By January 1, 1980 we will implement on Unit 1, requirements Nos. 2.1.3.a, Direct Indication of Safety Valve Position, 2.1.3.b, Subcooling Meter, and 2.1.8.a, Post Accident Sampling, in the same manner as we are doing it for Unit 2. The Unit 2 actions to which we refer are those described in our letter AEP:NRC:00253B of December 19, 1979. With respect to Item 2.1.6.a, System Integrity for High Radioactivity, we will not perform a leakage test of the letdown and charging system on Unit 1. The leakage test of the letdown and charging system of Unit 2 serves the purpose of perfecting and gaining experience on the methodology. When we complete that work on Unit 2, we will begin our overall program to measure the leakage of systems in both Units.

Very truly yours,



R. S. Hunter  
Vice President

cc: R. C. Callen  
G. Charnoff  
John E. Dolan  
R. W. Jurgensen  
D. V. Shaller - Bridgman

A039  
5/10

8001030

P

693

