

**LICENSEE EVENT REPORT**

**CONTROL BLOCK:**

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 14 15 25 26 30 57 58  
0 1 M I D C C 2 0 0 0 0 0 0 0 0 0 0 3 4 1 1 1 1 4 5  
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT. 58

CON'T  
7 8 60 61 68 69 74 75 80  
0 1 L 6 0 5 0 0 0 3 1 6 7 1 1 1 3 7 9 8 0 2 2 8 8 0 9  
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

VENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
A RE-EVALUATION OF CALIBRATION DATA TAKEN DURING THE LAST REFUELING OUTAGE REVEALED

THAT THE AS FOUND DATA FROM THE STEAM LINE PRESSURE TRANSMITTERS WOULD RESULT IN

THE DIFFERENTIAL STEAM LINE PRESSURE SETPOINT FOR LOOPS 3 AND 4 BE NON-CONSERVATIVE

IN RESPECT TO THE LIMIT SPECIFIED BY T.S. TABLE 3.3-4 ITEM 1.E.:

SYSTEM CODE S H		CAUSE CODE E		CAUSE SUBCODE E		COMPONENT CODE I N S T R U				COMP. SUBCODE I		VALVE SUBCODE Z					
11		12		13		14				15		16					
9 10		11		12		13 14 15 16 17 18				19		20					
EVENT YEAR 8 0		SEQUENTIAL REPORT NO. 0 0 5		OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0									
21 22		23 24 25 26		27 28 29		30 31		32									
ACTION TAKEN E		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED Y		NPRD-4 FORM SUB. Y		PRIME COMP. SUPPLIER N		COMPONENT MANUFACTURER F 1 8 0	
33 34		35 36		37 38 39 40		41 42		43 44		45 46 47 48		49 50 51 52		53 54 55 56		57 58 59 60	

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

THE EVALUATION OF THE TRANSMITTER CALIBRATION DATA FOR LOOPS 3 AND 4, TRANSMITTER-

MPP 230 and 240, REVEALED THAT THE COMBINED ERRORS OF AS FOUND DATA WOULD HAVE RE-

RESULTED IN A MAXIMUM POSSIBLE TRIP SETPOINT OF 127.6 PSIG. THIS ERROR IS ATTRIBUTED

TO INSTRUMENT DRIFT. THESE TRANSMITTERS WERE RECALIBRATED AND RETURNED TO SERVICE.

THESE TRANSMITTERS ARE MANUFACTURED BY FOXBORO MODEL NO. E11GM-HSAE1. SEE SUPPLEMENT.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION			
1	5	H	28	0	0	0	29	B	31	SURVEILLANCE TEST	32
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE					
1	6	Z	33	Z	34	NA	35	NA	36		
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION					
1	7	0	0	0	37	Z	38	NA	39		
PERSONNEL INJURIES		NUMBER		DESCRIPTION							
1	8	0	0	0	40	NA	41				
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION							
1	9	Z	42	NA	43						
PUBLICITY ISSUED		DESCRIPTION									
2	0	N	44	NA	45						
NRC USE ONLY											

NAME OF PREPARER J. L. Rischling 8008040523 PHONE: 616-465-5901

**NRC USE ONLY**

616-465-5901

ATTACHMENT TO LER # 80-005/03L-0

SUPPLEMENT TO CAUSE DESCRIPTION

NO FURTHER ACTIONS ARE PLANNED.