



INDIANA & MICHIGAN ELECTRIC COMPANY

DONALD C. COOK NUCLEAR PLANT
P.O. Box 458, Bridgman, Michigan 49106
(616) 465-5901

February 27, 1980

Mr. J.G. Keppler, Regional Director
Office of Inspection and Enforcement
United States Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Operating License DPR-58 and DPR-74
Docket Nos. 50-315 and 50-316
AEO No. 80-001/04X-0

Dear Mr. Keppler:

During the preparation of the Annual Environmental Operating Report, it was discovered that the maximum quantity of detergent discharged to the lake, Specification 4.1.1.7.2, Table 4.1-1, of 5,000 pounds per year, was exceeded by 360 pounds.

This was as a result of the issuing of forty (40) gallons of detergent for use as a circulating water condenser foaming agent prior to complete authorization.

A procedure change has been made which requires complete authorization of this condenser foaming agent prior to issuing, and all issuing personnel have been made aware of the need for proper authorization.

Routine surveillance of the lake environment, as described in Appendix B, Technical Specification 4.1.2.1, has shown no adverse effects to the aquatic biota.

Sincerely yours,

for D.V. Shaller
Plant Manager

/bab

cc: J.E. Dolan
R.S. Hunter
R.W. Jurgensen
R.F. Kroeger
R.W. Kilburn
R.E. Masse RO:III
R.C. Callen MPSC
G. Charnoff, Esq.
G. Olson

J.M. Hennigan
W. Lavallee EPRI
PNSRC
J.F. Stietzel
E.L. Townley
Dir., IE (20 copies)
Dir., MIPC (2 copies)
Directorate of Licensing

MAR 3 1980
C003
5
1/0
8003050488
~~8003050488~~