

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8004080520 DOC.DATE: 80/03/28 NOTARIZED: NO DOCKET #
 FACIL:50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH.NAME AUTHOR AFFILIATION
 MALONEY,G.P. Indiana & Michigan Electric Co.
 RECIP.NAME RECIPIENT AFFILIATION
 DENTON,H.R. Office of Nuclear Reactor Regulation

SUBJECT: Responds to NRC 800129 ltr requesting fee submittal for
 review of documents in 791218 ltr.Fee already paid.Discusses
 seismic qualification items.

DISTRIBUTION CODE: M008S COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3
 TITLE: License Fees

NOTES: SEND 3 CYS ALL MATL TO I & E

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
ACTION:	04 BC ORB #1	3 3	LA	1 0
INTERNAL:	01 REG FILE 07 MILLER, LFMB	1 1 1 1	02 NRC PDR	1 1
EXTERNAL:	03 LPDR	1 1		
	ADD: H. DENTON	1 1		

APR 10 1980

APP

TOTAL NUMBER OF COPIES REQUIRED: LTTR

9

8 ENCL

8

7

INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

March 28, 1980
AEP:NRC:00001B

Donald C. Cook Nuclear Plant Unit No. 2
Docket No. 50-316
License No. DPR-74

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Mr. Denton:

This letter is in response to Mr. W. C. Miller's letter dated January 29, 1980, in which he requested that a check for \$4,000 be forwarded to his office to complete the review of documents we furnished in our Letter AEP:NRC:00001A dated December 18, 1979.

We would like to advise you that the AEP:NRC:00001 letters were initiated to address concerns raised by the NRC Seismic Qualification Review Team in September, 1977. Our records indicate that a check for \$4,000 accompanied our letter AEP:NRC:00001 to cover the fee for this review (a copy of the check is enclosed for your records). Letter No. AEP:NRC:00001A was issued to close out outstanding items generated by the review of AEP:NRC:00001 and should be considered as supplementary information furnished to the NRC Staff at their request.

In light of these facts, we consider the review of documents presented in AEP:NRC:00001A and in this letter, to be a continuation of the review of AEP:NRC:00001, and request you to update your records to show that the fee for the said review has already been paid.

In addition, we would like to use this letter to formally document the information furnished to your staff over the telephone, on items 3 and 4 of our letter No. AEP:NRC:00029 dated June 7, 1978. The latter was also generated as a result of your Staff's review of the documents contained in our letter AEP:NRC:00001. Responses to Items 1 and 2 were formally given in our letter No. AEP:NRC:00001A, dated December 18, 1979.

M008

S
1/1

ADD:

ltr ENC

H. DENTON

1 1

8004080520

THE UNITED STATES OF AMERICA
DO hereby certify that
[Name] is a citizen of the United States of America.

[Faint, illegible text, likely a signature or official statement]

Response to Item 3

Sections 3.4 and 6.1.1 of ITE Imperial Corporation's Seismic Withstandability test indicate that the frequencies employed for qualification ranged from 1 to 32 Hz. However, the qualification document filed in 1971 (Attachment 5 to our letter No. AEP:NRC:00001) as proof of qualification for GE 12 PJCI1AV1A protection relay, contained Seismic Withstandability test results for the frequency range from 2.5 Hz to 12 Hz. However, in 1973 additional information, submitted now as Attachment 2 to this letter, was obtained from the Vendor establishing that the relay was qualified up to 33 Hz.

Response to Item 4


Attachment 6 to AEP:NRC:00001 was furnished to establish:

- 1) The seismic qualification of the Switchboard and Components as a unit.
- 2) That there exists no natural frequency for this unit in the range between 1 Hz to 10Hz.

This attachment in no way serves as qualification document for the protective relay. This relay GE1 PJCI1AV1A has been qualified as described in Item 3 above. Furthermore, Attachment 6 was reviewed and found adequate by the seismic qualification review team (See page 3 of Enclosure 1 to Mr. Karl Kniel's letter dated October 20, 1977).

We again reiterate the request previously made in our letter No. AEP:NRC:00001A that conditions 3A and 3B contained in Amendment No. 6 to Operating License No. DPR-74 for Unit 2 of the Donald C. Cook Nuclear Plant be deleted as having been fulfilled.

Very truly yours,


G. P. Maloney
Vice President

GPM/emc

cc: attached

Mr. Harold R. Denton, Director

AEP:NRC:00001B

cc: R. C. Callen
G. Charnoff
R. S. Hunter
R. W. Jurgensen
D. V. Shaller-Bridgman
W. C. Miller - NRC

1-1-1

1-1-1

1-1-1

1-1-1