

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	1	2	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	1	4			5					
7	8	9						14						25										26						30		57		58	
		LICENSEE CODE						LICENSE NUMBER										LICENSE TYPE																	

CON'T

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80																			
		L	6	0	5	0	0	0	3	1	5	7	0	3	2	4	8	0	8	0	4	1	8	8	0	9															

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING THE PERFORMANCE OF A SURVEILLANCE TEST ON THE UNIT 1 650 FOOT ELEVATION

0 3 | AIRLOCK DOOR A LEAKAGE OF 130 CFH WAS FOUND. THIS CONDITION IS NON CONSERVATIVE

0 4 | WITH RESPECT TO T.S. 4.6.1.3b.

0 5 |

0 6 |

0 7 |

0 8 |

7 8 9 8

SYSTEM CODE S D 11		CAUSE CODE X 12		CAUSE SUBCODE Z 13		COMPONENT CODE P E N E T R 14				COMP. SUBCODE A 15		VALVE SUBCODE Z 16	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 0 21 22		SEQUENTIAL REPORT NO. 0 0 6 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. 0 32			
ACTION TAKEN X 18		FUTURE ACTION Z 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23		NPRD-4 FORM SUB. N 24	
PRIME COMP. SUPPLIER A 25		COMPONENT MANUFACTURER W 3 0 2 26											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 AN INSPECTION OF THE DOOR SEAL FOLLOWING THE SURVEILLANCE TEST INDICATED THE

1 1 SEAL WAS CLEAN AND IN GOOD CONDITION. A RETEST WAS THEN PERFORMED AND THE

1 2 LEAK RATE WAS LESS THAN 20 CFH. NO CAUSE FOR THE LEAK COULD BE FOUND AND

1 3 NO FURTHER ACTION IS PLANNED. THE ACTION REQUIREMENT FOR T.S. 4.6.1.3b WAS

1 4 FULFILLED.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	E	28	1	0	0	29	NA	30
7	8	9	10	11	12	13	14	15	16
ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	NA	35	NA	36
7	8	9	10	11	12	13	14	15	16
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	Z	38	NA	39
7	8	9	10	11	12	13	14	15	16
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40	NA	41		
7	8	9	10	11	12	13	14	15	16
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42	NA	43				
7	8	9	10	11	12	13	14	15	16
PUBLICITY ISSUED		DESCRIPTION							
2	0	N	44	NA	45				
7	8	9	10	11	12	13	14	15	16
								NRC USE ONLY	

NAME OF PREPARER S. D. DELONG

PHONE: 616-465-5901