

## ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8811300572 DOC. DATE: 88/11/18 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316  
 AUTH. NAME AUTHOR AFFILIATION  
 MENGE, R.C. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP. NAME RECIPIENT AFFILIATION  
 ZUGGER, P.D. Michigan, State of

SUBJECT: NPDES noncompliance notification: on 881114, prefilter  
 backwash effluent for suspended solids was 171 mg/l.

DISTRIBUTION CODE: IE23D COPIES RECEIVED: LTR 1 ENCL 6 SIZE: 2  
 TITLE: Environmental Event Report (per Tech Specs)

## NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-1 LA		1	0		PD3-1 PD		1	1
	SCOTT, W		1	1					
INTERNAL:	AEOD/DSP/TPAB		1	1		AEOD/PTB		1	1
	NRR/DEST/ADE 8H		1	1		NRR/DOEA/EAB 11		1	1
	NRR/DREP/EPB 10		1	1		NRR/DREP/RPB 10		1	1
	NRR/PMAS/ILRB12		1	1		NRR/PMAS/PTSB12		1	1
	NUDOCS-ABSTRACT		1	1		OGC/HDS1		1	1
	<u>REG FILE</u>		1	1		RGN3 FILE 01		1	1
	RGN2/DRSS/EPRPB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

## NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 28

*E. B. W.*

Indiana Michigan  
Power Company  
One Summit Square  
P.O. Box 60  
Fort Wayne, IN 46801  
219 425 2111

DMB



INDIANA  
MICHIGAN  
POWER

Paul D. Zugger, Executive Secretary  
Michigan Water Resources Commission  
Stevens T. Mason Building, P.O. Box 30026  
Lansing, Michigan 48909

November 18, 1988

PRIORITY ROUTING	
First	Second
HA	
ORA	
DRP	
DRS	
DRSS	
DRM	

FILE *du*

Dear Mr. Zugger:

Richard C. Menge  
Senior Vice President  
219 425 2103

RE: Donald C. Cook Nuclear Plant  
NPDES Permit No. MI 0005827  
Prefilter Backwash Limitations

A sample of the prefilter backwash effluent (Outfall 00F) taken on November 14, 1988 was analyzed for suspended solids and indicated 171 mg/l. The backwash unit was operating normally at that time. Rough lake conditions appear to have stirred bottom sediments coming into the plant's intake water.

By copy of this letter, the Nuclear Regulatory Commission is notified pursuant to the requirements of Appendix B, Part II, Nonradiological Environmental Protection Plan, Section 3.2.

Very truly yours,

*Richard C. Menge*  
Richard C. Menge  
Senior Vice President

RCM/df

c: Valdas Adamkus - USEPA, Region V  
~~Valdas Adamkus - USEPA, Region III~~  
Fred Morley - MDNR, Plainwell

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

*Richard C. Menge*  
Richard C. Menge

8811300572 881118  
PDR ADDCK 05000315  
S PNU

*11-25*  
*11-23*  
*1/0*  
NOV 21 1988

November 18, 1988  
Paul D. Zugger  
Page 2

bc: A. J. Ahern/T. E. Webb/M. R. Robida - Columbus  
M. P. Alexich - Columbus  
P. A. Barrett - Columbus  
C. E. Hawk - Columbus  
K. D. Mack - Columbus  
W. E. Walters/D. L. Baker/J. L. Hughey - Fort Wayne

A. A. Blind/J. R. Sampson - Cook Plant  
NRC Resident Inspector - Cook Plant  
PNSRC - Cook Plant  
W. G. Smith, Jr. - Cook Plant  
J. T. Wojcik/D. M. Fitzgerald - Cook Plant

G. Charnoff/R. E. Zahler - Shaw, Pittman, Potts & Trowbridge

T. E. Murley - Nuclear Reactor Regulations