

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8903090013 DOC. DATE: 89/02/23 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME: SMITH, W.G. AUTHOR AFFILIATION: Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME: DAVIS, A.B. RECIPIENT AFFILIATION: Document Control Branch (Document Control Desk)

SUBJECT: RO: on 890118, Fire Door 391 separating Fire Zones 43 & 44N in auxiliary bldg declared inoperable in excess of 7 days.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-1 LA	1 1	PD3-1 PD	1 1
	STANG, J	1 1		
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	ACRS WYLIE	1 1	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
	ARM/DCTS/DAB	1 1	DEDRO	1 1
	NRR/DEST/ADE 8H	1 1	NRR/DEST/ADS 7E	1 0
	NRR/DEST/CEB 8H	1 1	NRR/DEST/ESB 8D	1 1
	NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
	NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
	NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
	NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/QAB 10	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RAB 10	1 1
	NRR/DREP/RPB 10	2 2	NRR/DRIS/SIB 9A	1 1
	NUDOCS-ABSTRACT	1 1	REG FILE 02	1 1
	RES/DSIR/EIB	1 1	RES/DSR/PRAB	1 1
	RGN3 FILE 01	1 1		
EXTERNAL:	EG&G WILLIAMS, S	4 4	FORD BLDG HOY, A	1 1
	H ST LOBBY WARD	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC MAYS, G	1 1
	NSIC MURPHY, G. A	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 45 ENCL 44

Indiana Michigan
Power Company
Cook Nuclear Plant
P.O. Box 458
Bridgman MI 49106
616 465 5931



February 23, 1989

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315:50-316
License Nos. DPR-58:DPR-74

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Attn: A. B. Davis

Dear Mr. Davis:

This letter is to inform you that Fire Door 391 has been inoperable for longer than the seven days allowed by Technical Specification 3.7.10 Action a, and that the CO2 fire suppression system protecting the Unit Two 4KV complex has been inoperable for longer than the 14 days permitted by Technical Specification 3.7.9.2 Action a.

Fire Door 391 separating Fire Zones 43 and 44N in the Unit 1 Auxiliary building was declared inoperable on January 18, 1989 due to broken latching hardware. Due to the unique design of the three point latch on the door we have had difficulty in obtaining certified parts to repair the door. It is expected that parts will be obtained and the door returned to operable status by March 31, 1989. At the time the door was declared inoperable a roving fire watch patrol as required by Technical Specification 3.7.10 Action a was established and will remain in effect until the door is declared operable.

The CO2 fire suppression system protecting Fire Zones 45, 46A, 46B, 46C, 46D, 47A, 47B and 60 in the Unit Two 4KV complex was removed from service on February 3, 1989 to allow modification to the system piping required by the installation of a new ventilation system and fire dampers in the area. At the time the system was removed from service a continuous fire watch required by Technical Specification 3.7.9.2 Action a was established and maintained until the system was returned to service on February 18, 1989.

Respectfully,

W. G. Smith, Jr.
Plant Manager

/afh

IE22
11

c: D. H. Williams, Jr.
A. B. Davis, Region III
M. P. Alexich
P. A. Barrett
J. E. Borggren
R. F. Kroeger
NRC Resident Inspector
Wayne Scott, NRC
R. C. Callen
G. Charnoff, Esq.
Dottie Sherman, ANI Library
D. Hahn
INPO
PNSRC
A. A. Blind
S. J. Brewer/B. P. Lauzau