

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8907130209 DOC. DATE: 89/07/06 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 AUTH. NAME AUTHOR AFFILIATION
 SMITH, W.G. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 DAVIS, A.B. Document Control Branch (Document Control Desk)

SUBJECT: Advises that listed actions will be performed to return facility to svc.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES: ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD3-1 LA	1 1	PD3-1 PD	1 1
STANG, J	5 5		
INTERNAL: NRR/DEST/ADS 7E	1 1	NRR/DEST/CEB 8H	1 1
NRR/DEST/ESB 8D	1 1	NRR/DEST/ICSB	1 1
NRR/DEST/MTB 9H	1 1	NRR/DEST/RSB 8E	1 1
NRR/DOEA/TSB 11	1 1	NUDOCS-ABSTRACT	1 1
OG/LEMB	1 0	OGC/HDS1	1 0
REG FILE 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL: LPDR	1 1	NRC PDR	1 1
NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 22 ENCL 20

R
I
D
S
/
A
D
D
S

MAJ
/

1. THE FIRST PART OF THE DOCUMENT IS A
2. SUMMARY OF THE MAIN POINTS OF THE
3. REPORT. IT IS A CONCISE STATEMENT OF
4. THE FACTS AND FINDINGS OF THE
5. INVESTIGATION. IT IS A SUMMARY OF
6. THE RESULTS OF THE WORK DONE BY
7. THE COMMITTEE. IT IS A SUMMARY OF
8. THE CONCLUSIONS REACHED BY THE
9. COMMITTEE. IT IS A SUMMARY OF THE
10. RECOMMENDATIONS MADE BY THE COMMITTEE.

Indiana Michigan
Power Company
Cook Nuclear Plant
P.O. Box 458
Bridgman, MI 49106
616 465 5901



July 6, 1989

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Attn: A. B. Davis

Dear Mr. Davis:

Confirming my conversation with members of your staff this date, we will perform the following actions with regard to return to service of D. C. Cook Unit One:

- 1) All Unit 1 Safety-Related and Technical Specification equipment Job Orders, performed during the 1989 refueling outage, will be reviewed to confirm that:
 - a) documentation exists that the required post-work testing (or other, required performance measure verification) has been satisfactorily completed, or,
 - b) if required post-work testing (or other, required performance measure verification) is not complete at this time, the testing or performance measure verification is scheduled and identified as an applicable Mode change constraint in the return-to-service sequence, or
 - c) ASME Section XI VT-2 Examinations, which are not required to be complete prior to power operations, are identified and scheduled for performance.

The above reviews will be completed prior to changing from the current Mode 5 to Mode 4 on D. C. Cook Unit One.

- 2) NRC RIII will be notified of the completion of the above reviews, including identification of any additional instances found where the required post-work testing (or other, required performance measure verification) was not properly completed, prior to changing from the current Mode 5 to Mode 4 on D. C. Cook Unit One.
- 3) We will, within thirty (30) days, provide you with a full, written report on this matter. It is our understanding that this report may be in the form of a License Event Report (LER).

W. G. Smith, Jr.
W. G. Smith, Jr.

8907130209 890706
PDR ADOCK 05000315
PDC

A001

U.S. Nuclear Regulatory Commission
Document Control Desk
Wash., D.C. 20555
Page 2

c: D. H. Williams, Jr.
M. P. Alexich
P. A. Barrett
J. E. Borggren
R. F. Kroeger
NRC Resident Inspector
J. Giitter, NRC
R. C. Callen
G. Charnoff, Esq.
Dottie Sherman, ANI Library
D. Hahn
PNSRC/B. A. Svensson
S. J. Brewer/B. P. Lauzau

