

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8909180003 DOC. DATE: 89/02/28 NOTARIZED: NO DOCKET #
 FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M.P. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "Reactor Containment Bldg Integrated Leakage Rate."
 W/890908 ltr.

DISTRIBUTION CODE: A017D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 225
 TITLE: OR Submittal: Append J Containment Leak Rate Testing

NOTES: *see Rts*

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-1 LA		1	0		PD3-1 PD		2	2
	GIITTER, J.		1	1					
INTERNAL:	NRR/DEST/PSB	8D	1	1		NUDOCS-ABSTRACT		1	1
	OG/HDS1		1	0		OGC/HDS1		1	1
	<u>REG FILE</u>	01	1	1		RES TELFORD, J		1	1
	RES/DE/SEB		1	0		RES/DSIR/SAIB		1	0
	RES/DSR/RPSB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 17 11

MAF
EXP



AEP:NRG:0968A
10 CFR 50, App. J

Donald C. Cook Nuclear Plant Unit 2
Docket No. 50-316
License No. DPR-74
INTEGRATED LEAK RATE TEST

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Attn: T. E. Murley

September 8, 1989

Dear Dr. Murley:

Pursuant to the provisions of 10 CFR 50, Appendix J, Section V, Paragraph B, enclosed is a copy of the Reactor Containment Building Integrated Leakage Rate Test (ILRT) Report for Donald C. Cook Nuclear Plant Unit 2. The Unit 2 ILRT was successfully completed on February 13, 1989. The ILRT was performed as specified in surveillance test procedure **2 THP 4030 STP.202 in accordance with the requirements of American National Standard Institute (ANSI) N45.4-1972, ANSI/ANS 56.8-1987, the Code of Federal Regulations, the plant FSAR, and Technical Specification 4.6.1.2.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,


M. P. Alexich
Vice President

ldp

cc: D. H. Williams, Jr.
W. G. Smith, Jr. - Bridgman
R. C. Callen
G. Charnoff
A. B. Davis
NRC Resident Inspector - Bridgman
NFEM Section Chief

8909180003 890228
PDR ADOCK 05000316
P PDC

A017
11

