

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8910250171 DOC. DATE: 89/10/16 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M.P. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T.E. Document Control Branch (Document Control Desk)

SUBJECT: Responds to 890911 SER on plant conformance to Reg Guide 1.97.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD3-1 LA		1	1		PD3-1 PD		1	1
	GIITTER, J.		5	5					
INTERNAL:	NRR/DEST/ADS 7E		1	1		NRR/DEST/ESB 8D		1	1
	NRR/DEST/ICSB		1	1		NRR/DEST/MTB 9H		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DOEA/TSB 11		1	1
	NUDOCS-ABSTRACT		1	1		OC/LEMB		1	0
	OGC/HDS1		1	0		<u>REG FILE 01</u>		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 9

MA
11/1



AEP:NRG:0773AG
TAC Nos. 51080 & 51081

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
WIDE-RANGE STEAM GENERATOR LEVEL
INSTRUMENTATION UPGRADE

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Attn: T. E. Murley

October 16, 1989

Dear Dr. Murley:

The following information is provided in response to the NRC Safety Evaluation Report on "D. C. Cook Conformance to Reg. Guide 1.97", dated September 11, 1989. Although the level instrumentation presently installed is not environmentally or seismically qualified and the electrical cables associated with the instruments do not meet the separation criteria as stated in Reg. Guide 1.97 for Category 1 variables, we will provide each of the four steam generator wide-range level instruments (one per steam generator) with a diverse Class 1E power source. At present, one Class 1E power source feeds all four steam generator level instruments. This change was reviewed with the NRC staff during a teleconference among Messrs. J. G. Gitter, B. Marcus and A. C. Udy on September 25, 1989. We estimate completion of this repowering by December 31, 1989 for both Units 1 and 2.

This document has been prepared following Corporate procedures that incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,

M. P. Alexich
Vice President

A001
1/0

Dr. T. E. Murley

-2-

AEP:NRC:0773AG

eh

cc: D. H. Williams, Jr.
A. A. Blind - Bridgman
R. C. Callen
G. Charnoff
NFEM Section Chief
A. B. Davis - Region III
NRC Resident Inspector - Bridgman