

ATTACHMENT 2 TO AEP:NRG:0930
PROPOSED REVISED LICENSE PAGES

9001050237 891227
PDR ADOCK 05000315
P PDC

3

* 2.I Iodine Monitoring

Amendment
No. 49

The licensee shall implement a program which will ensure the capability to accurately determine the airborne concentration in vital areas under accident conditions. This program shall include the following:

1. Training of personnel,
2. Procedures for monitoring, and
3. Provisions for maintenance of sampling and analysis equipment.

Amendment
No.

2.J In all places of this license, the reference to the Indiana and Michigan Electric Company is amended to read "Indiana Michigan Power Company."

3. This amended license is effective as of the date of issuance and shall expire October 25, 2014.

* Amendment No. 70 superseded the following Amendments for numbering: Nos. 33, 45 and 49.

FOR THE NUCLEAR REGULATORY COMMISSION

Roger S. Boyd, Director
Division of Project Management
Office of Nuclear Reactor Regulation

Enclosure:

Appendix A - Technical Specifications

Date of Issuance: March 30, 1976

**** H. Iodine Monitoring**

Amendment
No. 34

The licensee shall implement a program which will ensure the capability to accurately determine the airborne iodine concentration in vital areas under accident conditions. This program shall include the following:

1. Training of personnel,
2. Procedures for monitoring, and
3. Provisions for maintenance of sampling and analysis equipment.

**** I.** In all places of this license, the reference to the Indiana and Michigan Power Company is deleted and all references to "the licensees" is amended to read "the licensee." The intent is to recognize the Indiana and Michigan Electric Company as the sole licensee of the Donald C. Cook Nuclear Plant.

Amendment
No. 29

J. In all places of this license, the reference to the Indiana and Michigan Electric Company is amended to read "Indiana Michigan Power Company."

Amendment
No. 98

K. STEAM GENERATOR REPAIR PROGRAM

Amendment
No. 100

- (1) The licensee is authorized to repair Unit 2 steam generators by replacement of major components. Repairs shall be conducted in accordance with the licensee's commitments identified in the Commission approved Donald C. Cook Nuclear Plant Unit No. 2 Steam Generator Repair Report dated November 7, 1986, as revised through Revision 6, and additional commitments identified in the staff's related Safety Evaluation dated March 8, 1988.
- (2) The Technical Specifications identified in Table 3.2-2 of the Steam Generator Repair Report dated November 7, 1986, as revised through Revision 6 dated February 18, 1988, will not be applicable during the repair program. For purposes of Technical Specification applicability, the Steam Generator Repair Project will begin when the last fuel assembly from the Unit 2 core is placed in the spent fuel pool and will end when the first fuel assembly is removed from the spent fuel pool to refuel the Unit 2 core.

Amendment 3. This license is effective as of the date of issuance and shall expire at midnight, December 25, 2017.

**** Amendment 29 - Changed G to H, H to I, and added a new G;
Amendment 34 - Changed H to 3, added a new H and K; Amendment 52
- Deleted G, Changed H to G, and K to H; Amendment 14 added H.**