

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9010240364 DOC. DATE: 90/10/12 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 ALEXICH, M.P. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T.E. Document Control Branch (Document Control Desk)

SUBJECT: Updates 900625 response to GL 90-04, generic safety issue
 GSI 67.3.3, "Improved Accident Monitoring."

DISTRIBUTION CODE: A018D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Generic Ltr 90-04 re Status of Licensee Implementation of Generic Saf

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL	
	PD3-1 LA		1	1		PD3-1 PD		1	1	
	COLBURN, T.		2	2						
INTERNAL:	CROCKER, L 9H3		1	1		ECCLESTON, K10D4		1	1	
	NUDOCS-ABSTRACT		1	1		REG-FILE 90-01		1	1	
	SCHOLL, R 13E4		1	1						
EXTERNAL:	NRC PDR		1	1						

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 10 ENCL 10
0

2

0

1

1

1



AEP:NRC:1108D

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
GENERIC SAFETY ISSUES (GSI)
UPDATE RESPONSE TO GENERIC LETTER (GL) 90-04

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Attn: T. E. Murley

October 12, 1990

Dear Dr. Murley:

The purpose of this letter is to update our AEP:NRC:1108C, June 25, 1990 response to GL 90-04. The item of concern is GSI 67.3.3, "Improved Accident Monitoring."

In our June 25, 1990 letter, we indicated that action item GSI 67.3.3 would be completed by December 31, 1990 in accordance with the Reg Guide 1.97 schedule contained in our letter AEP:NRC:0773AB dated October 5, 1988. In the process of finalizing documentation on the safety issues we have determined that approximately 64 limit switches, 32 in each unit, installed during construction do not have adequate traceability concerning the seismic qualification. We propose to verify the seismic quality by testing several switches currently in use as well as new limit switches from the storeroom. Due to the difficulties of contracting and scheduling independent laboratories for seismic shake tests, we anticipate approximately a one-year time frame to qualify the 64 limit switches installed. Completion for closeout of this issue will be delayed until December 31, 1991.

Our letter, AEP:NRC:0773AB dated October 5, 1988, which provided a schedule for GSI 67.3.3/Reg Guide 1.97 completion, will be updated by a separate letter.

9010240364 901012
PDR ADOCK 05000315
P FDC

A016
10

Dr. T. E. Murley

-2-

AEP:NRC:1108D

This document has been prepared following Corporate procedures that incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,



M. P. Alexich
Vice President

MPA/eh

cc: D. H. Williams, Jr.
A. A. Blind - Bridgman
J. R. Padgett
G. Charnoff
NFEM Section Chief
A. B. Davis - Region III
NRC Resident Inspector - Bridgman



10-10-10