

N.R.C. OPERATING DATA REPORT

DOCKET NO. 50-316
DATE 17-Apr-90
COMPLETED BY WT Gillett
TELEPHONE 616-465-5901

OPERATING STATUS

1. Unit Name D. C. Cook Unit 2
2. Reporting Period MARCH 90 notes
3. Licensed Thermal Power (MWt) 3411
4. Name Plate Rating (Gross MWe) 1133
5. Design Electrical Rating (Net MWe) 1100
6. Maximum Dependable Capacity (GROSS MWe) 1100
7. Maximum Dependable Capacity (Net MWe) 1060
8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons

9. Power Level To Which Restricted. If Any (Net MWe)
10. Reasons For Restrictions. If Any:


	This Mo.	Yr. to Date	Cumm.
11. Hours in Reporting Period	744.0	2160.0	107352.0
12. No. of Hrs. Reactor Was Critical	744.0	1695.2	71871.2
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator on Line	744.0	1683.6	70413.1
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Therm. Energy Gen. (MWH)	2534067	5677778	216555668
17. Gross Elect. Energy Gen. (MWH)	843300	1885910	70682020
18. Net Elect. Energy Gen. (MWH)	816057	1824350	68070008
19. Unit Service Factor	100.0	77.9	67.1
20. Unit Availability Factor	100.0	77.9	67.1
21. Unit Capacity Factor (MDC Net)	103.5	79.7	61.2
22. Unit Capacity Factor (DER Net)	99.7	76.8	59.6
23. Unit Forced Outage Rate	0.0	17.2	13.9

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration):
Refueling outage to begin on June 23, 1990 for an estimated duration of 77 days.

25. If Shut Down At End of Report Period, Estimated Date of Startup:

26. Units in Test Status (Prior to Commercial Operation):
Forecast Achieved
INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

9005180090 900507
PDR ADOCK 05000316
R PDC



Indiana Michigan
Power Company
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49106
616 465 5901

50-316



U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

April 4, 1990

Gentlemen:

Pursuant to the requirements of Donald C. Cook Nuclear Plant
Unit 2 Technical Specification 6.9.1.10, the attached Monthly
Operating Report for the month of March 1990 is submitted.

Respectfully,

A. Alan Blind
A.A. Blind
Plant Manager

c: B.A. Svensson
NRC Region III
D.R. Hahn
EPRI - Nuclear Safety Analysis Center
R.C. Callen
S.L. Hall
INPO Records Center
ANI Nuclear Engineering Department
D.H. Williams, Jr.
M.P. Alexich
J.F. Kurgan
J.J. Markowsky
D.A. Timberlake
D.W. Paul
T.O. Argenta
S.H. Steinhart
B.L. Jorgensen
W.T. Gillett
E.A. Smarrella
J. Krieger
E.C. Schimmel

9005180090

N.R.C. OPERATING DATA REPORT

DOCKET NO. 50-316
 DATE 04-Apr-90
 COMPLETED BY WT Gillett
 TELEPHONE 616-465-5901

OPERATING STATUS

1. Unit Name D. C. Cook Unit 2 -----
 2. Reporting Period MARCH 90 notes
 3. Licensed Thermal Power (MWt) 3411
 4. Name Plate Rating (Gross MWe) 1133
 5. Design Electrical Rating (Net MWe) 1100
 6. Maximum Dependable Capacity (GROSS MWe) 1100
 7. Maximum Dependable Capacity (Net MWe) 1060 -----
 8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons _____

9. Power Level To Which Restricted. If Any (Net MWe) _____
 10. Reasons For Restrictions. If Any: _____

	This Mo.	Yr. to Date	Cumm.
11. Hours in Reporting Period	744.0	8040.0	104472.0
12. No. of Hrs. Reactor Was Critical	744.0	5860.9	69456.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator on Line	744.0	5799.5	68009.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Therm. Energy Gen. (MWH)	2534067	19035456	208601833
17. Gross Elect. Energy Gen. (MWH)	843300	6154900	68051120
18. Net Elect. Energy Gen. (MWH)	816057	5942584	65527248
19. Unit Service Factor	100.0	72.1	66.6
20. Unit Availability Factor	100.0	72.1	66.6
21. Unit Capacity Factor (MDC Net)	103.5	69.7	60.5
22. Unit Capacity Factor (DER Net)	99.7	67.2	59.0
23. Unit Forced Outage Rate	0.0	6.9	13.9

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration):
Refueling outage to begin on June 23, 1990, for an estimated
duration of 77 days.

25. If Shut Down At End of Report Period, Estimated Date of Startup: _____

26. Units in Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY		
INITIAL ELECTRICITY		
COMMERCIAL OPERATION		

AVERAGE DAILY POWER LEVEL (MWe-Net)

DOCKET NO. 50-316
UNIT TWO
DATE 04-Apr-90
COMPLETED BY WT Gillett
TELEPHONE 616-465-5901

MONTH MARCH 90

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	1091	17	1097
2	1093	18	1098
3	1097	19	1096
4	1099	20	1096
5	1096	21	1097
6	1100	22	1098
7	1099	23	1097
8	1099	24	1090
9	1097	25	1100
10	1097	26	1100
11	1101	27	1095
12	1100	28	1097
13	1097	29	1094
14	1098	30	1098
15	1097	31	1094
16	1096		



UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: March 1990

DOCKET NO: 50-316
UNIT NAME: D.C. COOK UNIT 2
DATE: April 4, 1990
COMPLETED BY: E.C. Schimmel
TELEPHONE: (616) 465-5901

NO.	DATE	TYPE ¹	DURATION HOURS	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT NO.	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
-----	------	-------------------	-------------------	---------------------	---	---------------------------------	-----------------------------	--------------------------------	--

None

There were no unit shutdowns or significant power reductions from the maximum power level of 100% during the month.

1	2	3	4	5
F: Forced	Reason:	Method:	Exhibit G - Instructions	Exhibit I: Same Source
S: Scheduled	A: Equipment Failure (Explain)	1: Manual	for preparation of data	
	B: Maintenance or Test	2: Manual Scram	entry sheets for Licensee	
	C: Refueling	3: Automatic Scram	Event Report (LER) File	
	D: Regulatory Restriction	4: Other (Explain)	(NUREG 0161)	
	E: Operator Training and License Examination			
	F: Administrative			
	G: Operational Error (Explain)			
	H: Other (Explain)			

[Faint, illegible text covering the majority of the page, likely bleed-through from the reverse side.]

DOCKET NO: 50-316
UNIT NAME: D.C. Cook Unit 2
COMPLETED BY: E.C. Schimmel
TELEPHONE: (616) 465-5901
DATE: April 4, 1990
PAGE: 1 of 1

MONTHLY OPERATING ACTIVITIES - March 1990

HIGHLIGHTS

The unit entered the reporting period at 100% Rated Thermal Power and exited the reporting period at 100% Rated Thermal Power, with no significant load changes.

Gross electrical generation for the month of March was 843300 MWH.

DETAILS

There were no significant operational events during the month of March.

DOCKET NO: 50-316
UNIT NAME: D.C. Cook Unit 2
COMPLETED BY: E.C. Schimmel
TELEPHONE: (616) 465-5901
DATE: April 4, 1990
PAGE: 1 of 1

MAJOR SAFETY-RELATED MAINTENANCE - MARCH 1990

- 2-IC-1 Replaced defective power supply in power range drawer N-41.
- 2-M-1 Replaced the CD Diesel Generator starting air compressor.