

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9005220051 DOC.DATE: 90/05/11 NOTARIZED: NO DOCKET #
 FACIL:50-315, Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 AUTH.NAME AUTHOR AFFILIATION
 ALEXICH,M.P. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP.NAME RECIPIENT AFFILIATION
 MURLEY,T.E. Document Control Branch (Document Control Desk)

SUBJECT: Application for amend to License DPR-58, modifying Tech Spec
 Table 3.3-2.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+6
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTTR	ENCL		LTTR	ENCL
	PD3-1 LA	1	1	PD3-1 PD	1	1
	GIITTER,J.	5	5			
INTERNAL:	NRR/DET/ECMB 9H	1	1	NRR/DOEA/OTSB11	1	1
	NRR/DST 8E2	1	1	NRR/DST/SELB 8D	1	1
	NRR/DST/SICB 7E	1	1	NRR/DST/SRXB 8E	1	1
	NUDOCS-ABSTRACT	1	1	OG/LEMB	1	0
	OGC/HDS1	1	0	REG FILE 01	1	1
	RES/DSIR/EIB	1	1			
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19



AEP:NRC:1110
10 CFR 50.90

Donald C. Cook Nuclear Plant Unit 1
License No. DPR-58
Docket No. 50-315
TECHNICAL SPECIFICATION CHANGE: LOSS OF FLOW REACTOR
TRIP RESPONSE TIME

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

Attn: T. E. Murley

May 11, 1990

Dear Dr. Murley:

This letter and its attachments constitute an application for amendment to the Technical Specifications (T/Ss) for the Donald C. Cook Nuclear Plant Unit 1. Specifically, we are proposing to modify the T/S Table 3.3-2 (Reactor Trip System Response Times) Items 12 and 13 (Loss of Flow) required response times from 0.6 to 1.0 seconds. This change is consistent with the current Unit 1 accident analyses and is consistent with a change recently proposed for Unit 2 in our letter AEP:NRC:1071E. Attachment 1 is the description of the change and Attachment 2 is the revised T/S page.

We believe the proposed change will not result in (1) a significant change in the types of effluents or a significant increase in the amounts of any effluent that may be released offsite, or (2) a significant increase in individual or cumulative occupational radiation exposure.

These proposed changes have been reviewed by the Plant Nuclear Safety Review Committee and by the Nuclear Safety and Design Review Committee.

In compliance with the requirements of 10 CFR 50.91(b)(1), copies of this letter and its attachments have been transmitted to Mr. R. C. Callen of the Michigan Public Service Commission and the Michigan Department of Public Health.

9005220051 900511
PDR ADOCK 05000315
P PDC

A001
11

Dr. T. E. Murley

-2-

AEP:NRC:1110

This document has been prepared following Corporate procedures that incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,



M. P. Alexich
Vice President

MPA/eh .

Attachments

cc: D. H. Williams, Jr.
A. A. Blind - Bridgman
R. C. Callen
G. Charnoff
NFEM Section Chief
A. B. Davis - Region III
NRC Resident Inspector - Bridgman