

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9012190115 DOC. DATE: 90/11/30 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315  
 AUTH. NAME AUTHOR AFFILIATION  
 GILLET, W.T. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 SCHIMMEL, E.C. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 BLIND, A.A. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Nov 1990 for DC Cook Nuclear  
 Plant Unit 1. W/901206 ltr.

DISTRIBUTION CODE: IE24D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 6  
 TITLE: Monthly Operating Report (per Tech Specs)

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	PD3-1 LA	3	3	PD3-1 PD	1	1
	COLBURN, T.	1	1			
INTERNAL:	AEOD/DOA	1	1	AEOD/DSP/TPAB	1	1
	IRM TECH ADV	2	2	NRR/DLRO/LPEB10	1	1
	NRR/DOEA/OEAB	1	1	<u>REG FILE</u> 01	1	1
	RGN3	1	1			
EXTERNAL:	EG&G BRYCE, J.H	1	1	NRC PDR	1	1
	NSIC	1	1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 16 ENCL 16

Indiana Michigan  
Power Company  
Cook Nuclear Plant  
One Cook Place  
Bridgman, MI 49106  
616 465 5901



December 6, 1990

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Pursuant to the requirements of Donald C. Cook Nuclear Plant  
Unit 1 Technical Specification 6.9.1.10, the attached Monthly  
Operating Report for the month of November 1990 is submitted.

Respectfully,

A.A. Blind  
Plant Manager

Attachment

c: NRC Region III  
D.R. Hahn  
EPRI - Nuclear Safety Analysis Center  
R.C. Callen  
S.L. Hall  
J.G. Keppler  
INPO Records Center  
ANI Nuclear Engineering Department  
D.H. Williams, Jr.  
M.P. Alexich  
J.F. Kurgan  
J.J. Markowsky  
D.A. Timberlake  
D.W. Paul  
T.O. Argenta  
S.H. Steinhart  
J.A. Isom  
W.T. Gillett  
E.A. Smarrella  
J.C. Krieger  
B.A. Svensson  
E.C. Schimmel

9012190115 901130  
PDR ADCK 05000315  
R PDR



# N.R.C. OPERATING DATA REPORT

DOCKET NO. 50-315  
 DATE 03-Dec-90  
 COMPLETED BY WT GILLET  
 TELEPHONE 616-465-5901

## OPERATING STATUS

1. Unit Name D. C. Cook Unit 1
2. Reporting Period NOV.90
3. Licensed Thermal Power (MWt) 3250
4. Name Plate Rating (Gross MWe) 1152
5. Design Electrical Rating (Net MWe) 1030
6. Maximum Dependable Capacity (GROSS MWe) 1056
7. Maximum Dependable Capacity (Net MWe) 1020
8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons

notes

9. Power Level To Which Restricted. If Any (Net MWe)
10. Reasons For Restrictions. If Any:

	This Mo.	Yr. to Date	Cumm.
11. Hours in Reporting Period	720.0	8016.0	139512.0
12. No. of Hrs. Reactor Was Critical	0.0	6944.8	103387.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	463.0
14. Hours Generator on Line	0.0	6939.8	101628.8
15. Unit Reserve Shutdown Hours	0.0	0.0	321.0
16. Gross Therm. Energy Gen. (MWH)	0	20541629	295429648
17. Gross Elect. Energy Gen. (MWH)	0	6559000	96131230
18. Net Elect. Energy Gen. (MWH)	0	6301645	92433473
19. Unit Service Factor	0.0	86.6	73.9
20. Unit Availability Factor	0.0	86.6	73.9
21. Unit Capacity Factor (MDC Net)	0.0	77.1	65.9
22. Unit Capacity Factor (DER Net)	0.0	76.3	64.1
23. Unit Forced Outage Rate		0.0	7.1
24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration):			

25. If Shut Down At End of Report Period, Estimated Date of Startup:  
 January 15, 1990

26. Units in Test Status (Prior to Commercial Operation):

Forcast

Achieved

INITIAL CRITICALITY  
 INITIAL ELECTRICITY  
 COMMERCIAL OPERATION

AVERAGE DAILY POWER LEVEL (MWe-Net)

DOCKET NO. 50-315  
UNIT ONE  
DATE 03-Dec-90  
COMPLETED BY WT GILLET  
TELEPHONE 616-465-5901

MONTH NOV.90

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	0	17	0
2	0	18	0
3	0	19	0
4	0	20	0
5	0	21	0
6	0	22	0
7	0	23	0
8	0	24	0
9	0	25	0
10	0	26	0
11	0	27	0
12	0	28	0
13	0	29	0
14	0	30	0
15	0		
16	0		



## UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: November 1990

DOCKET NO: 50-315  
UNIT NAME: D.C. COOK UNIT 1  
DATE: December 6, 1990  
COMPLETED BY: E.C. Schimmel  
TELEPHONE: (616) 465-5901

NO.	DATE	TYPE <sup>1</sup>	DURATION HOURS	REASON <sup>2</sup>	METHOD OF SHUTTING DOWN REACTOR <sup>3</sup>	LICENSEE EVENT REPORT NO.	SYSTEM CODE <sup>4</sup>	COMPONENT CODE <sup>5</sup>	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
290 (cont.)	10/20/90	S	720.0	C	1	N/A	ZZ	ZZZZZZ	The unit was removed from service at 0031 hours on 901020 for the cycle 11-12 refueling outage. The unit was in mode 6 at the end of the reporting period, with no fuel in the reactor.

1	2	3	4	5
F: Forced	Reason:	Method:	Exhibit G - Instructions	Exhibit I: Same Source
S: Scheduled	A: Equipment Failure (Explain)	1: Manual	for preparation of data	
	B: Maintenance or Test	2: Manual Scram	entry sheets for Licensee	
	C: Refueling	3: Automatic Scram	Event Report (LER) File	
	D: Regulatory Restriction	4: Other (Explain)	(NUREG 0161)	
	E: Operator Training and License Examination			
	F: Administrative			
	G: Operational Error (Explain)			
	H: Other (Explain)			

DOCKET NO. 50-315  
UNIT NAME: D.C. Cook Unit 1  
COMPLETED BY: E.C. Schimmel  
TELEPHONE: (616) 465-5901  
DATE: December 6, 1990  
PAGE: 1 of 2

MONTHLY OPERATING ACTIVITIES - November 1990

HIGHLIGHTS

The unit entered the reporting period in mode 5. The unit entered mode 6 at 0202 hours on November 4, 1990. Core alterations began at 1323 hours on November 8, 1990 and the core offload was complete at 2200 hours on November 10, 1990. An unusual event was declared at 0507 hours on November 16, 1990, due to the planned evolution of both emergency diesel generators being inoperable. This was a planned outage activity while the reactor core was unloaded. The unusual event was exited at 1615 hours on November 16, 1990. An unusual event was declared at 1325 hours on November 28, 1990, due to the planned evolution of both emergency diesel generators being inoperable. This was a planned outage activity while the reactor core was unloaded. The unit exited the reporting period with the reactor coolant system in mode 6 and the reactor core unloaded.

Gross electrical generation for the month of October was 0 MWH.

DETAILS

11/04/90	0202	The unit is in mode 6.
11/08/90	1323	Commenced reactor core offloading.
11/10/90	2200	The reactor core offloading is complete.
11/16/90	0507	An unusual event is declared due to the planned evolution of both emergency diesel generators being made inoperable.
	1615	The unusual event is exited.
11/28/90	1325	An unusual event is declared due to the planned evolution of both emergency diesel generators being made inoperable.



DOCKET NO: 50-315  
UNIT NAME: D.C. Cook Unit 1  
COMPLETED BY: E.C. Schimmel  
TELEPHONE: (616) 465-5901  
DATE: December 6, 1990  
PAGE: 1 of 1

MAJOR SAFETY-RELATED MAINTENANCE - November 1990

There were no major safety-related maintenance items during the month of November.