

FORD 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9102080100 DOC. DATE: 90/04/04 NOTARIZED: NO DOCKET #
 FACIL: 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME AUTHOR AFFILIATION
 GILLETT, W.T. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 BLIND, A.A. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: Monthly operating rept for Mar 1990 for Donald C Cook, Unit
 2.W/900404 ltr.

DISTRIBUTION CODE: DF01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 6
 TITLE: Direct Flow Distribution: 50 Docket (PDR Avail)

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL: NUDOCS-ABSTRACT	1 1	REG FILE 001	1 1
EXTERNAL: NRC PDR	1 1	NSIC	1 1

R
I
D
S
/
F
O
R
D
2
D
O
C
U
M
E
N
T

TOTAL NUMBER OF COPIES REQUIRED: LTTR 4 ENCL 4

MR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

Indiana Michigan
Power Company
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49308
313 465 5901

INDIANA
MICHIGAN
POWER

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

April 4, 1990

Gentlemen:

Pursuant to the requirements of Donald C. Cook Nuclear Plant
Unit 2 Technical Specification 6.9.1.10, the attached Monthly
Operating Report for the month of March 1990 is submitted.

Respectfully,

A. Alan Blind

A.A. Blind
Plant Manager

c: B.A. Svensson
NRC Region III
D.R. Hahn
EPRI - Nuclear Safety Analysis Center
R.C. Callen
S.L. Hall
INPO Records Center
ANI Nuclear Engineering Department
D.H. Williams, Jr.
M.P. Alexich
J.F. Kurgan
J.J. Markowsky
D.A. Timberlake
D.W. Paul
T.O. Argenta
S.H. Steinhart
B.L. Jorgensen
W.T. Gillett
E.A. Smarrella
J. Krieger
E.C. Schimmel

IEPA 11-01
11

750000

N.R.C. OPERATING DATA REPORT

DOCKET NO. 50-316
 DATE 04-Apr-90
 COMPLETED BY WT Gillett
 TELEPHONE 616-465-5901

OPERATING STATUS

1. Unit Name D. C. Cook Unit 2 -----
 2. Reporting Period MARCH 90 notes
 3. Licensed Thermal Power (MWt) 3411
 4. Name Plate Rating (Gross MWe) 1133
 5. Design Electrical Rating (Net MWe) 1100
 6. Maximum Dependable Capacity (GROSS MWe) 1100
 7. Maximum Dependable Capacity (Net MWe) 1060 -----
 8. If Changes Occur in Capacity Ratings (Items no. 3 through 7) Since Last Report Give Reasons _____

9. Power Level To Which Restricted. If Any (Net MWe) _____
 10. Reasons For Restrictions. If Any: _____

	This Mo.	Yr. to Date	Cumm.
11. Hours in Reporting Period	744.0	8040.0	104472.0
12. No. of Hrs. Reactor Was Critical	744.0	5860.9	69456.0
13. Reactor Reserve Shutdown Hours	0.0	0.0	0.0
14. Hours Generator on Line	744.0	5799.5	68009.5
15. Unit Reserve Shutdown Hours	0.0	0.0	0.0
16. Gross Therm. Energy Gen. (MWH)	2534067	19035456	208601833
17. Gross Elect. Energy Gen. (MWH)	843300	6154900	68051120
18. Net Elect. Energy Gen. (MWH)	816057	5942584	65527248
19. Unit Service Factor	100.0	72.1	66.6
20. Unit Availability Factor	100.0	72.1	66.6
21. Unit Capacity Factor (MDC Net)	103.5	69.7	60.5
22. Unit Capacity Factor (DER Net)	99.7	67.2	59.0
23. Unit Forced Outage Rate	0.0	6.9	13.9

24. Shutdowns Scheduled over Next Six Months (Type, Date, and Duration):
Refueling outage to begin on June 23, 1990, for an estimated duration of 77 days.

25. If Shut Down At End of Report Period, Estimated Date of Startup: _____

26. Units in Test Status (Prior to Commercial Operation):
 Forecast Achieved
 INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

AVERAGE DAILY POWER LEVEL (MWe-Net)

DOCKET NO. 50-316
UNIT TWO
DATE 04-Apr-90
COMPLETED BY WT Gillett
TELEPHONE 616-465-5901

MONTH MARCH 90

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	1091	17	1097
2	1093	18	1098
3	1097	19	1096
4	1099	20	1096
5	1096	21	1097
6	1100	22	1098
7	1099	23	1097
8	1099	24	1090
9	1097	25	1100
10	1097	26	1100
11	1101	27	1095
12	1100	28	1097
13	1097	29	1094
14	1098	30	1098
15	1097	31	1094
16	1096		

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH: March 1990

DOCKET NO: 50-316
UNIT NAME: D.C. COOK UNIT 2
DATE: April 4, 1990
COMPLETED BY: E.C. Schimmel
TELEPHONE: (616) 465-5901

NO.	DATE	TYPE ¹	DURATION HOURS	REASON ²	METHOD OF SHUTTING DOWN REACTOR ³	LICENSEE EVENT REPORT NO.	SYSTEM CODE ⁴	COMPONENT CODE ⁵	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
-----	------	-------------------	-------------------	---------------------	---	---------------------------------	-----------------------------	--------------------------------	--

None

There were no unit shutdowns or significant power reductions from the maximum power level of 100% during the month.

1 F: Forced S: Scheduled	2 Reason: A: Equipment Failure (Explain) B: Maintenance or Test C: Refueling D: Regulatory Restriction E: Operator Training and License Examination F: Administrative G: Operational Error (Explain) H: Other (Explain)	3 Method: 1: Manual 2: Manual Scram 3: Automatic Scram 4: Other (Explain)	4 Exhibit G - Instructions for preparation of data entry sheets for Licensee Event Report (IER) File (NUREG 0161)	5 Exhibit I: Same Source
--------------------------------	---	--	--	-----------------------------

DOCKET NO: 50-316
UNIT NAME: D.C. Cook Unit 2
COMPLETED BY: E.C. Schimmel
TELEPHONE: (616) 465-5901
DATE: April 4, 1990
PAGE: 1 of 1

MONTHLY OPERATING ACTIVITIES - March 1990

HIGHLIGHTS

The unit entered the reporting period at 100% Rated Thermal Power and exited the reporting period at 100% Rated Thermal Power, with no significant load changes.

Gross electrical generation for the month of March was 843300 MWH.

DETAILS

There were no significant operational events during the month of March.

DOCKET NO: 50-316
UNIT NAME: D.C. Cook Unit 2
COMPLETED BY: E.C. Schimmel
TELEPHONE: (616) 465-5901
DATE: April 4, 1990
PAGE: 1 of 1

MAJOR SAFETY-RELATED MAINTENANCE - MARCH 1990

- 2-IC-1 Replaced defective power supply in power range drawer N-41.
- 2-M-1 Replaced the CD Diesel Generator starting air compressor.