

ATTACHMENT 2 TO AEP:NRC:1036B

PROPOSED REVISED TECHNICAL SPECIFICATIONS PAGES

9103060051 910227 .
PDR ADDCK 05000315
P PDR

CONTAINMENT SYSTEMS

3/4.6.3 CONTAINMENT ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.3.1 The containment isolation valves specified in Table 3.6-1 shall be OPERABLE with isolation times as shown in Table 3.6-1. The ACTION statement of T/S 3/4.6.3 is not applicable to the containment purge supply and exhaust isolation valves, VCR-101 through 106 and VCR-201 through 206, listed in Table 3.6-1. The Limiting Condition for Operation and its associated ACTION statement for these valves is given in Technical Specification 3/4.6.1.7.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one or more of the isolation valve(s) specified in Table 3.6-1 inoperable, either:

- a. Restore the inoperable valve(s) to OPERABLE status within 4 hours, or
- b. Isolate each affected penetration within 4 hours by use of at least one deactivated automatic valve secured in the isolation position, or
- c. Isolate each affected penetration within 4 hours by use of at least one closed manual valve or blind flange, or
- d. Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.6.3.1.1 The isolation valves specified in Table 3.6-1 shall be demonstrated OPERABLE prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by performance of a cycling test and verification of isolation time.

CONTAINMENT SYSTEMS

3/4.6.3 CONTAINMENT ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.3.1 The containment isolation valves specified in Table 3.6-1 shall be OPERABLE with isolation times as shown in Table 3.6-1. The ACTION statement of Technical Specification 3/4.6.3 is not applicable to the containment purge and exhaust isolation valves, VCR-101 through 106 and VCR-201 through 206, listed in Table 3.6-1. The Limiting Condition for Operation and its associated ACTION statement for these valves is given in Technical Specification 3/4.6.1.7.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one or more of the isolation valve(s) specified in Table 3.6-1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and either:

- a. Restore the inoperable valve(s) to OPERABLE status within 4 hours, or
- b. Isolate each affected penetration within 4 hours by use of at least one deactivated automatic valve secured in the isolation position, or
- c. Isolate each affected penetration within 4 hours by use of at least one closed manual valve or blind flange, or
- d. Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

The provisions of Specification 3.0.4 are not applicable.

SURVEILLANCE REQUIREMENTS

4.6.3.1.1 The isolation valves specified in Table 3.6-1 shall be demonstrated OPERABLE prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by performance of a cycling test and verification of isolation time.

ATTACHMENT 3 TO AEP:NRC:1036B

CURRENT TECHNICAL SPECIFICATIONS PAGES MARKED-UP .

TO REFLECT PROPOSED CHANGES

CONTAINMENT SYSTEMS

3/4.6.3 CONTAINMENT ISOLATION VALVES

LIMITING CONDITION FOR OPERATION

3.6.3.1 The containment isolation valves specified in Table 3.6-1 shall be OPERABLE with isolation times as shown in Table 3.6-1. The ACTION statement of T/S 3/4.6.3 is not applicable to the containment purge supply and exhaust isolation valves, VCR-101 through 106 and VCR-201 through 206, listed in Table 3.6-1. The Limiting Condition for Operation and its associated ACTION statement for these valves is given in Technical Specification 3/4.6.1.7.

APPLICABILITY: MODES 1, 2, 3 and 4.

ACTION:

With one or more of the isolation valve(s) specified in Table 3.6-1 inoperable, either:

- a. Restore the inoperable valve(s) to OPERABLE status within 4 hours, or
- b. Isolate each affected penetration within 4 hours by use of at least one deactivated automatic valve secured in the isolation position, or
- c. Isolate each affected penetration within 4 hours by use of at least one closed manual valve or blind flange, or
- d. Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

The provisions of specification 3.0.4 are SURVEILLANCE REQUIREMENTS not applicable

4.6.3.1.1 The isolation valves specified in Table 3.6-1 shall be demonstrated OPERABLE prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator; control or power circuit by performance of a cycling test and verification of isolation time.

3/4.6.3 CONTAINMENT ISOLATION VALVESLIMITING CONDITION FOR OPERATION

3.6.3.1 The containment isolation valves specified in Table 3.6-1 shall be OPERABLE with isolation times as shown in Table 3.6-1. The ACTION statement of Technical Specification 3/4.6.3 is not applicable to the containment purge and exhaust isolation valves, VCR-101 through 106 and VCR-201 through 206, listed in Table 3.6-1. The Limiting Condition for Operation and its associated ACTION statement for these valves is given in Technical Specification 3/4.6.1.7.

APPLICABILITY: Modes 1, 2, 3 and 4.

ACTION:

With one or more of the isolation valves(s) specified in Table 3.6-1 inoperable, maintain at least one isolation valve OPERABLE in each affected penetration that is open and either:

- a. Restore the inoperable valve(s) to OPERABLE status within 4 hours, or
- b. Isolate each affected penetration within 4 hours by use of at least one deactivated automatic valve secured in the isolation position, or
- c. Isolate each affected penetration within 4 hours by use of at least one closed manual valve or blind flange; or
- d. Be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

The provisions of specification 3.0.4 are ^{not applicable} to the provisions of specification 3.0.4 are

SURVEILLANCE REQUIREMENTS

4.6.3.1.1 The isolation valves specified in Table 3.6-1 shall be demonstrated OPERABLE prior to returning the valve to service after maintenance, repair or replacement work is performed on the valve or its associated actuator, control or power circuit by performance of a cycling test and verification of isolation time.



10/10/10