

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9104170020 DOC. DATE: 91/04/09 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 AUTH. NAME AUTHOR AFFILIATION
 FITZGERALD, D.M. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: NPDES noncompliance notification: on 910327, automatic temp recorder for Outfall 001 failed & no temp measurements recorded from 910328-31. Plant procedures will be revised to describe compensatory sampling measures in event of failure.

DISTRIBUTION CODE: C001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Licensing Submittal: Environmental Rept Amdt & Related Correspondence

NOTES:

RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
	LTTR	ENCL		LTTR	ENCL
PD3-1 LA	3	3	PD3-1 PD	1	1
COLBURN, T.	1	1			
INTERNAL: AEOD/DSP/TPAB	1	1	NRR/DET/ESGB 8D	1	1
OC/LEMB	1	0	OGC/HDS2	1	0
<u>REG FILE</u> 01	1	1	RGN3 DRSS/RPB	1	1
EXTERNAL: EG&G SIMPSON, F	2	2	NRC PDR	1	1
NSIC	1	1			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 130

Initial-1

Indiana Michigan
Power Company
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49106
616 465 5901



MICHIGAN - DNR
SWQD-DATA UNIT
P. O. Box 30028
Lansing, MI 48909

April 9, 1991

Dear MDNR Representative:

Re: NPDES Permit MI 0005827

The purpose of this letter is to describe the reason for missing intake and discharge temperature data for Outfall 001 (Unit 1 discharge) at the Cook Nuclear Plant.

On March 27, 1991, the automatic temperature recorder for this outfall failed. The failure resulted in no temperature measurements being recorded from March 28 to 31, 1991.

In order to prevent future occurrences, we will revise plant procedures to describe compensatory sampling measures to be implemented in the event of recorder failure.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. M. Fitzgerald".

D. M. Fitzgerald
Environmental Supervisor

c: F. Morley/J. Bantjes - MDNR Plainwell
A. B. Davis - NRC Region III
J. A. Isom - NRC Resident Inspector
Dr. T. E. Murley - NRR
NRC Document Control

9104170020 910409
PDR ADOCK 05000315
S PDR

1/0
0001

