

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9111120196 DOC. DATE: 91/11/04 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316

AUTH. NAME AUTHOR AFFILIATION  
 FITZPATRICK, E. American Electric Power Co., Inc.  
 RECIP. NAME RECIPIENT AFFILIATION  
 MURLEY, T. E. Document Control Branch (Document Control Desk)

SUBJECT: Requests withdrawal of proposed changes to Tech Spec  
 4.8.1.1.2.e.2 re diesel generator operability.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal: General Distribution

### NOTES:

RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
	LTTR	ENCL		LTTR	ENCL
PD3-1 LA	1	1	PD3-1 PD	1	1
COLBURN, T.	2	2			
INTERNAL: NRR/DET/ECMB 7D	1	1	NRR/DET/ESGB	1	1
NRR/DOEA/OTSB11	1	1	NRR/DST 8E2	1	1
NRR/DST/SELB 7E	1	1	NRR/DST/SICB8H7	1	1
NRR/DST/SRXB 8E	1	1	NUDOCS-ABSTRACT	1	1
OC/LEMB	1	0	OGC/HDS2	1	0
<u>REG FILE</u> 01	1	1	RES/DSIR/EIB	1	1
EXTERNAL: NRC PDR	1	1	NSIC	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 10

A 1A-4

American Electric Power  
Service Corporation  
1 Riverside Plaza  
Columbus, OH 43215  
614 223 1000



AEP:NRC:1142B

Donald C. Cook Nuclear Plant Units 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
WITHDRAWAL OF PROPOSED CHANGES TO  
TECHNICAL SPECIFICATION 4.8.1.1.2.e.2

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Attn: T. E. Murley

November 4, 1991

Dear Dr. Murley:

In our January 15, 1991 letter, among other changes, we requested to revise T/S 4.8.1.1.2.e.2, which concerns diesel generator operability, to insert the term "steady state" as follows:

". . . Verifying the generator capability to reject a load greater than or equal to 600 kw while maintaining steady state voltage at  $4160 \pm 420$  volts and frequency at  $60 \pm 1.2$  Hz." We inserted these words to clarify the T/S so that, when the 600 kw load is dropped, the operator ignores the initial oscillation of the needle on the control room panel instruments that read voltage and frequency. Using that initial oscillation of the instrument could cause the diesel generator to fail the surveillance when it is in fact operable. This could occur even though the implementing procedure specifies the use of a pin recorder or visual recorder, which more accurately measure voltage and frequency, when performing the surveillance.

The purpose of this letter is to withdraw our request to revise T/S 4.8.1.1.2.e.2, as submitted in our letter AEP:NRC:1142 dated January 5, 1991. This request is made based upon discussions with the NRC Project Manager. It is noted that the other changes requested in this letter were issued as Amendments 155 (Unit 1) and 139 (Unit 2).

9111120196 911104  
PDR ADOCK 05000315  
PDR

*Handwritten:* AEP  
1/10

Dr. T. E. Murley

-2-

AEP:NRC:1142B

This document has been prepared following Corporate procedures that incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,



E. E. Fitzpatrick  
Vice President

eh

cc: D. H. Williams, Jr.  
A. A. Blind - Bridgman  
J. R. Padgett  
G. Charnoff  
NFEM Section Chief  
A. B. Davis - Region III  
NRC Resident Inspector - Bridgman

