

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9205050144 DOC.DATE: 92/05/01 NOTARIZED: NO DOCKET #
 FACIL:50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH.NAME AUTHOR AFFILIATION
 FITZPATRICK,E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP.NAME RECIPIENT AFFILIATION
 MURLEY,T.E.

SUBJECT: Application for amends to licenses DPR-58 & DPR-14,
 consisting of TS revising visual insp surveillance
 requirements & acceptance criteria associated w/T/Ss 3/4.7.8
 & 3/4.7.7.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 597,50
 TITLE: OR Submittal: General Distribution

NOTES: *See Snubber Tech Spec. Changes*

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-1 LA		1	1		PD3-1 PD		1	1
	STANG,J		2	2					
INTERNAL:	NRR/DET/ECMB 7D		1	1		NRR/DET/ESGB		1	1
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2		1	1
	NRR/DST/SELB 7E		1	1		NRR/DST/SICB8H7		1	1
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT		1	1
	OC/LEMB		1	0		OGC/HDS2		1	0
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

AA-7
 JLP



AEP:NRC:1143

Donald C. Cook Nuclear Plant Units 1 and 2
License Nos. 50-315 and 50-316
Docket Nos. DPR-58 and DPR-74
SNUBBER TECHNICAL SPECIFICATION CHANGES

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Attn: T. E. Murley

May 1, 1992

Dear Dr. Murley:

This letter and its attachments constitute an application for amendment of the license conditions and Technical Specifications (T/Ss) for the Donald C. Cook Nuclear Plant Units 1 and 2. Specifically, the changes proposed in this letter revise the visual inspection surveillance requirements and the acceptance criteria associated with T/Ss 3/4.7.8 and 3/4.7.7, "Snubbers," Units 1 and 2 respectively, in accordance with the guidance provided in Generic Letter 90-09, "Alternative Requirements for Snubber Visual Inspection Intervals and Corrective Actions," dated December 11, 1990. An alternate schedule for visual inspections has been developed by the NRC that maintains the same confidence level as the existing schedule and will generally allow visual inspections and corrective actions to be performed during plant outages. In addition, we are proposing to remove the snubber component lists in Tables 3.7.4 and 3.7.9 of T/Ss 3/4.7.8 and 3/4.7.7 for Units 1 and 2 respectively, in accordance with the guidance provided in Generic Letter 84-13, "Technical Specification for Snubbers," dated May 3, 1984.

Attachment 1 provides a detailed description of the proposed changes, the justification for the changes, and our proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92. Attachment 2 contains the existing T/S pages marked to reflect the proposed changes. Attachment 3 contains the proposed T/S pages.

We believe that the proposed changes will not result in (1) a significant change in the types of any effluent that may be released offsite, or (2) a significant increase in individual or cumulative occupational radiation exposure.

9205050144 920501
PDR ADDCK 05000315
P PDR

ADD 1



1-2

1

2-3

4-5

6-7

8

9

10

11

12

13

14

15

16

17

18

These proposed changes have been reviewed by the Plant Nuclear Safety Review Committee and the Nuclear Safety and Design Review Committee.

In compliance with the requirements of 10 CFR 50.91 (b)(1), copies of this letter and its attachments have been transmitted to the Michigan Public Service Commission and the Michigan Department of Public Health.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,



E. E. Fitzpatrick
Vice President

tjw

Attachments

cc: D. H. Williams, Jr.
A. A. Blind - Bridgman
J. R. Padgett
G. Charnoff
NFEM Section Chief
A. B. Davis - Region III
NRC Resident Inspector - Bridgman