

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9205270159 DOC. DATE: 92/05/21 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY Document Control Branch (Document Control Desk)

SUBJECT: Forwards revised TS & list of commitments, per 920513 telcon
 agreement to submit results of steam line break analysis
 prior to Cycle 13. Commitments incorporate criteria from
 WCAP-13187, App A into plant procedures.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+6
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-1 LA		1	1		PD3-1 PD		1	1
	STANG, J		2	2					
INTERNAL:	NRR/DET/ECMB 7D		1	1		NRR/DET/ESGB		1	1
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2		1	1
	NRR/DST/SELB 7E		1	1		NRR/DST/SICB8H7		1	1
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT		1	1
	OC/LEMB		1	0		OGC/HDS2		1	0
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 18 ENCL 16

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



AEP:NRC:1166C

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
MODIFICATION TO TECHNICAL SPECIFICATIONS CHANGE
TO ALLOW INTERIM PLUGGING CRITERIA OF 1.0 VOLT

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

May 21, 1992

Dear Dr. Murley:

This letter documents discussions held with the Cook Nuclear Plant NRR Project Manager, Mr. John Stang, on May 13, 1992. During those discussions we agreed to submit the results of our steam line break leak analysis prior to restart for Cycle 13. The analysis will provide estimated leakages expected through the end of Cycle 13. Technical Specification (T/S) 4.4.5.5.e has been revised to specifically state this reporting requirement.

In addition, the NRR Project Manager noted that an editorial change is required to T/S 4.4.5.4.a.10.1, which was previously submitted with our proposal regarding interim plugging criteria (AEP:NRC:1166B dated April 21, 1992). Proposed revised pages for both T/Ss (4.4.5.4.a.10.1 and 4.4.5.5.e) are contained in Attachment 1 to this letter.

Attachment 2 is a list of commitments that our NRR Project Manager requested we put in writing. These commitments concern incorporation of certain criteria from WCAP-13187 Appendix A into Cook Nuclear Plant procedures. This report was previously submitted with our letter AEP:NRC:1166 dated March 20, 1992. The commitments also involve additional inspection and reporting requirements requested by your staff.

This document has been prepared following Corporate procedures which incorporate a reasonable set of controls to ensure its accuracy and completeness prior to signature by the undersigned.

Sincerely,

E. E. Fitzpatrick
Vice President

A001
111



:

[illegible]

4

11

10

Dr. T. E. Murley

-2-

AEP:NRC:1166C

dag

Attachments

cc: D. H. Williams, Jr.
A. A. Blind - Bridgman
J. R. Padgett
G. Charnoff
NFEM Section Chief
A. B. Davis - Region III
NRC Resident Inspector - Bridgman