

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9209150314 DOC. DATE: 92/09/11 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315  
 AUTH. NAME AUTHOR AFFILIATION  
 TOLLAS, G. A. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 BLIND, A. A. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: LER 92-010-00: on 920812, determined that section of  
 Thermo-Lag 330 had been overlooked. Caused by obsolete  
 documentation being utilized for surveillance. Established  
 fire watch for area. W/920911 ltr.

DISTRIBUTION CODE: IE22T COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

### NOTES:

	RECIPIENT.		COPIES			RECIPIENT		COPIES		
	ID CODE/NAME		L	T		ID CODE/NAME		L	T	
	PD3-1 LA		1	1		PD3-1 PD		1	1	
	STANG, J		1	1						
INTERNAL:	ACNW		2	2		AEOD/DOA		1	1	
	AEOD/DSP/TPAB		1	1		AEOD/ROAB/DSP		2	2	
	NRR/DET/EMEB 7E		1	1		NRR/DLPQ/LHFB10		1	1	
	NRR/DLPQ/LPEB10		1	1		NRR/DOEA/DEAB		1	1	
	NRR/DREP/PRPB11		2	2		NRR/DST/SELB 8D		1	1	
	NRR/DST/SICB8H3		1	1		NRR/DST/SPLBBD1		1	1	
	NRR/DST/SRXB 8E		1	1		<del>REG. FILE</del> 02		1	1	
	RES/DSIR/EIB		1	1		RGN3 FILE 01		1	1	
EXTERNAL:	EG&G BRYCE, J. H		2	2		L ST LOBBY WARD		1	1	
	NRC PDR		1	1		NSIC MURPHY, G. A		1	1	
	NSIC POORE, W.		1	1		NUDOCS FULL TXT		1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

Indiana Michigan  
Power Company  
Cook Nuclear Plant  
One Cook Place  
Bridgman, MI 49106  
616 465 5901



September 11, 1992

United States Nuclear Regulatory Commission  
Document Control Desk  
Rockville, Maryland 20852

Operating Licenses DPR-58  
Docket No. 50-315

Document Control Manager:

In accordance with the criteria established by  
10 CFR 50.73 entitled Licensee Event Report System, the  
following report is being submitted:

92-010-00

Sincerely,

A handwritten signature in cursive script, appearing to read "A. A. Blind".

A. A. Blind  
Plant Manager

/sb

Attachment

c: D. H. Williams, Jr.  
A. B. Davis, Region III  
E. E. Fitzpatrick  
P. A. Barrett  
R. F. Kroeger  
B. Walters - Ft. Wayne  
NRC Resident Inspector  
J. F. Stang - NRC  
J. G. Keppler  
M. R. Padgett  
G. Charnoff, Esq.  
D. Hahn  
INPO  
S. J. Brewer/B. P. Lauzau  
B. A. Svensson

150044

9209150314 920911  
PDR ADOCK 05000315  
PDR

A large, stylized handwritten signature or initials, possibly "JE27", written in the bottom right corner of the page.

EXPIRES: 4/30/92

## LICENSEE EVENT REPORT (LER)

ESTIMATED BURDEN PER RESPONSE TO COMPLY WITH THIS INFORMATION COLLECTION REQUEST: 60.0 HRS. FORWARD COMMENTS REGARDING BURDEN ESTIMATE TO THE RECORDS AND REPORTS MANAGEMENT BRANCH (P-530), U.S. NUCLEAR REGULATORY COMMISSION, WASHINGTON, DC 20555, AND TO THE PAPERWORK REDUCTION PROJECT (3150-0104), OFFICE OF MANAGEMENT AND BUDGET, WASHINGTON, DC 20503.

FACILITY NAME (1) D. C. Cook Nuclear Plant - Unit 1										DOCKET NUMBER (2) 0 5 0 0 0 3 1 5					PAGE (3) 1 OF 0 1									
TITLE (4) Missed Surveillance Due to the Use of Obsolete Documentation in Support of Thermo-Lag 330 Inspections																								
EVENT DATE (5)			LER NUMBER (6)				REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)														
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES				DOCKET NUMBER(S)											
0	8	1	2	9	2	9	2	0	1	0	0	0	9	1	1	9	2	0	5	0	0	0		
OPERATING MODE (9) 6			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)																					
POWER LEVEL (10) 0 0 0			20.402(b)				20.405(c)				50.73(a)(2)(iv)				73.71(b)									
			20.405(a)(1)(i)				50.38(c)(1)				50.73(a)(2)(v)				73.71(c)									
			20.405(a)(1)(ii)				50.38(c)(2)				50.73(a)(2)(vii)				OTHER (Specify in Abstract below and in Text, NRC Form 366A)									
			20.405(a)(1)(iii)				50.73(a)(2)(ii)				50.73(a)(2)(viii)(A)													
			20.405(a)(1)(iv)				50.73(a)(2)(iii)				50.73(a)(2)(viii)(B)													
			20.405(a)(1)(v)				50.73(a)(2)(iii)				50.73(a)(2)(ix)													
LICENSEE CONTACT FOR THIS LER (12)																								
NAME G. A. Tollas - Safety and Assessment										TELEPHONE NUMBER														
										AREA CODE		6 1 6 4 6 5 - 5 9 0 1												
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																								
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC		CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRC														
SUPPLEMENTAL REPORT EXPECTED (14)												EXPECTED SUBMISSION DATE (15)		MONTH	DAY	YEAR								
<input checked="" type="checkbox"/> YES (If yes, complete EXPECTED SUBMISSION DATE)												<input type="checkbox"/> NO		1	2	3	1	9	2					

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single space typewritten lines) (16)

In response to NRC bulletin 92-01, fire watches were established in all areas of the plant where Thermo-Lag 330 was identified as having been installed. On August 12, 1992, following further research, it was determined that a section of Thermo-Lag 330, which enclosed a conduit in the Unit-2 Blowdown Flash Tank area, had been overlooked. It was further determined that the Thermo-Lag 330 at that location had not been included in the surveillance program for fire barriers as required by Technical Specification 3/4.7.10 due to obsolete documentation being utilized for that surveillance.

The immediate corrective action taken was the establishment of a fire watch for the area. A subsequent inspection of the Thermo-Lag 330 installation determined the fire barrier to be in acceptable condition to perform its intended design function.

This is an interim report. In an effort to ensure that there is no other Thermo-Lag 330 installed in the plant which has not been included in the surveillance program, all available drawings and previous surveillances are being researched. At this time, the investigation and research is ongoing and a complete response is not yet available.