

DONALD C. COOK NUCLEAR PLANT UNIT 1 CYCLE 13  
CORE OPERATING LIMITS REPORT

Revision 2

November 1992

9211230205 921113  
PDR ADOCK 05000315  
P PDR



COLR for DONALD C. COOK NUCLEAR PLANT UNIT 1 CYCLE 13

1.0 CORE OPERATING LIMITS REPORT

This Core Operating Limits Report for Donald C. Cook Nuclear Plant Unit 1 Cycle 13 has been prepared in accordance with the requirements of Technical Specification 6.9.1.11.

The Technical Specifications affected by this report are listed below:

3/4.1.1.4	Moderator Temperature Coefficient
3/4.1.3.1	Movable Control Assemblies Group Height
3/4.1.3.3	Rod Drop Time
3/4.1.3.4	Shutdown Rod Insertion Limits
3/4.1.3.5	Control Rod Insertion Limits
3/4.2.1	Axial Flux Difference
3/4.2.2	Heat Flux Hot Channel Factor
3/4.2.3	Nuclear Enthalpy Hot Channel Factor
3/4.2.6	Allowable Power Level

100

100

COLR for Donald C. Cook Nuclear Plant Unit 1 Cycle 13

2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.9.1.11.

2.1 Moderator Temperature Coefficient (Specification 3/4.1.1.4)

2.1.1 The Moderator Temperature Coefficient (MTC) Limits are:

The BOL/ARO-MTC shall be less positive than the value given in Figure 1.

The EOL/ARO/RTP-MTC shall be less negative than  $-4.59E-4 \Delta k/k/^\circ F$ .

This limit is based on a  $T_{avg}$  program with HFP  $T_{avg}$  of 553 F

where: ARO stands for All Rods Out  
BOL stands for Beginning of Cycle Life  
EOL stands for End of Cycle Life  
RTP stands for Rated Thermal Power  
HFP stands for Hot Full Thermal Power

2.1.2 The MTC Surveillance limit is:

The 300 ppm/ARO/RTP-MTC should be less negative than or equal to  $-3.67E-4 \Delta k/k/^\circ F$  at a vessel average temperature of 553 F.

COLR for Donald C. Cook Nuclear Plant Unit 1 Cycle 13

2.2 Rod Drop Time Drop Height (Specification 3/4.1.3.3)

2.2.1 All rods shall be dropped from 231 steps.

2.3 Shutdown Rod Insertion Limit (Specification 3/4.1.3.4)

2.3.1 The shutdown rods shall be withdrawn to 231 steps.

2.4 Control Rod Insertion Limits (Specifications 3/4.1.3.5 and 3/4.1.3.1)

2.4.1 The control rod banks shall be limited in physical insertion as shown in Figure 2.

2.4.2 Successive Control Banks shall overlap by 103 steps. The sequence for Control Bank withdrawal shall be Control Bank A, Control Bank B, Control Bank C, and Control Bank D.

2.5 Axial Flux Difference (Specification 3/4.2.1)

2.5.1 The Allowable Operation Limits are provided in Figure 3.

2.5.2 The AXIAL FLUX DIFFERENCE (AFD) target band during base load operations is +3%, -3% (not applicable for this cycle).

2.5.3 The AFD target band is +5%, -5% for a cycle average accumulated burnup  $\geq 0.0$  MWD/MTU.

COLR for Donald C. Cook Nuclear Plant Unit 1 Cycle 13

2.6 Heat Flux Hot Channel Factor -  $F_Q(Z)$  (Specification 3.2.2)

$$F_Q(Z) \leq \frac{CFQ}{P} * K(Z) \quad \text{for } P > 0.5$$

$$F_Q(Z) \leq 2 * CFQ * K(Z) \quad \text{for } P \leq 0.5$$

$$\text{where: } P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$$

2.6.1  $CFQ = 2.15$  for Westinghouse fuel

2.6.2  $K(Z)$  is provided in Figure 4 for Westinghouse fuel

COLR for Donald C. Cook Nuclear Plant Unit 1 Cycle 13

2.7 Nuclear Enthalpy Rise Hot Channel Factor -  $F_{\Delta H}^N$   
(Specification 3/4.2.3)

$$F_{\Delta H}^N \leq \text{CFDH} * (1 + \text{PFDH} * (1-P))$$

where:  $P = \frac{\text{THERMAL POWER}}{\text{RATED THERMAL POWER}}$

2.7.1                      CFDH = 1.49 for Westinghouse fuel

2.7.2                      PFDH = 0.3

COLR for Donald C. Cook Nuclear Plant Unit 1 Cycle 13

2.8 Allowable Power Level - APL (Specification 3.2.6)

$$\text{APL} = \min \text{ over } Z \text{ for } \frac{\text{CFQ} * K(Z)}{F_Q(Z) * V(Z) * F_P}$$

- 2.8.1 V(Z) is provided in Table 1 for  $\pm 5\%$  AFD target band
- 2.8.2 CFQ and K(Z) are provided in COLR Sections 2.6.1 and 2.6.2, respectively
- 2.8.3  $F_P$  is provided in Technical Specification 3.2.6






FIGURE 1  
MODERATOR TEMPERATURE COEFFICIENT (MTC)

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

26

27

28

29

30

31

32

33

34

35

36

37

38

39

40

41

42

43

44

45

46

47

48

49

FULLY WITHDRAWN




FIGURE 2

ROD BANK INSERTION LIMITS VERSUS  
THERMAL POWER FOUR-LOOP OPERATION




FIGURE 3  
AXIAL FLUX DIFFERENCE LIMITS  
AS A FUNCTION OF RATED THERMAL POWER




FIGURE 4

$K(z)$  - NORMALIZED  $F_q(z)$  AS A FUNCTION  
OF CORE HEIGHT FOR WESTINGHOUSE FUEL

MESH NO.	AXIAL ELEV. (FT)	BURNUP RANGES (MWD/MTU)									
		0 150	150 1000	1000 2000	2000 4000	4000 6000	6000 8000	8000 10000	10000 12000	12000 14000	14000 EOL
1	0.0	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
2	0.2	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
3	0.4	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
4	0.6	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
5	0.8	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
6	1.0	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
7	1.2	1.1030	1.1033	1.1041	1.1066	1.1106	1.1159	1.1228	1.1311	1.1408	1.1408
8	1.4	1.1008	1.1015	1.1026	1.1056	1.1097	1.1149	1.1213	1.1289	1.1376	1.1376
9	1.6	1.0988	1.0996	1.1009	1.1043	1.1084	1.1135	1.1193	1.1281	1.1337	1.1337
10	1.8	1.0974	1.0985	1.0999	1.1032	1.1071	1.1116	1.1168	1.1226	1.1291	1.1291
11	2.0	1.0969	1.0979	1.0992	1.1021	1.1054	1.1093	1.1137	1.1186	1.1239	1.1239
12	2.2	1.0964	1.0972	1.0983	1.1007	1.1035	1.1066	1.1101	1.1140	1.1183	1.1183
13	2.4	1.0955	1.0962	1.0971	1.0990	1.1012	1.1035	1.1061	1.1090	1.1120	1.1120
14	2.6	1.0945	1.0951	1.0957	1.0971	1.0985	1.1001	1.1017	1.1035	1.1053	1.1053
15	2.8	1.0933	1.0937	1.0941	1.0948	1.0956	1.0963	1.0970	1.0977	1.0984	1.0984
16	3.0	1.0918	1.0919	1.0921	1.0922	1.0922	1.0922	1.0920	1.0917	1.0913	1.0907
17	3.2	1.0905	1.0905	1.0902	1.0899	1.0894	1.0894	1.0882	1.0876	1.0870	1.0865
18	3.4	1.0896	1.0896	1.0888	1.0879	1.0878	1.0870	1.0862	1.0873	1.0889	1.0889
19	3.6	1.0890	1.0890	1.0880	1.0872	1.0861	1.0852	1.0869	1.0905	1.0945	1.0945
20	3.8	1.0889	1.0889	1.0876	1.0866	1.0851	1.0865	1.0904	1.0951	1.0999	1.0999
21	4.0	1.0889	1.0889	1.0878	1.0869	1.0870	1.0892	1.0937	1.0993	1.1049	1.1049
22	4.2	1.0885	1.0885	1.0878	1.0873	1.0887	1.0917	1.0969	1.1033	1.1096	1.1096
23	4.4	1.0880	1.0880	1.0875	1.0882	1.0904	1.0940	1.0998	1.1069	1.1138	1.1138
24	4.6	1.0871	1.0871	1.0873	1.0889	1.0918	1.0960	1.1024	1.1100	1.1175	1.1175
25	4.8	1.0863	1.0865	1.0872	1.0894	1.0929	1.0978	1.1047	1.1126	1.1206	1.1206
26	5.0	1.0856	1.0862	1.0871	1.0899	1.0939	1.0992	1.1064	1.1146	1.1230	1.1230
27	5.2	1.0851	1.0859	1.0870	1.0902	1.0946	1.1002	1.1077	1.1159	1.1247	1.1247
28	5.4	1.0844	1.0853	1.0866	1.0902	1.0949	1.1008	1.1084	1.1165	1.1256	1.1256
29	5.6	1.0833	1.0844	1.0859	1.0898	1.0948	1.1008	1.1085	1.1164	1.1256	1.1256
30	5.8	1.0820	1.0832	1.0849	1.0890	1.0941	1.1002	1.1079	1.1158	1.1248	1.1248
31	6.0	1.0803	1.0817	1.0835	1.0878	1.0930	1.0991	1.1067	1.1141	1.1230	1.1230
32	6.2	1.0783	1.0798	1.0817	1.0861	1.0913	1.0973	1.1047	1.1118	1.1204	1.1204
33	6.4	1.0759	1.0774	1.0794	1.0838	1.0889	1.0948	1.1019	1.1087	1.1167	1.1167
34	6.6	1.0730	1.0746	1.0766	1.0810	1.0860	1.0916	1.0983	1.1046	1.1121	1.1121
35	6.8	1.0698	1.0714	1.0733	1.0775	1.0823	1.0875	1.0939	1.0997	1.1065	1.1065
36	7.0	1.0654	1.0671	1.0691	1.0734	1.0792	1.0830	1.0887	1.0939	1.0998	1.0998
37	7.2	1.0626	1.0653	1.0671	1.0700	1.0772	1.0772	1.0825	1.0870	1.0924	1.0924
38	7.4	1.0628	1.0654	1.0660	1.0668	1.0741	1.0741	1.0756	1.0793	1.0837	1.0837
39	7.6	1.0626	1.0649	1.0656	1.0682	1.0704	1.0720	1.0731	1.0737	1.0737	1.0737
40	7.8	1.0663	1.0678	1.0694	1.0718	1.0735	1.0743	1.0743	1.0741	1.0731	1.0712
41	8.0	1.0714	1.0722	1.0730	1.0745	1.0754	1.0760	1.0781	1.0781	1.0758	1.0750
42	8.2	1.0759	1.0762	1.0765	1.0771	1.0777	1.0784	1.0790	1.0800	1.0802	1.0802
43	8.4	1.0804	1.0806	1.0809	1.0814	1.0820	1.0826	1.0833	1.0854	1.0854	1.0848
44	8.6	1.0848	1.0851	1.0855	1.0863	1.0870	1.0876	1.0882	1.0905	1.0905	1.0893
45	8.8	1.0890	1.0895	1.0900	1.0910	1.0918	1.0924	1.0929	1.0953	1.0953	1.0934
46	9.0	1.0929	1.0935	1.0942	1.0954	1.0963	1.0970	1.0974	1.0997	1.0997	1.0975
47	9.2	1.0966	1.0973	1.0980	1.0993	1.1003	1.1011	1.1016	1.1038	1.1038	1.1019
48	9.4	1.1000	1.1007	1.1014	1.1028	1.1040	1.1051	1.1059	1.1075	1.1075	1.1071
49	9.6	1.1029	1.1039	1.1049	1.1068	1.1085	1.1100	1.1113	1.1124	1.1132	1.1132
50	9.8	1.1065	1.1076	1.1087	1.1109	1.1129	1.1147	1.1164	1.1179	1.1192	1.1192
51	10.0	1.1103	1.1113	1.1124	1.1147	1.1168	1.1189	1.1209	1.1229	1.1248	1.1248
52	10.2	1.1137	1.1146	1.1158	1.1181	1.1204	1.1227	1.1250	1.1273	1.1297	1.1297
53	10.4	1.1167	1.1178	1.1187	1.1210	1.1234	1.1259	1.1285	1.1311	1.1339	1.1339
54	10.6	1.1192	1.1201	1.1212	1.1235	1.1259	1.1285	1.1313	1.1343	1.1374	1.1374
55	10.8	1.1211	1.1221	1.1234	1.1259	1.1286	1.1313	1.1342	1.1372	1.1402	1.1402
56	11.0	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
57	11.2	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
58	11.4	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
59	11.6	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
60	11.8	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
61	12.0	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000

Top and bottom 10% of core are excluded as per Technical Specifications.

TABLE 1  
DONALD C. COOK UNIT 1 CYCLE 13  
V(Z) FUNCTION