

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9211240001 DOC. DATE: 92/11/12 NOTARIZED: NO DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316  
 AUTH. NAME AUTHOR AFFILIATION  
 MENGE, R.C. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP. NAME RECIPIENT AFFILIATION  
 MORLEY, F. Michigan, State of

SUBJECT: NPDES noncompliance notification: on 921109, review of records determined that First Quarter 1992 samples for stormwater outfall 001S not collected. Quarterly sampling requirement added to computerized tracking sys.

DISTRIBUTION CODE: C001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: Licensing Submittal: Environmental Rept Amdt & Related Correspondence

### NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-1 LA	3 3	PD3-1 PD	1 1
	STANG, J	1 1		
INTERNAL:	NRR/DET/ESGB 8D	1 1	OC/LEMB	1 0
	OGC/HDS2	1 0	REG. FILE 01	1 1
	RGN3 DRSS/RPB	1 1		
EXTERNAL:	EG&G SIMPSON, F	2 2	NRC PDR	1 1
	NSIC	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 14 ENCL 12 0

EC-1  
 JSP



Indiana Michigan  
Power Company  
One Summit Square  
P.O. Box 60  
Fort Wayne, IN 46801  
219 425 2111



**INDIANA  
MICHIGAN  
POWER**

Mr. Fred Morley, District Supervisor  
Surface Water Quality Division  
Michigan Department of Natural Resources  
621 North 10th Street  
P. O. Box 355  
Plainwell, MI 49080

November 12, 1992

Richard C. Menge  
President  
219 425 2103

Dear Mr. Morley:

RE: Cook Nuclear Plant  
NPDES Permit No. MI 0005827

On November 9, 1992, an internal review of our records revealed that the first quarter 1992 samples for Stormwater Outfall 001S had not been collected. Part I, Section A. 5. of the permit requires that samples be collected quarterly, for Total Copper and Total Zinc analyses.

In order to prevent recurrences of this event, the quarterly sampling requirement has been added to our tracking system used for other NPDES analyses. This computerized tracking system alerts the user that the sample is due to be collected, and will continue to appear as due until the records are signed off as completed.

This event will also be documented in our annual submittal of Stormwater monitoring results, due to the MDNR on March 1, 1993. Second, third and fourth quarter 1992 samples were collected per the permit requirements.

By copy of this letter, the Nuclear Regulatory Commission is notified pursuant to the requirements of Appendix B, Part II, Nonradiological, Environmental Protection Plan, Section 3.2.

Very truly yours,

R. C. Menge  
President

RCM/sdb/050

c: c: A. B. Davis - NRC Region III  
NRC Resident Inspector  
Dr. T. E. Murley - NRC Document Control  
NRR Document Control

230104

9211240001 921112  
PDR ADOCK 05000315  
S PDR

*Cool*  
*1/4*

November 12, 1992

Mr. Fred Morley, District Supervisor

Page Two

I certify under penalty of law that I have personally examined and am familiar with the information submitted on this and all attached documents; and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.



R. C. Merge