

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 M I D C C 2 ② 0 0 0 0 0 0 0 0 0 0 0 0 ③ 4 1 1 1 1 ④ 57 CAT 58 ⑤

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T

7 8 9 L ⑥ 0 5 0 0 0 3 1 6 ⑦ 0 4 2 9 8 0 ⑧ 0 5 2 0 8 0 ⑨

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING NORMAL OPERATION WHILE PERFORMING A SURVEILLANCE TEST, IT WAS DISCOVERED

0 3 | THAT THE BISTABLE FOR STEAM GENERATOR WATER LEVEL HI-HI ESF SETPOINT (TURBINE

0 4 | TRIP AND FEEDWATER ISOLATION) HAD DRIFTED HIGH EXCEEDING THE LCO VALUE. T.S.

0 5 | TABLE 3.3-4 ITEM 5.a. THE APPLICABLE ACTION REQUIREMENT WAS MET.

0 6 |

0 7 |

0 8 |

7 8 9

SYSTEM CODE S H 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14				COMP. SUBCODE S 15		VALVE SUBCODE Z 16					
EVENT YEAR 8 0 21		SEQUENTIAL REPORT NO. 0 2 1 24		OCCURRENCE CODE 0 3 28		REPORT TYPE L 30		REVISION NO. 0 32									
ACTION TAKEN E 33		FUTURE ACTION Z 34		EFFECT ON PLANT Z 35		SHUTDOWN METHOD Z 36		HOURS 0 0 0 0 22		ATTACHMENT SUBMITTED N 41		NPRD-4 FORM SUB. Y 42		PRIME COMP. SUPPLIER N 43		COMPONENT MANUFACTURER F 1 8 0 44	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 THE BISTABLE WAS RECALIBRATED AND RETURNED TO SERVICE. ON APRIL 30, 1980, THE

1 1 BISTABLE TRIP POINT WAS AGAIN CHECKED. THE SETPOINT HAD DRIFTED SIGNIFICANTLY AND

1 2 THE BISTABLE (FOXBORO-MODEL 63 U-BC-OHEM-F) WAS REPLACED. THE NEW BISTABLE WAS

1 3 CALIBRATED AND PLACED IN SERVICE.

1 4

7	8	9	FACILITY STATUS										% POWER										OTHER STATUS										METHOD OF DISCOVERY										DISCOVERY DESCRIPTION										OPERATOR OBSERVATION									
1	5		E	28	1	0	0	29	NA	30	A	31																																																		
7	8	9	ACTIVITY CONTENT										AMOUNT OF ACTIVITY										LOCATION OF RELEASE																																							
1	6		Z	33	Z	34	NA	35	NA	36																																																				
7	8	9	PERSONNEL EXPOSURES										DESCRIPTION																																																	
1	7		0	0	0	37	Z	38	NA	39																																																				
7	8	9	PERSONNEL INJURIES										DESCRIPTION																																																	
1	8		0	0	0	40	NA	41																																																						
7	8	9	LOSS OF OR DAMAGE TO FACILITY										DESCRIPTION										8005270461																																							
1	9		Z	42	NA	43																																																								
7	8	9	PUBLICITY										DESCRIPTION										NRC USE ONLY																																							
2	0		N	44	NA	45																																																								
7	8	9	ISSUED																																																											

NAME OF PREPARER J. L. RISCHLING

PHONE: 616-465-5901

100-100000

8 Copies