

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5
7	8	9						14	15	25										26	30				57	58			
		LICENSEE CODE							LICENSE NUMBER											LICENSE TYPE					CAT				

CON'T

0	1	REPORT SOURCE														SOCKET NUMBER														EVENT DATE														REPORT DATE													
7	8	L	6	0	5	0	0	0	3	1	6	7	1	1	0	1	7	9	8	0	6	0	2	8	0	9																															
		60	61	68														69	74														75	80																							

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | DURING SURVEILLANCE TESTING, HYDROGEN RECOMBINER NO. 1 FAILED TO INCREASE
0 3 | TEMPERATURE TO $\geq 1200^{\circ}\text{F}$ WITHIN 5 HOURS AS REQUIRED BY T.S. 4.6.4.2B3. SIX
0 4 | HOURS WERE REQUIRED TO REACH THAT TEMPERATURE. ONCE THE TEMPERATURE WAS
0 5 | REACHED, IT WAS MAINTAINED AS REQUIRED. THE NO. 2 RECOMBINER TESTED
0 6 | SATISFACTORILY. THIS IS THE FIRST OCCURRENCE OF THIS TYPE. PUBLIC HEALTH
0 7 | AND SAFETY WERE NOT AFFECTED.

SYSTEM CODE S E (11)		CAUSE CODE B (12)		CAUSE SUBCODE B (13)		COMPONENT CODE R E C O M B (14)				COMP. SUBCODE Z (15)		VALVE SUBCODE Z (16)	
LER/RO REPORT NUMBER [] [] 21 22		EVENT YEAR 7 9 23 24		SEQUENTIAL REPORT NO. [] [] [] 25 26 27		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30		REVISION NO. [] 31			
ACTION TAKEN B (18)		FUTURE ACTION Z (19)		EFFECT ON PLANT Z (20)		SHUTDOWN METHOD Z (21)		HOURS 0 0 0 (22) 37 38 39		ATTACHMENT SUBMITTED N (23)		NPRD-4 FORM SUB. N (24)	
PRIME COMP. SUPPLIER N (25)		COMPONENT MANUFACTURER W 2 0 0 (26)											

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1	0	CAUSE OF THE EVENT WAS INCORRECT ELECTRICAL CONNECTION OF ONE HEATER
1	1	ELEMENT WHICH RESULTED IN A RESISTANCE IMBALANCE BETWEEN PHASES. THE
1	2	WIRING WAS CORRECTED AND THE CONTROLLER GAIN AND BIAS WERE ADJUSTED.
1	3	THE UNIT WAS RETESTED AND TEMPERATURE EXCEEDED 1200 ⁰ F IN 4 HOURS.

A number line starting at 7 and ending at 9. The segment between 7 and 8 is divided into 10 equal parts. The first part is labeled '1' and the fourth part is labeled '4'. The number 8 is marked at the end of the segment.

7 8 9 FACILITY STATUS (28) 10 11 12 13 % POWER 0 0 0 (29) 14 15 16 17 OTHER STATUS NA (30) 18 19 20 21 22 23 24 25 26 27 METHOD OF DISCOVERY (31) 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 DISCOVERY DESCRIPTION SURVEILLANCE TEST (32) 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 33 34

AMOUNT OF ACTIVITY
NA

35

LOCATION OF RELEASE

36

PERSONNEL EXPOSURES									
NUMBER				TYPE	DESCRIPTION				
1	7	0	0	0	(37) Z (38) NA (39)				

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1 8	0 0 0	40	NA

1 9		Z	(42)	LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION	(43)	NA	8006050315	JUN 4 1980
-----	--	---	------	---	------	----	------------	------------

7		8	9	10		NRC USE ONLY									
ISSUED		PUBLICITY		DESCRIPTION											
2	0	N	44	NA											

10

DAVID G. WIZNER

NAME OF PREPARER _____

PHONE: 616-465-5901, EXT. 1398



214