

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	I	D	C	C	2	2	0	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER											25	26	LICENSE TYPE				30	57	CAT	58

REPORT

0	1	REPORT SOURCE										DOCKET NUMBER										EVENT DATE										REPORT DATE									
7	8	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80																			
		L	6	0	5	0	0	0	3	1	6	7	0	6	0	9	8	0	8	0	7	0	8																		

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

RECENTLY, IT WAS DETERMINED THAT TWO CHECK VALVES (R-156 AND R-157)

03 ARE UTILIZED AS 'CONTAINMENT ISOLATION VALVES. AS A RESULT OF THIS

0 4 DETERMINATION, THIS REPORT IS BEING SUBMITTED IDENTIFYING PREVIOUS

05 | EVENTS INVOLVING R-156 AND R-157. THESE VALVES WERE NOT INCLUDED IN

06 THE TYPE C LEAK TEST PRIOR TO NOVEMBER 1978. T.S. 4.6.1.2.d. CHECK

07 VALVE R-156 WAS FOUND INSTALLED BACKWARDS, T.S. 3.5.3.1. ACTION ITEM

018 -C WAS FULFILLED BY CLOSING A MANUAL ISOLATION VALVE.

7 8 9

0 9

7 8

SYSTEM CODE

S D 11

9 10

CAUSE CODE

B 12

11

CAUSE SUBCODE

A 13

12

COMPONENT CODE

V A L V E X 14

13 18

COMP. SUBCODE

C 15

19

VALVE SUBCODE

A 16

20

(17) LER/RO REPORT NUMBER 8 0 — 0 2 6 / 0 3 L — 0

ACTION TAKEN		FUTURE ACTION		EFFECT ON PLANT		SHUTDOWN METHOD		HOURS				ATTACHMENT SUBMITTED		NPRD-4 FORM SUB.		PRIME COMP. SUPPLIER		COMPONENT MANUFACTUR.			
G	18	Z	19	Z	20	Z	21	0	0	0	0	Y	23	N	24	N	25	K	0	8	
22	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THESE VALVES PROVIDE A RELIEF FUNCTION FOR GLYCOL TRAPPED BETWEEN THE

11 CONTAINMENT ISOLATION VALVES: VCR-10 AND 11; AND VCR-20 AND 21. THE

1 2 TWO CHECK VALVES WERE OMITTED WHEN THE ORIGINAL SURVEILLANCE PROCEDURE

1 2 WAS PREPARED TO CONDUCT TYPE C LEAKAGE TESTS. ON NOVEMBER 18, 1978

14 | CHECK VALVE R-156 WAS REMOVED AND REINSTALLED (SEE ATTACHED SUPPLEMEN

7 8 9
FACILITY STATUS (28) % POWER (29) OTHER STATUS (30) METHOD OF DISCOVERY (31) DISCOVERY DESCRIPTION (32)
1 5 E 0 7 5 NA B SURVEILLANCE TESTING

7 8 9 10 12 13 44 45 46

ACTIVITY CONTENT
RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 6 Z (33) Z (34) NA NA

PERSONNEL EXPOSURES		TYPE		DESCRIPTION
NUMBER				
1	7	0	0	0
		(37)	Z	(38) NA

7		8		9		11		12		13	
PERSONNEL INJURIES											
NUMBER						DESCRIPTION (41)					
1	8	0	0	0	(40)	NA					

7		8	9	11		12
TYPE		LOSS OF OR DAMAGE TO FACILITY DESCRIPTION (43)				
1	9	Z	(42)	NA		

8007150695

7		8	9	10	PUBLICITY										NRC USE ONLY									
ISSUED		DESCRIPTION																						
2	0	N	(44)		NA																			
7	8	9	10											68 69										

NAME OF PREPARER J. L. Rischling

PHONE: 616-465-5901

ATTACHMENT TO LER #80-026/03L-0

SUPPLEMENT TO CAUSE DESCRIPTION

CORRECTLY. A TYPE C LEAK TEST WAS PERFORMED ON BOTH R-156 AND R-157, BOTH VALVES SUCCESSFULLY PASSED. AT THIS TIME THESE CHECK VALVES WERE ADDED TO THE APPLICABLE SURVEILLANCE TEST PROCEDURE, INCLUDING THEM IN THE TYPE C LEAKAGE TEST. A SEPARATE REPORT IS BEING SUBMITTED FOR THESE VALVES IN UNIT 1.

