

LICENSEE EVENT REPORT

CONTROL BLOCK:

							(1)
--	--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1	REPORT SOURCE										L	6	0	5	0	0	0	3	1	5	7	1	2	3	0	7	8	8	1	2	1	0	8	0	9												
7	8											60	61	DOCKET NUMBER										68	69	EVENT DATE										74	75	REPORT DATE										80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | WHILE PERFORMING A ROUTINE SURVEILLANCE TEST IT WAS DISCOVERED THAT CONTAINMENT

0 3 | ISOLATION VALVE VCR-010 HAD FAILED TO COMPLETELY CLOSE AS REQUIRED. VCR-010 WAS

0 4 | RETURNED TO SERVICE WITHIN ONE HOUR OF DISCOVERY IN COMPLIANCE WITH THE FOUR HOUR

0 5 | TIME LIMIT IMPOSED BY T.S. 3.6.3.1A.

0 6 |

0 7 |

0 8 |

7 8 9

09		SYSTEM CODE S D		CAUSE CODE E	CAUSE SUBCODE B	COMPONENT CODE V A L V E X				COMP. SUBCODE D	VALVE SUBCODE D		
7	8	9	10	11	12	13	14	15	16	17	18	19	20
LER/RO REPORT NUMBER		EVENT YEAR 7 8			SEQUENTIAL REPORT NO. 0 7 0		OCCURRENCE CODE /		REPORT TYPE 0 3		REVISION NO. 0		
21	22	23	24	25	26	27	28	29	30	31	32		
ACTION TAKEN X	FUTURE ACTION Z	EFFECT ON PLANT Z	SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. N		PRIME COMP. SUPPLIER N		
33	34	35	36	37	38	39	40	41	42	43	COMPONENT MANUFACTURER G 2 5 5		
18	19	20	21	22	23	24	25	26	27	28	29	30	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | TECHNICIAN INVESTIGATION INDICATED THAT THROUGH CYCLING THE VALVE SEVERAL TIMES

1 1 | THE STROKE BECAME SMOOTH AND THE VALVE WOULD FULLY CLOSE. A FOREIGN MATERIAL

1 2 | SUCH AS DIRT OR DUST APPEARED TO HAVE BUILT UP IN THE VALVE GLAND AREA CAUSING

1 3 | THE PROBLEM.

1 4 |

7 8 9

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	D	28	0	0	0	29	N/A	30
7	8	9	10	11	12	13	14	15	16
ACTIVITY		CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	34	35	36	37	38	39
7	8	9	10	11	12	13	14	15	16
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	Z	38	39	40
7	8	9	10	11	12	13	14	15	16
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40	41	42	43	44
7	8	9	10	11	12	13	14	15	16
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42	43	44	45	46	47	48
7	8	9	10	11	12	13	14	15	16
PUBLICITY		ISSUED		DESCRIPTION					
2	0	N	44	45	46	47	48	49	50
7	8	9	10	11	12	13	14	15	16

8012160496

NRC USE ONLY

NAME OF PREPARER T.P. Beilman

PHONE: 616-465-5901 Ext. 1280

