

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION: NBR: 8107080386 DOC. DATE: 81/07/02 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana & 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana & 05000316
 AUTH. NAME. AUTHOR AFFILIATION
 HUNTER, R.S. Indiana & Michigan Electric Co.
 RECIP. NAME. RECIPIENT AFFILIATION
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Advises that EPRI PWR safety relief valves installed in plant will perform intended function. Util will submit final evaluations & other plant specific data on schedule consistent w/RC Youngdahl 801215 & 810701 ltrs.

DISTRIBUTION CODE: A046S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: Response to NUREG-0737/NUREG-0660 TMI Action Plan Rgmts (DL's)

NOTES: I&E: 3 copies all material. 05000315
 Send 3 copies of all material to I&E. 05000316

ACTION:	RECIPIENT ID CODE/NAME:		COPIES		RECIPIENT ID CODE/NAME	COPIES	
			LTTR	ENCL		LTTR	ENCL
	ORB #1	8C 05	7	7			
INTERNAL:	A/D C&C SYS	27	1		A/D C&S ENG	22	1
	A/D FOR TECH	32	1		A/D GEN PROJ	31	1
	A/D LICENS	16	1		A/D M&Q ENG	23	1
	A/D OP REACT	15	1		A/D PLANT SYS	25	1
	A/D RAD PROT	26	1		A/D SAFETY AS	17	1
	DEP. DIR, DHFS	29	1		DIR, EM PREP	33	1
	DIRECTOR, DE	21	1		DIRECTOR, DHFS	28	1
	DIRECTOR, DL	14	1		DIRECTOR, DSI	24	1
	DIRECTOR, DST	30	1		EMERG PREP DEV		1
	EMRG. PRP LIC		1		FEMA-REP DIV		1
	I&E	12	2		OELD		1
	OR ASSESS BR	18	3		PDR	02	1
	RAD ASMT BR		1		<u>BEG. FILE</u>	01	1
EXTERNAL:	ACRS	34	16	16	INPO, J. STARNES		1
	LPDR	03	1	1	NSIC	04	1
	NTIS		1	1			

HA
4

TOTAL NUMBER OF COPIES REQUIRED: LTTR

59

56

ENCL

0

55


INDIANA & MICHIGAN ELECTRIC COMPANY

P. O. BOX 18
BOWLING GREEN STATION
NEW YORK, N. Y. 10004

July 2, 1981
AEP:NRC:0585

Donald C. Cook Nuclear Plant Unit Nos. 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
NUREG-0737, Section II.D.1 - PWR Safety & Relief Valve Test Program


Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555



Dear Mr. Denton:

By letter dated July 1, 1981, R. C. Youngdahl (Consumers Power), Chairman, EPRI Research Program, transmitted the Interim Data Report for the EPRI PWR Safety and Relief Valve Test Program. This report summarizes the test data collected to date on relief valves (safety valve data is still not available). Results provided in Section 4.5 for relief valves of the EPRI Interim Data Report are applicable to our plant. The Donald C. Cook Nuclear Plant has Masoneilan Model #38-20721 power operated relief valves and Crosby Model #HB-BP-86-6M6 safety valves. Please note that Masoneilan valves identical to those tested are installed in both Units of the Cook Plant. Our preliminary evaluation of the data indicates that the valves installed in our plant will perform their intended function. Indiana & Michigan Electric Company will submit final evaluations and other plant specific data on a schedule consistent with R. C. Youngdahl's letter of December 15, 1980 as modified by his letter of July 1, 1981.

Very truly yours,


R. S. Hunter
Vice President

cc: John E. Dolan - Columbus
R. C. Callen
G. Charnoff
R. W. Jurgensen
D. V. Shaller - Bridgman
Region III Resident Inspector - Bridgman
Joe Williams

8107080386 810702
PDR ADOCK 05000315
PDR

A046
610