

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9310210186 DOC. DATE: 93/10/12 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MURLEY, T. E. Document Control Branch (Document Control Desk)

SUBJECT: Informs NRC that licensees successfully completed random
 internal insp of water supply sys of fire protection sys
 piping.

DISTRIBUTION CODE: A006D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: OR/Licensing Submittal: Fire Protection

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD3-1 LA		1	0		PD3-1 PD		1	1
	WETZEL, B		2	2					
INTERNAL:	NRR/DSSA/SPLB		1	1		NUDOCS-ABSTRACT		1	1
	OC/LEDGB		1	0		OGC/HDS2		1	0
	REG FILE 01		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 11 ENCL 8 0

MA-4
 11/10



AEP:NRC:0692CQ

Donald C. Cook Nuclear Plant Units 1 and 2
Docket Nos. 50-315 and 50-316
License Nos. DPR-58 and DPR-74
FIRE PROTECTION SYSTEM
WATER SUPPLY SYSTEM INSPECTION

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Attn: T. E. Murley

October 12, 1993

Dear Dr. Murley:

The purpose of this letter is to inform you that we have successfully completed the random internal inspection of the water supply system of the fire protection system piping. We committed to this inspection in our AEP:NRC:0692CH letter dated May 15, 1992. In this May 15, 1992, letter we requested, and you granted, a suspension of fire protection water flow testing in order to preclude zebra mussel infestation. The purpose of the suspension was to isolate that portion of the fire protection system piping that would be used by the new water supply system being constructed, thereby precluding zebra mussel intrusion if possible. The isolation point was downstream of the (old) fire protection system pumps, which were subjected to continued surveillance testing, and which did in fact become contaminated.

We believe our recent inspection results, which revealed no zebra mussel contamination in the isolated fire protection system piping, indicates the success of our combined efforts. We believe any shells, or remaining pieces thereof, if they existed, would have been flushed out of the isolated piping with clean water after the new water supply system was installed and operationally tested.

Sincerely,

A handwritten signature in cursive script, appearing to read 'E. E. Fitzpatrick'.

E. E. Fitzpatrick
Vice President

dr
210050

9310210186 931012
PDR ADDCK 05000315
G PDR

A006
110

Dr. T. E. Murley

- 2 -

AEP:NRC:0692CQ

cc: A. A. Blind
G. Charnoff
J. B. Martin - Region III
NFEM Section Chief
NRC Resident Inspector
J. R. Padgett

