

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9405240214 DOC. DATE: 94/05/18 NOTARIZED: NO DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Withdraws request for TS change re SG tube plugging
 criteria.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD3-1 LA		1	1		PD3-1 PD		1	1
	HICKMAN, J		2	2					
INTERNAL:	NRR/DE/EELB		1	1		NRR/DORS/OTSB		1	1
	NRR/DRCH/HICB		1	1		NRR/DRPW		1	1
	NRR/DSSA/SPLB		1	1		NRR/DSSA/SRXB		1	1
	NUDOCS-ABSTRACT		1	1		OC/LFDCB		1	1
	OGC/HDS2		1	0		<u>REG FTEE</u> 01		1	1
EXTERNAL:	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 16 ENCL 14 0

R
I
D
S
/
A
D
D
S
/
A
D
D
S

AA-4



AEP:NRC:1166P

Donald C. Cook Nuclear Plant Unit 1
Docket No. 50-315
License No. DPR-58
TECHNICAL SPECIFICATION CHANGE WITHDRAWAL
UNIT 1 STEAM GENERATOR ALTERNATE PLUGGING CRITERIA

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Attn: Mr. W. T. Russell

May 18, 1994

Dear Mr. Russell:

We hereby withdraw our request for a technical specification (T/S) change to Cook Nuclear Plant Unit 1 Steam Generator Tube Plugging criteria, submitted in our letter AEP:NRC:1166 dated March 20, 1991. This T/S change request proposed, beginning with Unit 1 Cycle 13, a 4-volt bobbin coil alternate plugging criterion that we are confident would assure continued safe operation of the Unit 1 steam generators. We subsequently requested and have received interim Unit 1 steam generator tube plugging criteria for both Cycles 13 and 14.

A separate T/S change request for steam generator tube plugging criteria, applicable beyond Cycle 14, will be submitted in the future. Such a request may incorporate either interim plugging criteria or alternate plugging criteria, depending upon the nature and availability of accepted industry standards at that time.

Sincerely,

W. J. Smith
for E. E. Fitzpatrick
Vice President

dr

cc: A. A. Blind
G. Charnoff
J. B. Martin - Region III
NFEM Section Chief
NRC Resident Inspector
J. R. Padgett

230053

9405240214 940518
PDR ADDCK 05000315
PDR

ADD 1/0