

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

RECEPTION NBR: 9411010334 DOC. DATE: 94/10/28 NOTARIZED: YES DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Document Control Branch (Document Control Desk)

SUBJECT: Advises that installation of permanent design change will be deferred because affected equipment & areas are not accessible at power for necessary pre-design walkdowns & work plan development.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: 315/4-4

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD3-1 PD	1 1	HICKMAN, J	1 1
INTERNAL: AEOD/DEIB	1 1	AEOD/SPD/RAB	1 1
AEOD/SPD/RRAB	1 1	AEOD/TTC	1 1
DEDRO	1 1	FILE CENTER 02	1 1
NRR/DORS/OEAB	1 1	NRR/DRCH/HHFB	1 1
NRR/PMAS/IRCB-E	1 1	NUDOCS-ABSTRACT	1 1
OE DIR	1 1	OGC/HDS2	1 1
RES/HFB	1 1	RGN3 FILE 01	1 1
INTERNAL: LITCO BRYCE, J H	1 1	NOAC	1 1
NRC PDR	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 19 ENCL 19 2

P
R
I
O
R
I
T
Y

1

D
O
C
U
M
E
N
T



AEP:NRC:1212A2

Donald C. Cook Nuclear Plant Unit 1
Docket No. 50-315
License No. DPR-58
REVISION TO COMMITMENT MADE IN
RESPONSE TO NOTICE OF VIOLATION IN
NRC INSPECTION REPORT NO. 50-315/94004(DRP)

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Attn: Mr. J. B. Martin

October 28, 1994

Dear Mr. Martin:

References

- (1) NRC Inspection Report No. 50-315/94004(DRP), which contained a Notice of Violation with regard to the activities that contributed to the reactor coolant level perturbations experienced during the draining of the Unit 1 reactor coolant system from February 16 through 18, 1994
- (2) Our response to Reference 1, Letter No. AEP:NRC:1212A, dated May 2, 1994, pp. 8-9 of the Attachment

In Reference 2, we committed to install a permanent design change to address Violation III in Reference 1 with regard to mid-loop reactor vessel level indication. We scheduled the installation of the permanent design change to occur during the next refueling outage of Donald C. Cook Nuclear Plant Unit 1 (presently scheduled for September 1995), and during the following refueling outage of Cook Nuclear Plant Unit 2 (presently scheduled for February 1996).

We are deferring the installation of this permanent design change on Unit 1 until the subsequent Unit 1 refueling outage, presently scheduled for January 1997. No change is being made to the schedule for Unit 2. The reason for the change in schedule for this modification on Unit 1 is that the affected equipment and areas are not accessible at power for necessary pre-design walkdowns and work plan development prior to outage start, necessitating that these essential preparation activities be part

IE 01
110



Mr. J. B. Martin

- 2 -

AEP:NRC:1212A2

of the sequence of operations to take place very early in the outage, with the potential for adverse effects on the outage schedule. Because the "temporary" reactor vessel mid-loop level transmitter that was used during this year's Unit 2 refueling outage was used with excellent results, and because we expect to see continued excellent results using the "temporary" transmitter until the permanent design change can be installed, deferral of the design change on Unit 1 was determined to be appropriate.

This letter is submitted pursuant to 10 CFR 50.54(f) and, as such, an oath statement is attached.

Sincerely,



E. E. Fitzpatrick
Vice President

ar

Attachment

cc: A. A. Blind
G. Charnoff
NFEM Section Chief
NRC Resident Inspector - Bridgman, MI
NRC Resident Inspector - Big Rock Point Nuclear Plant
J. R. Padgett
W. T. Russell, NRC - Washington, D.C.



STATE OF OHIO)
COUNTY OF FRANKLIN)

E. E. Fitzpatrick, being duly sworn, deposes and says that he is the Vice President of licensee Indiana Michigan Power Company, that he has read the foregoing REVISION TO COMMITMENT MADE IN RESPONSE TO NOTICE OF VIOLATION IN NRC INSPECTION REPORT NO. 50-315/94004(DRP) and knows the contents thereof; and that said contents are true to the best of his knowledge and belief.

E. E. Fitzpatrick

Subscribed and sworn to before me this 22nd
day of October, 19 94.

Rita D. Hill
NOTARY PUBLIC

RITA D. HILL
NOTARY PUBLIC, STATE OF OHIO
MY COMMISSION EXPIRES 6-28-99

