

ATTACHMENT 1 TO AEP:NRC:0980V
ADDITIONAL TECHNICAL SPECIFICATION PAGES
MARKED TO REFLECT PROPOSED CHANGE

9411300097 941118
PDR ADCK 05000315
P PDR

ADMINISTRATIVE CONTROLS

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those facility components identified in ~~Table 5.9.1~~ *the Updated Final Safety Analysis Report*.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the Plant Staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or review of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PNSRC and the NSDRC.
- l. Records of radioactive shipments.
- m. Records of the service lives of hydraulic snubbers including the date at which service life commences and associated installation and maintenance records.

6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is 1000 mrem/hr or less shall be barricaded and .

ADMINISTRATIVE CONTROLS

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those facility components identified in ~~Table 5.7-1~~ *the updated final Safety Analysis Report*.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the Plant Staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or review of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PNSRC and the NSDRG.
- l. Records of radioactive shipments.
- m. Records of the service lives of hydraulic snubbers including the date at which service life commences and associated installation and maintenance records.

6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is 1000 mrem/hr or less shall be barricaded and

ATTACHMENT 2 TO AEP:NRC:0980V
ADDITIONAL PROPOSED REVISED T/S PAGES

ADMINISTRATIVE CONTROLS

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those facility components identified in the Updated Final Safety Analysis Report.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the Plant Staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or review of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PNSRC and the NSDRG.
- l. Records of radioactive shipments.
- m. Records of the service lives of hydraulic snubbers including the date at which service life commences and associated installation and maintenance records.

6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is 1000 mrem/hr or less shall be barricaded and

ADMINISTRATIVE CONTROLS

6.10.2 The following records shall be retained for the duration of the Facility Operating License:

- a. Records and drawing changes reflecting unit design modifications made to systems and equipment described in the Final Safety Analysis Report.
- b. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
- c. Records of radiation exposure for all individuals entering radiation control areas.
- d. Records of gaseous and liquid radioactive material released to the environs.
- e. Records of transient or operational cycles for those facility components identified in the Updated Final Safety Analysis Report.
- f. Records of reactor tests and experiments.
- g. Records of training and qualification for current members of the Plant Staff.
- h. Records of in-service inspections performed pursuant to these Technical Specifications.
- i. Records of Quality Assurance activities required by the QA Manual.
- j. Records of reviews performed for changes made to procedures or equipment or review of tests and experiments pursuant to 10 CFR 50.59.
- k. Records of meetings of the PNSRC and the NSDRG.
- l. Records of radioactive shipments.
- m. Records of the service lives of hydraulic snubbers including the date at which service life commences and associated installation and maintenance records.

6.11 RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared consistent with the requirements of 10 CFR Part 20 and shall be approved, maintained and adhered to for all operations involving personnel radiation exposure.

6.12 HIGH RADIATION AREA

6.12.1 In lieu of the "control device" or "alarm signal" required by paragraph 20.203(c)(2) of 10 CFR 20, each high radiation area in which the intensity of radiation is 1000 mrem/hr or less shall be barricaded and