

# PRIORITY 1

(ACCELERATED RIDS PROCESSING)

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9411300355      DOC. DATE: 94/11/18      NOTARIZED: YES      DOCKET #  
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315  
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316  
 AUTH. NAME      AUTHOR AFFILIATION  
 FITZPATRICK, E.      Indiana Michigan Power Co. (formerly Indiana & Michigan Ele  
 RECIP. NAME      RECIPIENT AFFILIATION  
 RUSSELL, W.T.      Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to licenses DPR-58 & DPR-74 to TS re  
 change request on in-service insp requirements.

DISTRIBUTION CODE: A047D      COPIES RECEIVED: LTR 1 ENCL 1 / SIZE: 3 + 10  
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD3-1 LA	1 0	PD3-1 PD	1 1
	HICKMAN, J	2 2		
INTERNAL:	AEOD/SPD/RAB	1 1	<u>FILE CENTER 0.1</u>	1 1
	NRR/DE/EMCB	1 1	NRR/DE/EMEB	1 1
	NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
	RES/DSIR/EIB	1 1		
EXTERNAL:	LITCO BROWN, B	1 1	LITCO RANSOME, C	1 1
	NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL  
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM  
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 15 ENCL 13

P  
R  
I  
O  
R  
I  
T  
Y  
  
1  
  
D  
O  
C  
U  
M  
E  
N  
T





AEP:NRC:0730K

Donald C. Cook Nuclear Plant Units 1 and 2  
Docket Nos. 50-315 and 50-316  
License Nos. DPR-58 and DPR-74  
TECHNICAL SPECIFICATION CHANGE REQUEST ON  
IN-SERVICE INSPECTION REQUIREMENTS

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Attn: W. T. Russell

November 18, 1994

Dear Mr. Russell:

This letter and its attachments constitute an application for amendment to the Technical Specifications (T/Ss) for the Donald C. Cook Nuclear Plant Units 1 and 2. Specifically, we propose to modify Technical Specification 4.0.5.a for both Units 1 and 2. This change to the T/Ss was suggested in a draft version of NUREG-1482, "Guidelines for Inservice Testing at Nuclear Power Plants," and the proposed wording has been adopted in the currently approved version of the Standardized Technical Specifications (NUREG-1431). If approved, the proposed change will allow us to implement a 10 CFR 50.55a(f)(5)(iii) relief request prior to obtaining written relief from the NRC. This position is in accord with 10 CFR 50.55a which does not require that relief requests be approved before they are implemented.

Attachment 1 provides a detailed description of the proposed change, justification for the change, and our proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92. Attachment 2 contains the existing T/S pages marked to reflect the proposed change. Attachment 3 contains the affected T/S pages with the proposed change incorporated.

We believe that the proposed change will not result in (1) a significant change in the types of any effluent that may be released off site, or (2) a significant increase in individual or cumulative occupational radiation exposure.

9411300355 941118  
PDR ADDOCK 05000315  
P PDR

AD47



Mr. W. T. Russell

-2-

AEP:NRC:0703K

This proposed change has been reviewed by the Plant Nuclear Safety Review Committee and the Nuclear Safety and Design Review Committee.

This T/S change will be of most benefit if approved prior to implementation of our third ten year In-service Inspection Plan, scheduled for July 1996.

In compliance with the requirements of 10 CFR 50.91(b)(1), copies of this letter and its attachments have been transmitted to the Michigan Public Service Commission and the Michigan Department of Public Health.

This letter is submitted pursuant to 10 CFR 50.30(b) and, as such, an oath statement is attached.

Sincerely,



E. E. Fitzpatrick  
Vice President

eh

Attachments

cc: A. A. Blind  
G. Charnoff  
J. B. Martin - Region III  
NFEM Section Chief  
NRC Resident Inspector - Bridgman  
J. R. Padgett

STATE OF OHIO)  
COUNTY OF FRANKLIN)

E. E. Fitzpatrick, being duly sworn, deposes and says that he is the Vice President of licensee Indiana Michigan Power Company, that he has read the foregoing TECHNICAL SPECIFICATION CHANGE REQUEST ON INSERVICE INSPECTION REQUIREMENTS, and knows the contents thereof; and that said contents are true to the best of his knowledge and belief.

E E Fitzpatrick

Subscribed and sworn to before me this 18<sup>th</sup>

day of November, 19 94.

Rita D Hill  
NOTARY PUBLIC

RITA D. HILL  
NOTARY PUBLIC, STATE OF OHIO  
MY COMMISSION EXPIRES 6-28-99