

ATTACHMENT 1 TO AEP:NRG:1182A

MARKED-UP

TECHNICAL SPECIFICATION PAGES

9502150154 950210
PDR ADOCK 05000315
P PDR

REACTIVITY CONTROL SYSTEMS

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

GROUP HEIGHT

LIMITING CONDITION FOR OPERATION

{ with all individual indicated rod positions
within the allowed rod misalignment }

3.1.3.1 All full length (shutdown and control) rods shall be OPERABLE and positioned within ~~± 12 steps (indicated position)~~ of their group step counter demand position as follows:

[insert attached text]

APPLICABILITY: MODES 1* and 2*

ACTION:

- a. With one or more full length rods inoperable due to being immovable as a result of excessive friction or mechanical interference or known to be untrippable, determine that the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied within 1 hour and be in HOT STANDBY within 6 hours.
- b. With more than one full length rod inoperable or misaligned from the group step counter demand position by more than ~~± 12 steps~~ the ~~(indicated position)~~, be in HOT STANDBY within 6 hours.
allowed rod misalignment,
- c. With one full length rod inoperable due to causes other than addressed by ACTION a, above, or misaligned from its group step counter demand position by more than ~~± 12 steps (indicated position)~~ the allowed rod misalignment, POWER OPERATION may continue provided that within one hour either:
 1. The affected rod is restored to OPERABLE status within the above alignment requirements, or THERMAL POWER level is reduced to less than or equal to 85% RATED THERMAL POWER for rod misalignments less than or equal to ± 18 steps,
 2. The affected rod is declared inoperable and the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied. POWER OPERATION may then continue provided that:
 - a) A reevaluation of each accident analysis of Table 3.1-1 is performed within 5 days; this reevaluation shall confirm that the previously analyzed results of these accidents remain valid for the duration of operation under these conditions, and
 - b) The SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is determined at least once per 12 hours, and

move to page 3/4 1-19

*See Special Test Exceptions 3.10.2 and 3.10.4

- o for THERMAL POWER less than or equal to 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 18 steps, and
- o for THERMAL POWER greater than 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 12 steps or as determined from Figure 3.1-4. Figure 3.1-4 permits ~~for~~ an allowed rod misalignment from ± 13 steps (for APL equal to 101%) to ± 18 steps (for APL greater or equal to 106%) provided the value of R (defined in Figure 3.1-4) is greater than or equal to 1.04.

REACTIVITY CONTROL SYSTEMS

3/4.1.3 MOVABLE CONTROL ASSEMBLIES.

GROUP HEIGHT

{with all individual indicated rod positions
within the allowed rod misalignment}

LIMITING CONDITION FOR OPERATION

3.1.3.1 All full length (shutdown and control) rods shall be OPERABLE and positioned within ~~±12 steps (indicated position)~~ of their group step counter demand position *as follows.*

[insert attached text]

APPLICABILITY: MODES 1* and 2*

ACTION:

- a. With one or more full length rods inoperable due to being immovable as a result of excessive friction or mechanical interference or known to be untrippable, determine that the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied within 1 hour and be in HOT STANDBY within 6 hours.
- b. With more than one full length rod inoperable or misaligned from the group step counter demand position by more than ~~±12 steps~~ *the (indicated position)* be in HOT STANDBY within 6 hours.
allowed rod misalignment
- c. With one full length rod inoperable due to causes other than addressed by ACTION a, above, or misaligned from its group step counter demand position by more than ~~±12 steps (indicated position)~~ *the allowed rod misalignment* POWER OPERATION may continue provided that within one hour either:
 1. The affected rod is restored to OPERABLE status within the above alignment requirements, or *THERMAL POWER level is reduced to less than or equal to 85% RATED THERMAL POWER for rod misalignments less than or equal to ±18 steps*
 2. The affected rod is declared inoperable and the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied. POWER OPERATION may then continue provided that:
 - a) A reevaluation of each accident analysis of Table 3.1-1 is performed within 5 days; this reevaluation shall confirm that the previously analyzed results of these accidents remain valid for the duration of operation under these conditions, and
 - b) The SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is determined at least once per 12 hours, and

MOVE TO PAGE 3/4 1-19

*See Special Test Exceptions 3.10.2 and 3.10.3

- for THERMAL POWER less than or equal to 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 18 steps, and
- for THERMAL POWER greater than 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 12 steps or as determined from Figure 3.1-4. Figure 3.1-4 permits ~~54~~ an allowed rod misalignment from ± 13 steps (for APL equal to 101%) to ± 18 steps (for APL greater or equal to 106%) provided the value of R (defined in Figure 3.1-4) is greater than or equal to 1.04.

ATTACHMENT 2 TO AEP:NRC:1182A
PROPOSED TECHNICAL SPECIFICATION PAGES

REACTIVITY CONTROL SYSTEMS

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

GROUP HEIGHT

LIMITING CONDITION FOR OPERATION

3.1.3.1 All full length (shutdown and control) rods shall be OPERABLE with all individual indicated rod positions within the allowed rod misalignment of their group step counter demand position as follows:

- for THERMAL POWER less than or equal to 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 18 steps, and
- for THERMAL POWER greater than 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 12 steps or as determined from Figure 3.1-4. Figure 3.1-4 permits an allowed rod misalignment from ± 13 steps (for APL equal to 101%) to ± 18 steps (for APL greater or equal to 106%) provided the value of R (defined in Figure 3.1-4) is greater than or equal to 1.04.

APPLICABILITY: MODES 1* and 2*

ACTION:

- a. With one or more full length rods inoperable due to being immovable as a result of excessive friction or mechanical interference or known to be untrippable, determine that the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied within 1 hour and be in HOT STANDBY within 6 hours.
- b. With more than one full length rod inoperable or misaligned from the group step counter demand position by more than the allowed rod misalignment, be in HOT STANDBY within 6 hours.
- c. With one full length rod inoperable due to causes other than addressed by ACTION a, above, or misaligned from its group step counter demand position by more than the allowed rod misalignment, POWER OPERATION may continue provided that within one hour either:
 1. The affected rod is restored to OPERABLE status within the above alignment requirements, or THERMAL POWER level is reduced to less than or equal to 85% of RATED THERMAL POWER for rod misalignments less than or equal to ± 18 steps, or
 2. The affected rod is declared inoperable and the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied. POWER OPERATION may then continue provided that:
 - a) A reevaluation of each accident analysis of Table 3.1-1 is performed within 5 days; this reevaluation shall confirm that the previously analyzed results of these accidents remain valid for the duration of operation under these conditions, and

*See Special Test Exceptions 3.10.2 and 3.10.4

REACTIVITY CONTROL SYSTEMS

3/4.1.3 MOVABLE CONTROL ASSEMBLIES

GROUP HEIGHT

LIMITING CONDITION FOR OPERATION

3.1.3.1 All full length (shutdown and control) rods shall be OPERABLE with all individual indicated rod positions within the allowed rod misalignment of their group step counter demand position as follows:

- for THERMAL POWER less than or equal to 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 18 steps, and
- for THERMAL POWER greater than 85% of RATED THERMAL POWER, the allowed rod misalignment is ± 12 steps or as determined from Figure 3.1-4. Figure 3.1-4 permits an allowed rod misalignment from ± 13 steps (for APL equal to 101%) to ± 18 steps (for APL greater or equal to 106%) provided the value of R (defined in Figure 3.1-4) is greater than or equal to 1.04.

APPLICABILITY: MODES 1* and 2*

ACTION:

- a. With one or more full length rods inoperable due to being immovable as a result of excessive friction or mechanical interference or known to be untrippable, determine that the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied within 1 hour and be in HOT STANDBY within 6 hours.
- b. With more than one full length rod inoperable or misaligned from the group step counter demand position by more than the allowed rod misalignment, be in HOT STANDBY within 6 hours.
- c. With one full length rod inoperable due to causes other than addressed by ACTION a, above, or misaligned from its group step counter demand position by more than the allowed rod misalignment, POWER OPERATION may continue provided that within one hour either:
 1. The affected rod is restored to OPERABLE status within the above alignment requirements, or THERMAL POWER level is reduced to less than or equal to 85% of RATED THERMAL POWER for rod misalignments less than or equal to ± 18 steps, or
 2. The affected rod is declared inoperable and the SHUTDOWN MARGIN requirement of Specification 3.1.1.1 is satisfied. POWER OPERATION may then continue provided that:
 - a) A reevaluation of each accident analysis of Table 3.1-1 is performed within 5 days; this reevaluation shall confirm that the previously analyzed results of these accidents remain valid for the duration of operation under these conditions, and

*See Special Test Exceptions 3.10.2 and 3.10.3