

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9503080168 DOC. DATE: 95/02/28 NOTARIZED: YES DOCKET #
 FACIL: 50-315 Donald C. Cook Nuclear Power Plant, Unit 1, Indiana M 05000315
 50-316 Donald C. Cook Nuclear Power Plant, Unit 2, Indiana M 05000316
 AUTH. NAME AUTHOR AFFILIATION
 FITZPATRICK, E. Indiana Michigan Power Co. (formerly Indiana & Michigan Ele
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards proposed TS, revising train A/B battery profiles &
 modifying train N batteries profile request for mod.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2 + 36
 TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD3-1 LA	1 1	PD3-1 PD	1 1
HICKMAN, J	1 1		
INTERNAL: <u>FILE CENTER</u> 01	1 1	NRR/DRCH/HICB	1 1
NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
EXTERNAL: NOAC	1 1	NRC PDR	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL
 DESK, ROOM P1-37 (EXT. 504-2083) TO ELIMINATE YOUR NAME FROM
 DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 11 ENCL 10



February 28, 1995

AEP:NRC:0896U

Docket Nos.: 50-315
50-316

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

Donald C. Cook Nuclear Plant Units 1 and 2
TECHNICAL SPECIFICATION CHANGE REQUEST:
REVISE THE TRAIN A/B BATTERY PROFILES
AND MODIFY TRAIN N BATTERIES' PROFILE
REQUEST FOR MODIFICATION

The purpose of this letter is to modify our AEP:NRC:0896S letter, same subject, dated July 19, 1994, as requested by the NRR staff. In a January 13, 1995, telephone conference the NRR reviewing engineer requested that we adopt the language of the latest revision to IEEE Standard 450 with regard to the modified performance test and degraded performance test recommendations. To satisfy his request, paragraph "e" on pages 3/4 8-14 and 3/4 8-18 for the Donald C. Cook Nuclear Plant Units 1 and 2 technical specifications respectively should read as follows.

"At least once per 60 months, conduct a performance test of battery capacity during shutdown (MODES 5 or 6), by verifying that the battery capacity is at least 80% of the manufacturer's rating. When this test is performed in place of a battery service test, a modified performance test shall be conducted.

Annual performance tests of battery capacity shall be given to any battery that shows signs of degradation or has reached 85% of the service life expected for the application. Degradation is indicated when the battery capacity drops more than 10% from its capacity on the previous performance test, or is below 90% of the manufacturer's rating. If the battery has reached 85% of service life, delivers a capacity of 100% or greater of the manufacturer's rated capacity, and has shown no signs of degradation, performance testing at two year intervals is acceptable until the battery shows signs of degradation."

070093.

9503080168 950228
PDR ADCK 05000315
P PDR

A001
11

The battery surveillance requirements have been modified to reflect the comments as requested. For your convenience, a copy of the existing T/Ss, marked to reflect all the changes, is included as Attachment 1. Attachment 2 is a typed copy of the T/Ss, as they should appear, with bar margins indicating the changes. Please note the new format we are implementing to allow electronic access to the T/Ss. With the new format there are pagination changes and minor administrative changes to Table 4.8-2 in both units in an ongoing effort to achieve uniformity between the units.


We have reviewed the staff's requested changes and believe the significant hazards consideration performed pursuant to 10 CFR 50.92 for the original submittal is valid. Therefore, we have not provided further justification for the changes requested by the NRR staff.

We believe the proposed additional changes will not result in (1) a significant change in the types of effluent or a significant increase in the amount of any effluent that may be released offsite, or (2) a significant increase in individual or cumulative occupational radiation exposure.

These proposed T/S changes have been reviewed and approved by the Plant Nuclear Safety Review Committee and will be approved by the Nuclear Safety and Design Review Committee at the next regularly scheduled meeting.

In compliance with the requirements of 10 CFR 50.91(b)(1), copies of this letter and its attachments have been transmitted to Mr. J. R. Padgett of the Michigan Public Service Commission and the Michigan Department of Public Health.

Sincerely,



E. E. Fitzpatrick

E. E. Fitzpatrick
Vice President

eh

Attachment

cc: A. A. Blind
G. Charnoff
J. B. Martin
NFEM Section Chief
NRC Resident Inspector - Bridgman
J. R. Padgett

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 28th DAY OF February 1995

John A. Hice

Notary Public

My Commission Expires: 6-28-99

