

0 0 1 0 0 0 1 0 0 5 0

PLG-0913

CALCULATION OF X/Q VALUES FOR THE CONTROL ROOM INTAKES

Prepared for
D.C. COOK PLANT

by
PLG, INC.

February 1993

9504140308 950407
PDR ADDCK 05000315
P PDR

7479A022293

0 0 1 0 0 5 0 0 0 5 2

TABLE OF CONTENTS

	<u>Page</u>
1.0 Introduction and Summary	1
2.0 Background	1
3.0 Input Data	1
4.0 Calculation of X/Q Values	2
5.0 ~5% Probable X/Q Results	3
Attachment A Estimation of Concentration Coefficients at the Control Room Intakes for Diffuse Releases from the Unit 1 and Unit 2 Containment Structures at the Donald C. Cook Nuclear Plant	A-1

LIST OF TABLES

	<u>Page</u>
Table 1 5% Probable Control Room Intake X/Q Values for the Cook Nuclear Plant	4
Table 2 Joint Frequency Tables of Wind Speed and Direction Versus Stability Category from the Cook Meteorological Tower for the Period of January 1, 1989 Through December 31, 1991	5
Table 3 Cumulative X/Q Values at Unit 1 Control Room Intake Based on Unit 1 Release	13
Table 2 Cumulative X/Q Values at Unit 1 Control Room Intake Based on Unit 2 Release	14
Table 3 Cumulative X/Q Values at Unit 2 Control Room Intake Based on Unit 1 Release	15
Table 4 Cumulative X/Q Values at Unit 2 Control Room Intake Based on Unit 2 Release	16

LIST OF FIGURES

	<u>Page</u>
Figure 1 Cumulative Plots of Direction Independent X/Q Values at Unit 1 Control Room Intake Based on Unit 1 Release	17
Figure 2 Cumulative Plots of Direction Independent X/Q Values at Unit 1 Control Room Intake Based on Unit 2 Release	18
Figure 3 Cumulative Plots of Direction Independent X/Q Values at Unit 2 Control Room Intake Based on Unit 1 Release	19
Figure 4 Cumulative Plots of Direction Independent X/Q Values at Unit 2 Control Room Intake Based on Unit 2 Release	20



1. The first part of the document is a list of names and addresses of the members of the committee.



CALCULATION OF X/Q VALUES FOR THE CONTROL ROOM INTAKES

1.0 INTRODUCTION AND SUMMARY

The purpose of this study was to calculate the 5% probable dispersion coefficients (X/Q) at the D.C. Cook plant control room intakes due to containment leakage after an accident. Four release-receptor combinations were evaluated for each of the 16 wind directions. Releases from both containment structures were evaluated and concentrations at each of the control room intakes were determined.

The study involved two major efforts. First, Dr. James Halitsky prepared estimates of direction-dependent concentration coefficients ($K_{c,avg}$) that are used along with wind speed to determine dilution due to turbulence around the plant structures. Dr. Halitsky's report is included as Attachment A. In this effort, Dr. Halitsky actually built a scale model of the plant to serve as a basis for his estimates. Dr. Halitsky is a well-known aerodynamicist who has worked with wind tunnels and has participated in field studies for many years. Use of generic factors is not appropriate for the Cook Plant due to the complex geometry of the plant structures involved. Second, values of X/Q were calculated for each weather category using site specific joint frequency weather data combined with the concentration coefficients.

The X/Q values were then rank ordered and summed to determine the 5% probable X/Q value for each release-receptor combination.

The maximum 5% X/Q value was $7.85E-4$ (sec/m³). Results for all combinations are given in Table 1.

2.0 BACKGROUND

During the design review in the licensing process, the U.S. NRC evaluates control room doses following an accident. This requires estimation of the dispersion (expressed as values of X/Q) that occurs as radionuclides released from the containment travel to the control room intake. Established NRC guidelines suggest that a conservative dispersion value should be used, such that concentrations at the intakes would not be exceeded more than 5% of the time. This is defined as the 5% probable X/Q value. Once the dilution factor is known, dose calculations to control room occupants can be made. The X/Q values computed in this study are appropriate for the first 8 hours following an accident. Values for longer time periods would be lower.

3.0 INPUT DATA

This study required use of two types of site/plant specific data as discussed below:

3.1 Meteorology

A 60m meteorological tower instrumented at two levels is in continuous operation at the plant site. For this report, joint frequency tables were generated for a 3-year period of record from January 1989 through

December 1991. Wind speed and direction measurements from the 33 ft level and delta temperature between 197 and 33 ft were used. The data recovery averaged better than 98% over the three year period. The concentration coefficients ($K_{c,avg}$) provided by Dr. Halitsky were to be used with wind speeds at the average plant structure height of 60 ft. Therefore, the wind speed taken from the 33 ft level was adjusted to 60 ft. Table 2 provides all seven joint frequency tables followed by a "totals" table for all stabilities.

3.2 Plant Parameters

The physical characteristics of the site were taken from drawings provided by AEP as shown in Figure 1 of Attachment A. The heights in Figure 1 are approximate as derived from the drawings. A scale model of the plant was constructed and used to visualize the plant complex. A simplified tracer study was run by Dr. Halitsky using the model to assist in visualizing the effect of the building cavities.

The plant grade averaged about 608 ft above sea level. The average release height of 60 ft above grade was used for all calculations. This height was about midway between plant grade of 608 ft and the top of the containment at about 720 ft. The reference area of the containment used in all calculations was 1685m².

4.0 CALCULATION OF 5% X/Q VALUES

An EXCEL® spreadsheet was developed to compute the X/Q values for each of the control room intakes given a diffuse release at either of the containments at the D.C. Cook Nuclear Plant. The X/Q values were computed using K-factors provided by Dr. James Halitsky as described in Attachment A. When the user selects a particular combination of source unit and control room intake, the X/Q value for each combination of direction, wind speed, and stability is computed and tabulated using:

$$X/Q = K_{c,avg}/u_{60}^A \quad (1)$$

where $K_{c,avg}$ is the Halitsky K-factor, u_{60} is the wind speed (m/s) at 60 ft (the average elevation of the complex above grade) and A is the reference area (m²) of the containment. The wind speed is adjusted for elevation using:

$$u_{60} = (60/h_m)^n \quad (2)$$

where the exponent n is 0.25 for unstable conditions (Pasquill-Gifford A, B, and C stability), 0.33 for neutral conditions (D stability), and 0.50 for stable conditions (E, F, G stability), and where h_m is the measurement height (33 ft) of the meteorological data. A total of sixteen directions, six wind speeds and seven stability classes were used. Each wind speed category in the joint frequency tables was assigned a wind speed approximating the average speed in the category.

The assumed wind speed in each joint frequency speed category (33 ft level) was as follows:

<u>Wind Speed Category</u>	<u>Assumed Average Speed (mph)</u>
1-3	2.00
4-7	5.50
8-12	10.00
13-18	15.50
19-24	21.25
25 +	27.00

5.0 5% PROBABLE X/Q RESULTS

The resulting table of X/Q values, their corresponding meteorological conditions and the frequency of these meteorological conditions, is sorted in order of descending X/Q. The cumulative frequency is then computed, and the desired X/Q value is the largest one for which the cumulative frequency exceeds 5%. Tables 1 through 4 provide numerical values of X/Q and their frequencies for the highest 5% of the categories in the joint frequency weather tables. Complementary cumulative distribution functions for all X/Q values and all release-receptor combinations are computed and plotted as shown in Figures 1 through 4.

0 0 1 0 0 0 1 0 0 5 7

TABLE 1. 5% PROBABLE CONTROL ROOM INTAKE X/Q VALUES
FOR THE COOK NUCLEAR PLANT

Release from	Unit 1	Unit 1	Unit 2	Unit 2
Receptor at	Intake 1	Intake 2	Intake 1	Intake 2
X/Q Value (sec/m ³)	7.85E-4	2.45E-4	3.43E-4	7.07E-4

0 0 1 0 0 0 1 0 0 5 8

TABLE 2. JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
VERSUS STABILITY CATEGORY FROM THE COOK
METEOROLOGICAL TOWER FOR THE PERIOD OF
JANUARY 1, 1989 THROUGH DECEMBER 31, 1991

00 000 000000

0 0 1 0 0 0 1 0 0 5 7

TABLE 2. JOINT FREQUENCY TABLE OF WIND SPEED AND DIRECTION
VERSUS STABILITY CATEGORY FROM THE COOK
METEOROLOGICAL TOWER FOR THE PERIOD OF
JANUARY 1, 1989 THROUGH DECEMBER 31, 1991

Stability Class: A							
Wind Direction	Wind Speed(Mph)						Total
	1-3	4-7	8-12	13-18	19-24	>24	
N	12	261	215	16	0	0	504
NNE	4	21	32	5	0	0	62
NE	8	29	32	8	2	0	79
ENE	3	54	50	9	0	0	116
E	5	63	50	7	0	0	125
ESE	4	83	39	5	0	0	131
SE	5	68	54	2	0	0	129
SSE	16	110	80	13	0	0	219
S	10	87	193	48	2	1	341
SSW	3	23	64	30	2	0	122
SW	6	119	172	28	0	0	325
WSW	9	162	204	32	2	0	409
W	5	194	123	10	3	0	335
WNW	19	210	68	2	1	0	300
NW	24	247	73	1	0	0	345
NNW	17	353	160	5	0	0	535
Total	150	2084	1609	221	12	1	4077

Periods of Calm(Hours) : 0

0 0 1 0 0 0 1 0 0 0 0

TABLE 2 (continued)

Stability Class: B							
Wind Direction	1-3	4-7	8-12	13-18	19-24	>24	Total
N	14	77	54	8	0	0	153
NNE	4	19	18	3	0	0	44
NE	3	36	21	9	3	0	72
ENE	12	31	33	5	0	0	81
E	7	44	32	5	0	0	88
ESE	5	34	19	2	0	0	60
SE	6	40	20	1	0	0	67
SSE	6	23	32	3	1	0	65
S	6	43	66	34	2	0	151
SSW	3	13	43	20	0	0	79
SW	2	55	77	22	0	0	156
WSW	3	76	71	12	2	0	164
W	8	66	47	9	9	0	139
WNW	6	44	30	5	0	0	85
NW	20	43	23	4	0	0	90
NNW	8	89	30	1	0	0	128
Total	113	733	616	143	17	0	1622

Periods of Calm(Hours) : 0

0 0 1 0 0 0 1 0 0 6 1

TABLE 2 (continued)

Stability Class: C							
Wind Direction	Wind Speed(Mph)						Total
	1-3	4-7	8-12	13-18	19-24	>24	
N	13	99	54	16	0	0	182
NNE	7	25	40	3	0	0	75
NE	9	35	28	6	2	0	80
ENE	6	45	29	11	1	0	92
E	10	54	26	8	0	0	98
ESE	8	28	19	5	0	0	60
SE	17	36	18	0	0	0	71
SSE	14	51	30	4	0	0	99
S	5	42	70	28	3	0	148
SSW	3	19	51	36	6	0	115
SW	5	49	79	23	2	0	158
WSW	4	57	61	37	11	0	170
W	6	41	80	23	3	0	153
WNW	6	62	69	17	2	0	156
NW	6	48	42	9	0	0	105
NNW	16	81	54	16	0	0	167
Total	135	772	750	242	30	0	1929

Periods of Calm(Hours) : 0

0 0 1 0 0 5 0 0 0 6 3

0 0 1 0 0 0 1 0 0 6 2

TABLE 2 (continued)

Stability Class: D							
Wind Direction	Wind Speed(Mph)						Total
	1-3	4-7	8-12	13-18	19-24	>24	
N	63	353	195	39	1	0	651
NNE	35	166	108	25	4	0	338
NE	35	170	136	43	5	0	389
ENE	38	150	121	13	4	0	326
E	41	135	111	26	3	0	316
ESE	43	113	105	13	0	0	274
SE	49	129	95	11	0	0	284
SSE	48	146	98	36	0	0	328
S	49	259	343	126	10	2	789
SSW	18	157	401	162	17	2	757
SW	37	147	336	117	10	0	647
WSW	25	134	284	112	13	1	569
W	30	176	294	113	12	0	625
WNW	66	230	329	50	0	0	675
NW	71	255	176	50	0	0	552
NNW	78	360	180	67	3	1	689
Total	726	3080	3312	1003	82	6	8209

Periods of Calm(Hours) : 0

0 0 1 0 0 0 1 0 0 6 3

TABLE 2 (continued)

Stability Class E							
Wind Direction	Wind Speed (Mph)						Total
	1-3	4-7	8-12	13-18	19-24	>24	
N	97	183	58	10	1	1	350
NNE	76	144	35	3	1	0	259
NE	77	139	80	0	0	0	296
ENE	62	170	34	0	0	0	266
E	92	157	56	2	5	0	312
ESE	89	174	34	1	0	0	298
SE	96	179	50	5	0	0	330
SSE	122	225	83	10	2	0	442
S	108	505	294	41	3	0	951
SSW	56	271	270	56	1	0	654
SW	50	178	153	19	0	0	400
WSW	45	125	78	11	2	0	261
W	59	113	56	6	0	0	234
WNW	83	96	26	1	4	0	210
NW	55	58	15	2	0	0	130
NNW	78	110	13	6	0	0	207
Total	1245	2827	1335	173	19	1	5600

Periods of Calm(Hours) : 0

00100010064

TABLE 2 (continued)

Stability Class: F							
Wind Direction	Wind Speed(Mph)						Total
	1-3	4-7	8-12	13-18	19-24	>24	
N	38	17	5	1	0	1	62
NNE	49	10	5	0	0	0	64
NE	86	37	5	1	0	0	129
ENE	110	60	7	8	0	0	185
E	130	68	5	0	0	0	203
ESE	129	57	3	0	0	0	189
SE	106	61	8	0	0	0	175
SSE	188	176	8	0	0	0	372
S	153	260	16	2	0	0	431
SSW	61	77	9	1	0	0	148
SW	37	51	10	0	0	0	98
WSW	15	28	6	3	0	0	52
W	34	16	1	3	0	0	54
WNW	28	16	3	0	0	0	47
NW	36	7	3	0	0	0	46
NNW	26	6	3	0	0	0	35
Total	1226	947	97	19	0	1	2290

Periods of Calm(Hours) : 0

0 0 1 0 0 0 1 0 0 6 5

TABLE 2 (continued)

Stability Class G							
Wind Direction	Wind Speed (mph)						Total
	1-3	4-7	8-12	13-18	19-24	>24	
N	17	4	1	0	0	0	22
NNE	24	2	0	0	0	0	26
NE	65	8	1	0	0	0	74
ENE	155	16	2	0	0	0	173
E	224	28	0	0	0	0	252
ESE	188	9	0	0	0	0	197
SE	255	14	0	0	0	0	269
SSE	345	64	0	0	0	0	409
S	245	94	3	0	0	0	342
SSW	57	34	0	0	0	0	91
SW	28	10	1	0	0	0	39
WSW	25	6	0	0	0	0	31
W	30	2	0	0	0	0	32
WNW	19	5	0	0	0	0	24
NW	20	2	0	0	0	0	22
NNW	21	7	0	0	0	0	28
Total	1718	305	8	0	0	0	2031

Periods of Calm(Hours) : 0

0 0 1 0 0 0 1 0 0 6 6

TABLE 2 (continued)

Stability Class: All							
Wind Direction	Wind Speed(Mph)						Total
	1-3	4-7	8-12	13-18	19-24	>24	
N	254	994	582	90	2	2	1924
NNE	199	387	238	39	5	0	868
NE	283	454	303	67	12	0	1119
ENE	386	526	276	46	5	0	1239
E	509	549	280	48	8	0	1394
ESE	466	498	219	26	0	0	1209
SE	534	527	245	19	0	0	1325
SSE	739	795	331	66	3	0	1934
S	576	1290	985	279	20	3	3153
SSW	201	594	838	305	26	2	1966
SW	165	609	828	209	12	0	1823
WSW	126	588	704	207	30	1	1656
W	172	608	601	164	27	0	1572
WNW	227	663	525	75	7	0	1497
NW	232	660	332	66	0	0	1290
NNW	244	1006	440	95	3	1	1789
Total	5313	10748	7727	1801	160	9	25758

Periods of Calm(Hours) : 0

Hours of Missing Data : 522

0 0 1 0 0 0 1 0 0 6 7

TABLE 3. CUMULATIVE X/Q VALUES AT UNIT 1 CONTROL ROOM INTAKE
BASED ON UNIT 1 RELEASE

All Directions					
Stability Class	Wind Speed	Wind Direction	Chi/Q s/m^3	# of Hours	Cumul. Freq.
G	1.21	ESE	7.853E-4		5.09%
A	1.04	NE	2.112E-3	8	0.03%
B	1.04	NE	2.112E-3	3	0.04%
C	1.04	NE	2.112E-3	9	0.08%
D	1.09	NE	2.012E-3	35	0.21%
E	1.21	NE	1.816E-3	77	0.51%
F	1.21	NE	1.816E-3	86	0.85%
G	1.21	NE	1.816E-3	65	1.10%
A	1.04	WNW	1.027E-3	19	1.17%
A	1.04	NW	1.027E-3	24	1.27%
B	1.04	WNW	1.027E-3	6	1.29%
B	1.04	NW	1.027E-3	20	1.37%
C	1.04	WNW	1.027E-3	6	1.39%
C	1.04	NW	1.027E-3	6	1.41%
D	1.09	WNW	9.790E-4	66	1.67%
D	1.09	NW	9.790E-4	71	1.95%
A	1.04	ESE	9.133E-4	4	1.96%
B	1.04	ESE	9.133E-4	5	1.98%
C	1.04	ESE	9.133E-4	8	2.01%
E	1.21	WNW	8.835E-4	83	2.33%
E	1.21	NW	8.835E-4	55	2.55%
F	1.21	WNW	8.835E-4	28	2.66%
F	1.21	NW	8.835E-4	36	2.80%
G	1.21	WNW	8.835E-4	19	2.87%
G	1.21	NW	8.835E-4	20	2.95%
D	1.09	ESE	8.702E-4	43	3.11%
A	1.04	N	8.562E-4	12	3.16%
B	1.04	N	8.562E-4	14	3.21%
C	1.04	N	8.562E-4	13	3.27%
D	1.09	N	8.158E-4	63	3.51%
E	1.21	ESE	7.853E-4	89	3.86%
F	1.21	ESE	7.853E-4	129	4.36%
G	1.21	ESE	7.853E-4	188	5.09%
A	2.86	NE	7.680E-4	29	5.20%
B	2.86	NE	7.680E-4	36	5.34%
C	2.86	NE	7.680E-4	35	5.47%
A	1.04	NNE	7.420E-4	4	5.49%
A	1.04	SE	7.420E-4	5	5.51%
B	1.04	NNE	7.420E-4	4	5.52%
B	1.04	SE	7.420E-4	6	5.55%
C	1.04	NNE	7.420E-4	7	5.57%
C	1.04	SE	7.420E-4	17	5.64%
E	1.21	N	7.363E-4	97	6.02%
F	1.21	N	7.363E-4	38	6.17%
G	1.21	N	7.363E-4	17	6.23%
D	3.00	NE	7.318E-4	170	6.89%

7479A012993

0 0 1 0 0 5 0 0 0 6 9



0 0 1 0 0 0 1 0 0 5 3

TABLE 4. CUMULATIVE X/Q VALUES AT UNIT 1 CONTROL ROOM INTAKE
BASED ON UNIT 2 RELEASE

All Directions					
Stability Class	Wind Speed	Wind Direction	Chi/Q s/m^3	# of Hours	Cumul. Freq.
E	1.21	N	2.454E-4		5.35%
A	1.04	NE	3.996E-4	8	0.03%
B	1.04	NE	3.996E-4	3	0.04%
C	1.04	NE	3.996E-4	9	0.08%
D	1.09	NE	3.807E-4	35	0.21%
E	1.21	NE	3.436E-4	77	0.51%
F	1.21	NE	3.436E-4	86	0.85%
G	1.21	NE	3.436E-4	65	1.10%
A	1.04	ENE	3.425E-4	3	1.11%
A	1.04	E	3.425E-4	5	1.13%
B	1.04	ENE	3.425E-4	12	1.18%
B	1.04	E	3.425E-4	7	1.20%
C	1.04	ENE	3.425E-4	6	1.23%
C	1.04	E	3.425E-4	10	1.27%
D	1.09	ENE	3.263E-4	38	1.41%
D	1.09	E	3.263E-4	41	1.57%
E	1.21	ENE	2.945E-4	62	1.81%
E	1.21	E	2.945E-4	92	2.17%
F	1.21	ENE	2.945E-4	110	2.60%
F	1.21	E	2.945E-4	130	3.10%
G	1.21	ENE	2.945E-4	155	3.70%
G	1.21	E	2.945E-4	224	4.57%
A	1.04	N	2.854E-4	12	4.62%
B	1.04	N	2.854E-4	14	4.67%
C	1.04	N	2.854E-4	13	4.72%
D	1.09	N	2.719E-4	63	4.97%
E	1.21	N	2.454E-4	97	5.35%
F	1.21	N	2.454E-4	38	5.49%
G	1.21	N	2.454E-4	17	5.56%
A	1.04	NNE	2.283E-4	4	5.57%
A	1.04	ESE	2.283E-4	4	5.59%
B	1.04	NNE	2.283E-4	4	5.61%
B	1.04	ESE	2.283E-4	5	5.63%
C	1.04	NNE	2.283E-4	7	5.65%
C	1.04	ESE	2.283E-4	8	5.68%
D	1.09	NNE	2.176E-4	35	5.82%
D	1.09	ESE	2.176E-4	43	5.99%
E	1.21	NNE	1.963E-4	76	6.28%
E	1.21	ESE	1.963E-4	89	6.63%
F	1.21	NNE	1.963E-4	49	6.82%
F	1.21	ESE	1.963E-4	129	7.32%
G	1.21	NNE	1.963E-4	24	7.41%
G	1.21	ESE	1.963E-4	188	8.14%
A	1.04	SE	1.712E-4	5	8.16%
A	1.04	SSE	1.712E-4	16	8.22%
B	1.04	SE	1.712E-4	6	8.25%

0 0 1 0 0 0 1 0 0 3 9

TABLE 5. CUMULATIVE X/Q VALUES AT UNIT 2 CONTROL ROOM INTAKE
BASED ON UNIT 1 RELEASE

All Directions					
Stability Class	Wind Speed	Wind Direction	Chi/Q s/m ³	# of Hours	Cumul. Freq.
B	1.04	ENE	3.425E-4		5.04%
A	1.04	SE	7.420E-4	5	0.02%
A	1.04	SSE	7.420E-4	16	0.08%
B	1.04	SE	7.420E-4	6	0.10%
B	1.04	SSE	7.420E-4	6	0.13%
C	1.04	SE	7.420E-4	17	0.19%
C	1.04	SSE	7.420E-4	14	0.25%
D	1.09	SE	7.071E-4	49	0.44%
D	1.09	SSE	7.071E-4	48	0.63%
E	1.21	SE	6.381E-4	96	1.00%
E	1.21	SSE	6.381E-4	122	1.47%
F	1.21	SE	6.381E-4	106	1.88%
F	1.21	SSE	6.381E-4	188	2.61%
G	1.21	SE	6.381E-4	255	3.60%
G	1.21	SSE	6.381E-4	345	4.94%
A	1.04	ENE	3.425E-4	3	4.95%
A	1.04	S	3.425E-4	10	4.99%
B	1.04	ENE	3.425E-4	12	5.04%
B	1.04	S	3.425E-4	6	5.06%
C	1.04	ENE	3.425E-4	6	5.09%
C	1.04	S	3.425E-4	5	5.11%
D	1.09	ENE	3.263E-4	38	5.25%
D	1.09	S	3.263E-4	49	5.44%
E	1.21	ENE	2.945E-4	62	5.68%
E	1.21	S	2.945E-4	108	6.10%
F	1.21	ENE	2.945E-4	110	6.53%
F	1.21	S	2.945E-4	153	7.12%
G	1.21	ENE	2.945E-4	155	7.73%
G	1.21	S	2.945E-4	245	8.68%
A	1.04	ESE	2.854E-4	4	8.69%
B	1.04	ESE	2.854E-4	5	8.71%
C	1.04	ESE	2.854E-4	8	8.74%
D	1.09	ESE	2.719E-4	43	8.91%
A	2.86	SE	2.698E-4	68	9.17%
A	2.86	SSE	2.698E-4	110	9.60%
B	2.86	SE	2.698E-4	40	9.76%
B	2.86	SSE	2.698E-4	23	9.85%
C	2.86	SE	2.698E-4	36	9.99%
C	2.86	SSE	2.698E-4	51	10.18%
D	3.00	SE	2.571E-4	129	10.68%
D	3.00	SSE	2.571E-4	146	11.25%
E	1.21	ESE	2.454E-4	89	11.60%
F	1.21	ESE	2.454E-4	129	12.10%
G	1.21	ESE	2.454E-4	188	12.83%
E	3.33	SE	2.320E-4	179	13.52%
E	3.33	SSE	2.320E-4	225	14.40%

7479A012993

0 0 1 0 0 5 0 0 0 7 1


TABLE 6. CUMULATIVE X/Q VALUES AT UNIT 2 CONTROL ROOM INTAKE
BASED ON UNIT 2 RELEASE

All Directions					
Stability Class	Wind Speed	Wind Direction	Chi/Q s/m ³	# of Hours	Cumul. Freq.
D	1.09	ESE	7.071E-4		5.11%
A	1.04	S	1.313E-3	10	0.04%
B	1.04	S	1.313E-3	6	0.06%
C	1.04	S	1.313E-3	5	0.08%
D	1.09	S	1.251E-3	49	0.27%
E	1.21	S	1.129E-3	108	0.69%
F	1.21	S	1.129E-3	153	1.29%
G	1.21	S	1.129E-3	245	2.24%
A	1.04	W	1.027E-3	5	2.26%
B	1.04	W	1.027E-3	8	2.29%
C	1.04	W	1.027E-3	6	2.31%
D	1.09	W	9.790E-4	30	2.43%
A	1.04	E	9.704E-4	5	2.45%
B	1.04	E	9.704E-4	7	2.47%
C	1.04	E	9.704E-4	10	2.51%
D	1.09	E	9.246E-4	41	2.67%
E	1.21	W	8.835E-4	59	2.90%
F	1.21	W	8.835E-4	34	3.03%
G	1.21	W	8.835E-4	30	3.15%
E	1.21	E	8.344E-4	92	3.51%
F	1.21	E	8.344E-4	130	4.01%
G	1.21	E	8.344E-4	224	4.88%
A	1.04	ESE	7.420E-4	4	4.90%
B	1.04	ESE	7.420E-4	5	4.91%
C	1.04	ESE	7.420E-4	8	4.95%
D	1.09	ESE	7.071E-4	43	5.11%
E	1.21	ESE	6.381E-4	89	5.46%
F	1.21	ESE	6.381E-4	129	5.96%
G	1.21	ESE	6.381E-4	188	6.69%
A	1.04	ENE	6.279E-4	3	6.70%
B	1.04	ENE	6.279E-4	12	6.75%
C	1.04	ENE	6.279E-4	6	6.77%
D	1.09	ENE	5.983E-4	38	6.92%
E	1.21	ENE	5.399E-4	62	7.16%
F	1.21	ENE	5.399E-4	110	7.59%
G	1.21	ENE	5.399E-4	155	8.19%
A	1.04	SE	5.137E-4	5	8.21%
B	1.04	SE	5.137E-4	6	8.23%
C	1.04	SE	5.137E-4	17	8.30%
D	1.09	SE	4.895E-4	49	8.49%
A	2.86	S	4.774E-4	87	8.82%
B	2.86	S	4.774E-4	43	8.99%
C	2.86	S	4.774E-4	42	9.15%
D	3.00	S	4.549E-4	259	10.16%
E	1.21	SE	4.418E-4	96	10.53%
F	1.21	SE	4.418E-4	106	10.94%

00100010071

FIGURE 1. CUMULATIVE PLOTS OF DIRECTION INDEPENDENT X/Q VALUES
AT UNIT 1 CONTROL ROOM INTAKE
BASED ON UNIT 1 RELEASE

CCDF for All Directions




7479A012993

00100500073

0 0 1 0 0 0 1 0 0 7 2

FIGURE 2. CUMULATIVE PLOTS OF DIRECTION INDEPENDENT X/Q VALUES
AT UNIT 1 CONTROL ROOM INTAKE
BASED ON UNIT 2 RELEASE




7479A012993

0 0 1 0 0 5 0 0 0 7 4

0 0 1 0 0 0 1 0 0 7 3

FIGURE 3. CUMULATIVE PLOTS OF DIRECTION INDEPENDENT X/Q VALUES
AT UNIT 2 CONTROL ROOM INTAKE
BASED ON UNIT 1 RELEASE

CCDF for All Directions




7479A012993

0 0 1 0 0 9 5 0 0 0 7 5

0.0100010074

FIGURE 4. CUMULATIVE PLOTS OF DIRECTION INDEPENDENT X/Q VALUES
AT UNIT 2 CONTROL ROOM INTAKE
BASED ON UNIT 2 RELEASE

CCDF for All Directions



7479A012993

00100500076
20

0 0 1 0 0 0 1 0 0 7 5

ATTACHMENT A

7479A020193

A-1
0 0 1 0 0 5 0 0 0 7 7

0 0 1 0 0 0 1 0 0 7 6

ESTIMATION OF CONCENTRATION COEFFICIENTS AT THE CONTROL ROOM INTAKES
FOR DIFFUSE RELEASES FROM THE UNITS 1 AND 2 CONTAINMENT STRUCTURES
AT THE DONALD C. COOK NUCLEAR PLANT

Prepared by

James Halitsky, Ph.D.
122 North Highland Place
Croton-on-Hudson, NY 10520

Prepared for

PLG, Inc.
Suite 730
1615 M Street, N.W.
Washington, D.C. 20036

7478A020193

0 0 1 0 0 5 0 0 0 7 8

TABLE OF CONTENTS

	<u>Page</u>
1 Introduction	1
2 Building Arrangements	1
3 Procedure for Estimating $K_{c,avg}$	1
4 Calculation of $K_{c,i}$	3
5 References	3
Table 1 Plume Model for $K_{c,i}$ Determination	4
Table 2 $K_{c,avg}$ Approximation for a Diffuse Leak	5
Figure 1 Donald C. Cook Nuclear Plant	6
Figure 2 Photographs of Scale Model	7
Figure 3 Photographs of Scale Model in Wind Stream	8
Appendix I Estimates of $K_{c,i}$ and $K_{c,avg}$	9

1. Introduction

This report contains a determination of values of the concentration coefficient $K_{c,avg}$ at the Unit 1 and Unit 2 control room intakes of the Donald C. Cook Nuclear Plant for diffuse releases through the Unit 1 and Unit 2 containment building surface.

The $K_{c,avg}$ determinations were made in sixteen conventional wind directions referred to true north. An equation is provided for combining a $K_{c,avg}$ value with a wind velocity at an elevation of 10m on the meteorological tower to obtain a value of the concentration factor X/Q for each of four release-intake combinations.

The $K_{c,avg}$ values were obtained by applying a Gaussian plume model to each of nine point source releases distributed uniformly on the surface of one containment building, converting the predicted X/Q values to K_c values for each release, and averaging the nine K_c values to yield $K_{c,avg}$ for the diffuse release. The Gaussian model included provisions for initial plume enlargement due to entrainment in the direction-specific building cavities, and employed plume expansion rates corresponding to PG-C stability in an adaptation of the Halitsky jet plume model (Reference 1) for short travel distances, as applied to building wake plumes.

2. Building Arrangement

Physical site characteristics were extracted from a set of plans, elevation and vertical section drawings dated 5/1/89, provided by AEP.

Figure 1 shows all significant buildings, roof elevations indicated by numbers within the building outline, and locations of the control room intakes. The topography is flat at elevation 608 ft over most of the plant area, but descends to lake elevation 580 ft, over a distance of about 300 ft in a north-south strip at the west edge of the plant.

A 1:360 scale (1 in equals 30 ft) cardboard model of the plant was constructed as an aid in visualizing the building complex and for use with a visual tracer (water mist from an ultrasonic room humidifier) in an air stream to detect and/or confirm the existence of cavities and local plume trajectories. Figures 2 and 3 show photographs of the model and the flow study set-up.

3. Procedure for Estimating $K_{c,avg}$

- a. Divide containment surface area into nine patches of equal area and replace each patch with a single point release. The nine release points correspond to those used in the EBR-II wind tunnel test and are identified by the following symbols:

BU = bottom upwind
 BL = bottom left side
 BR = bottom right side
 BD = bottom downwind
 MU = mid-height upwind

ML = mid-height left side
 MR = mid-height right side
 MD = mid-height downwind
 T = top

- b. The total gas release rate is Q ; the release rate at each of the release points is:

$$Q_i = Q/9 \quad (1)$$

- c. The concentration field near a building is given generally by:

$$X = K_c Q / Au \quad (2)$$

For multiple releases, each release makes the contribution:

$$X_i = K_{c,i} Q_i / Au \quad (3)$$

and the total concentration, for equal values of Q_i , becomes:

$$X = \sum_{i=1}^9 X_i = \sum_{i=1}^9 (K_{c,i} Q_i / Au) = \frac{1}{Au} \sum_{i=1}^9 K_{c,i} \frac{Q_i}{9} = \frac{\sum_{i=1}^9 Q_i}{Au} \frac{\sum_{i=1}^9 K_{c,i}}{9} = \frac{Q}{Au} K_{c,avg} \quad (4)$$

where,

$$K_{c,avg} = \frac{\sum_{i=1}^9 K_{c,i}}{9} \quad (5)$$

- d. The value of $K_{c,i}$ must be determined separately for each combination of wind direction, point source release location and intake location. This was done by first sketching the wind field in the building complex with cavity zones, streamlines and wakes determined by a combination of the information in Hosker (Reference 2), personal experience, and observations of a visual tracer moved about the model in the windstream. $K_{c,i}$ was then either calculated or estimated by analytical methods described in Section 4. Tables 1 and 2 show the individual values of $K_{c,i}$ for each of the $16 \times 9 \times 4 = 576$ combinations, and the values of $K_{c,avg}$.

- e. To combine the $K_{c,avg}$ values with wind frequency data, use:

$$X/Q \text{ (sec/m}^3\text{)} = \frac{K_{c,avg}}{Au_t} \quad (6)$$

where,

A = projected area of containment = 1685m^2

u_t = wind speed at an average elevation for the complex or about 60 ft above grade (m/s).

4. Calculation of $K_{C,i}$

$K_{C,i}$ in Equation 5 is obtained from Equation 3 after X_i is determined by an independent calculation using the Gaussian plume model outlined in Table 1. This model includes provisions for partial division of some released material from the plume (F_q), ground reflection (F_r), entrapment of released material in a building cavity with resulting establishment of a Gaussian wake plume having initial dimensions $\sigma_{z,0}$ and $\sigma_{y,0}$ and plume sigma growth according to the Halitsky jet plume model for PG stability C. The choice of PG-C was based on a comparison of predicted values of $K_{C,i}$ using the model in Table 1 against observed values of $K_{C,i}$ in the EBR-II wind tunnel model tests.

The 16 figures in Appendix I show drawings of the wind flow patterns for each wind direction used to determine values of $K_{C,i}$.

Table 2 provides a summary of $K_{C,avg}$ values.

5. References


1. Halitsky, J. (1989): A Jet Plume Model for Short Stacks, JAPCA J. v 39, No. 6, pp. 856-858.
2. Hosker, R.P., Jr. (1984): Flow and Diffusion Near Obstacles. Chapter 7 in Atmospheric Science and Power Production, D. Randerson, ed., U.S. DOE Pub. DE84005177, NTIS DOE/TIC-27601.

0 0 1 0 0 0 1 0 0 3 2

TABLE 2. $K_{c,avg}$ APPROXIMATION FOR A DIFFUSE LEAK
FROM THE COOK NUCLEAR PLANT CONTAINMENT STRUCTURES
WITH RECEPTORS AT THE CONTROL ROOM INTAKES

Values of $K_{c,avg}$				
Release from	Unit 1	Unit 1	Unit 2	Unit 2
Receptor at	Intake 1	Intake 2	Intake 1	Intake 2
Wind Direction (degrees from)				
000	1.5	0.5	0	0
022.5	1.3	0.4	0	0.4
045	3.7	0.7	0	0.5
067.5	0.8	0.6	0.6	1.1
090	1.2	0.6	0.4	1.7
112.5	1.6	0.4	0.5	1.3
135	1.3	0.3	1.3	0.9
157.5	0.4	0.3	1.3	0.3
180	0.2	0	0.6	2.3
202.5	0.1	0	0.1	0
225	0	0	0	0
247.5	0	0	0	0.1
270	0.7	0	0.2	1.8
292.5	1.8	0.2	0	0.7
315	1.8	0.2	0	0.7
337.5	0	0	0	0

0 0 1 0 0 0 1 0 0 3 3



SCALE: 1 IN = 100 FT

FIGURE 1. D.C. COOK NUCLEAR PLANT

J. HALITSKY
12 NOV. 1992
18 JAN 1993

REV.







FIGURE 2. PHOTOGRAPHS OF SCALE MODEL





FIGURE 3. PHOTOGRAPHS OF SCALE MODEL IN WIND STREAM

0 0 1 0 0 0 1 0 0 0

APPENDIX I

WIND PATTERNS USED TO ESTIMATE $K_{c,i}$ VALUES

001000010007

TRUE NORTH

PLANT NORTH

623

633

620

661

TRAJECTORIES
STARTING AT
ELEV. 64.5

ROOF ELEVATION

CAVITY
BOUNDARIES
AT ELEV.

64.5 ---

66.4 ---

70.8 ---

UNIT 1
INTAKES

UNIT 1
IL
770 (TOP)
ID
650

LAKE
580

594

638

661

717

663

678

707

682

GRADE
608

WAKE
AT L.S.

UNIT 2
INTAKES

UNIT 2
2L
770 (TOP)
2D

EL 580 WATER LINE

DOWN
EL 594

FLAT

EL 594

DOWN

EL 608

FLAT

DONALD C. COOK
NUCLEAR PLANT

WIND 000°

SCALE: 1 IN = 100 FT

100

00100500089

J. HALITSKY
12 NOV. 1992
REV. 18 JAN. 1973

00100010088

TRUE NORTH

PLANT-NORTH

633

661

620

623

629

626

ROOF ELEVATION

647

649

646

640

638

625

644

UNIT 1
INTAKES

UNIT 1

770
(TOP)

683

650

678

707

632

678

682

650

621

63

683

770
(TOR)

644

646

647

649

UNIT 2
INTAKES

UNIT 2

770
(TOR)

644

646

647

649

WAKE
STAB. C

WAKE

DONALD C. COOK
NUCLEAR PLANT

WIND 022.5°

SCALE: 1 IN = 100 FT

J. HALITSKY

12 NOV. 1992

REV. 18 JAN. 1993

100 0 0 1 0 0 5 0 0 0 9 0

LAKE
580

EL 580 WATER LINE

DOWN

EL 594

FLAT

EL 594

DOWN


EL 608

FLAT

EL 608

J. HALITSKY
12 NOV. 1992
18 JAN. 1993

0 0 1 0 0 0 1 0 0 9 0



SCALE: 1 IN = 100 FT

0 0 1 0 0 5 0 0 0 9 2

J. HALITSKY
12 NOV. 1992
REV. 18 JAN 1993

REV. 18 JAN. 1993

00100010092

TRUE NORTH

PLANT NORTH

623

633

620

661

16.39°

ROOF ELEVATION

629

626

647

649

646

640

638

625

644

UNIT 1
INTAKES

1D UNIT

683

112.5°

770 (TOP)

665

650

682

678

650

GRADE
608

LAKE
580

594

638

661

717

661

663

707

632

UNIT 2
INTAKES

2D UNIT 2

683

631

650

682

678

650

621

650

662 (BOTTOM)

770 (TOP)

624

640

646

647

649

EL 580 WATER LINE

DOWN

EL 594

FLAT

EL 594

DOWN

EL 608

FLAT

DONALD C. COOK
NUCLEAR PLANT

WIND 112.5°

SCALE: 1 IN = 100 FT

100


00100500094

J. HALITSKY

12 NOV. 1992

REV. 18 JAN. 1993

00100010095



DONALD C. COOK
NUCLEAR PLANT

SCALE: 1 IN = 100 FT
102

00100500095

J. HALITSKY
12 NOV. 1992
REV. 18 JAN. 1993

0 0 1 0 0 0 1 0 0 9 4

LAKE
580

EL 580 WATER LINE

DOWN
EL 594

FLAT

EL 594

DOWN

EL 608

FLAT

SCALE: 1 IN = 100 FT

100 0 0 1 0 0 5 0 0 0 9 6

TRUE NORTH

PLANT-NORTH

623

633

620

661

16.39°

ROOF ELEVATION

629

626

640

625

638

644

647

649

646

UNIT 1
INTAKES

683

UNIT 1

770 (TOP)

100

650

665

650

682

678

594

638

661

717

661

663

707

632

GRADE
608

UNIT 2
INTAKES

678

682

650

678

650

621

631

UNIT 2

770 (TOP)

20

644

662 (BOTTOM)

640

647

649

646

DONALD C. COOK
NUCLEAR PLANT

WIND 157.5°

J. HALITSKY
12 NOV. 1992

REV. 18 JAN. 1993

0010000100073

LAKE
580

EL 580 WATER LINE

DOWN
EL 594

FLAT

EL 594

DOWN

EL 608

FLAT

SCALE: 1 IN = 100 FT

100 0 1 0 0 5' 0 0 0 9 7

TRUE NORTH

PLANT NORTH

623

633

620

661

629

626

ROOF ELEVATION

647

649

646

638

640

625

UNIT 1
INTAKES

UNIT 1

OIL

770 (TOP)

682

650

678

707

632

GRAD
608

594

638

661

717

661

663

UNIT 2
INTAKES

678

682

650

621

631

UNIT 2

770 (TOP)

644

646

647

649

662 (BOTTOM)

640


DONALD C. COOK
NUCLEAR PLANT

WIND 180°

J. HALITSKY
12 NOV. 1992

REV. 18 JAN. 1993


0 0 1 0 0 0 1 0 0 9 6



DONALD C. COOK
NUCLEAR PLANT

WIND 202.5°


SCALE: 1 IN = 100 FT



0 0 1 0 0 5 0 0 0 9 8

J. HALITSKY
12 NOV. 1992
REV 18 JAN. 1993

0 0 1 0 0 0 1 0 0 9 7



DONALD C. COOK
NUCLEAR PLANT

SCALE: 1 IN = 100 FT

100 0 0 1 0 0 5 0 0 0 9 9

J. HALITSKY
12 NOV. 1992

REV. 18 JAN. 1993

00100010093

TRUE NORTH

PLANT NORTH

623

633

620

661

16.39°

ROOF ELEVATION

629

626

647

649

646

640

625

638

644

UNIT 1 INTAKES

UNIT 1

770 (TOP)

120

650

665

650

682

678

707

GRADE 608

594

638

661

717

661

663

LAKE 580

UNIT 2 INTAKES

UNIT 2

770 (TOP)

120

662 (BOTTOM)

640

682

678

650

621

631

644

646

647

649

247.5°

EL 580 WATER LINE

DOWN

EL 594

FLAT

EL 594

DOWN

EL 608

FLAT

DONALD C. COOK
NUCLEAR PLANT

WIND 247.5°

SCALE: 1 IN = 100 FT

100

0010050010
J. HALITSKY
12 NOV. 1992
REV. 18 JAN. 1993



