

Attachment 3 to AEP:NRG:1124B

PROPOSED REVISED
TECHNICAL SPECIFICATION PAGES

9506060418 950525
PDR ADDCK 05000315
P PDR

DESIGN FEATURES

DESIGN PRESSURE AND TEMPERATURE

5.2.2 The reactor containment building is designed and shall be maintained in accordance with the original design provisions contained in Section 5.2.2 of the FSAR.

PENETRATIONS

5.2.3 Penetrations through the reactor containment building are designed and shall be maintained in accordance with the original design provisions contained in Section 5.4 of the FSAR with allowance for normal degradation pursuant to the applicable Surveillance Requirements.

5.3 REACTOR CORE

FUEL ASSEMBLIES

5.3.1 The reactor core shall contain 193 fuel assemblies with each fuel assembly containing 204 fuel rods clad with Zircaloy-4. ^{add 'A'} Each fuel rod shall have a nominal active fuel length of 144 inches. The initial core loading shall have a maximum enrichment of 3.35 weight percent U-235. Reload fuel shall be similar in physical design to the initial core loading and shall have a maximum nominal enrichment of 4.95 weight percent U-235.

CONTROL ROD ASSEMBLIES

5.3.2 The reactor core shall contain 53 full length and no part length control rod assemblies. The full length control rod assemblies shall contain a nominal 142 inches of absorber material. The nominal values of absorber material shall be 80 percent silver, 15 percent indium and 5 percent cadmium. All control rods shall be clad with stainless steel tubing.

5.4 REACTOR COOLANT SYSTEM

DESIGN PRESSURE AND TEMPERATURE

5.4.1 The reactor coolant system is designed and shall be maintained:



11

DESIGN FEATURES

5.3 REACTOR CORE

FUEL ASSEMBLIES

5.3.1 The reactor core shall contain 193 fuel assemblies with each fuel assembly containing 264 fuel rods clad with Zircaloy-4. Each fuel rod shall have a nominal active fuel length of 144 inches. The initial core loading shall have a maximum enrichment of 3.3 weight percent U-235. Reload fuel shall be similar in physical design to the initial core loading and may be nominally enriched up to 4.95 weight percent U-235.

CONTROL ROD ASSEMBLIES

5.3.2 The reactor core shall contain 53 full length and no part length control rod assemblies. The full length control rod assemblies shall contain a nominal 142 inches of absorber material. The nominal values of absorber material shall be 80 percent silver, 15 percent indium and 5 percent cadmium. All control rods shall be clad with stainless steel tubing.

5.4 REACTOR COOLANT SYSTEM

DESIGN PRESSURE AND TEMPERATURE

5.4.1 The reactor coolant system is designed and shall be maintained:

- a. In accordance with the code requirements specified in Section 4.1.6 of the FSAR, with allowance for normal degradation pursuant to the applicable Surveillance Requirements.
- b. For a pressure of 2485 psig, and
- c. For a temperature of 650°F, except for the pressurizer which is 680°F.

"A"

except that limited substitutions of zirconium alloy or stainless steel filler rods, in accordance with NRC-approved applications of fuel rod configurations, may be used.

Attachment 2 to AEP:NRC:1124B

EXISTING TECHNICAL SPECIFICATIONS
PAGES MARKED TO REFLECT PROPOSED CHANGES

5.0 DESIGN FEATURES

5.2 CONTAINMENT (Continued)

DESIGN PRESSURE AND TEMPERATURE

- 5.2.2 The reactor containment building is designed and shall be maintained in accordance with the original design provisions contained in Section 5.2.2 of the FSAR.

PENETRATIONS

- 5.2.3 Penetrations through the reactor containment building are designed and shall be maintained in accordance with the original design provisions contained in Section 5.4 of the FSAR with allowance for normal degradation pursuant to the applicable Surveillance Requirements.

5.3 REACTOR CORE

FUEL ASSEMBLIES

- 5.3.1 The reactor core shall contain 193 fuel assemblies with each fuel assembly containing 204 fuel rods clad with Zircaloy-4, except that limited substitutions of zirconium alloy or stainless steel filler rods, in accordance with NRC-approved applications of fuel rod configurations, may be used. Each fuel rod shall have a nominal active fuel length of 144 inches. The initial core loading shall have a maximum enrichment of 3.35 weight percent U-235. Reload fuel shall be similar in physical design to the initial core loading and shall have a maximum nominal enrichment of 4.95 weight percent U-235.

CONTROL ROD ASSEMBLIES

- 5.3.2 The reactor core shall contain 53 full length and no part length control rod assemblies. The full length control rod assemblies shall contain a nominal 142 inches of absorber material. The nominal values of absorber material shall be 80 percent silver, 15 percent indium and 5 percent cadmium. All control rods shall be clad with stainless steel tubing.

5.4 REACTOR COOLANT SYSTEM

DESIGN PRESSURE AND TEMPERATURE

- 5.4.1 The reactor coolant system is designed and shall be maintained:

5.0 DESIGN FEATURES

5.3 REACTOR CORE

FUEL ASSEMBLIES

- 5.3.1 The reactor core shall contain 193 fuel assemblies with each fuel assembly containing 264 fuel rods clad with Zircaloy-4, except that limited substitutions of zirconium alloy or stainless steel filler rods, in accordance with NRC-approved applications of fuel rod configurations, may be used. Each fuel rod shall have a nominal active fuel length of 144 inches. The initial core loading shall have a maximum enrichment of 3.3 weight percent U-235. Reload fuel shall be similar in physical design to the initial core loading and may be nominally enriched up to 4.95 weight percent U-235.

CONTROL ROD ASSEMBLIES

- 5.3.2 The reactor core shall contain 53 full length and no part length control rod assemblies. The full length control rod assemblies shall contain a nominal 142 inches of absorber material. The nominal values of absorber material shall be 80 percent silver, 15 percent indium and 5 percent cadmium. All control rods shall be clad with stainless steel tubing.

5.4 REACTOR COOLANT SYSTEM

DESIGN PRESSURE AND TEMPERATURE

- 5.4.1 The reactor coolant system is designed and shall be maintained:
- a. In accordance with the code requirements specified in Section 4.1.6 of the FSAR, with allowance for normal degradation pursuant to the applicable Surveillance Requirements.
 - b. For a pressure of 2485 psig, and
 - c. For a temperature of 650°F, except for the pressurizer which is 680°F.