



Washington Public Power Supply System
A JOINT OPERATING AGENCY

Central File

P. O. Box 968

3000 GEO. WASHINGTON WAY

RICHLAND, WASHINGTON 99352

PHONE (509) 375-5000

October 30, 1980

602-80-236

Docket No. 50-397

Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 North California Blvd.
Walnut Creek, CA 94596

Attention: Mr. R. H. Engelken, Director

Gentlemen:

Subject: WPPSS NUCLEAR PROJECT NO. 2
IE BULLETIN NO. 78-04

Reference: D. L. Renberger to R. H. Engelken, same subject, dated
April 27, 1978

The above-referenced letter informed you of a proposed design for WNP-2 which utilizes a NAMCO type D2400X limit switch to be mounted on a valve within the Primary Containment. Our further analysis reveals that the said limit switch does not actually perform a safety-related nor a vital control function. Hence, we are removing our commitment for further actions to ensure that the environmentally qualified model of said switch will be used in the above-mentioned application.

Please advise us if you have any further questions on the subject.

Very truly yours,

D. L. Renberger

D. L. RENBERGER
Assistant Director,
Technology

DLR:BHS:cd

cc: JJ Verderber - B&R
JR Lewis - BPA
ND Lewis - EFSEC, Olympia
AD Toth - NRC
V. Stello - NRC
RE Snaith - B&R
B. Wood - NUS Corporation
WNP-2 Files

US NRC
DISTRIBUTION SERVICES
BRANCH

1980 NOV 17 PM 12 57

RECEIVED DISTRIBUTION
SERVICES UNIT

8011280 093

80-169

